



Tentative Interim Amendment

# NFPA<sup>®</sup> 10

## *Standard for Portable Fire Extinguishers*

**2018 Edition**

**Reference:** 6.1.3.10.6.1(new)

**TIA 18-1**

(SC 17-8-17 / TIA Log #1268)

**Note:** Text of the TIA was issued and approved for incorporation into the document prior to printing.

*1. Add new text to read as follows:*

**6.1.3.10.6** For fire-resistance-rated walls, only surface-mounted cabinets or listed fire-rated cabinets shall be installed.

**6.1.3.10.6.1** The provisions of 6.1.3.10.6 shall not apply to existing installations.

**Issue Date:** August 17, 2017

**Effective Date:** September 6, 2017

(Note: For further information on NFPA Codes and Standards, please see [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo))

Copyright © 2017 All Rights Reserved  
NATIONAL FIRE PROTECTION ASSOCIATION