



Tentative Interim Amendment

# NFPA<sup>®</sup> 101<sup>®</sup>

## *Life Safety Code*<sup>®</sup>

**2018 Edition**

**Reference:** 40.1.2.1.3

**TIA 18-1**

*(SC 17-8-24 / TIA Log #1263)*

**Note:** Text of the TIA was issued and approved for incorporation into the document prior to printing.

*1. Revise paragraph 40.1.2.1.3 to read as follows:*

**40.1.2.1.3\* High-Hazard Industrial Occupancy.** High-hazard industrial occupancies shall include all of the following:

1. Existing industrial occupancies that conduct industrial operations that use, process, store, or handle high-hazard contents, as defined by 6.2.2.4
2. New industrial occupancies that conduct industrial operations that use, process, store, or handle high-hazard contents or hazardous materials in excess of the maximum allowable quantities (MAQ) as permitted by the fire code
3. Industrial occupancies in which incidental high-hazard operations in low- or ordinary-hazard occupancies that are protected in accordance with Section 8.7 and 40.3.2 are not required to be the basis for overall occupancy classification

**Issue Date:** August 17, 2017

**Effective Date:** September 6, 2017

**(Note: For further information on NFPA Codes and Standards, please see [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo))**

Copyright © 2017 All Rights Reserved

NATIONAL FIRE PROTECTION ASSOCIATION