



Tentative Interim Amendment

# NFPA<sup>®</sup> 101<sup>®</sup>

## *Life Safety Code*<sup>®</sup>

### 2018 Edition

**Reference:** 14.7.6, 15.7.6(new), 16.7.6 and 17.7.6(new)

**TIA 18-6**

(SC 17-12-14 / TIA Log #1326)

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 101<sup>®</sup>, *Life Safety Code*<sup>®</sup>, 2018 edition. The TIA was processed by the Technical Committee on Educational and Day-Care Occupancies, and the Correlating Committee on Safety to Life, and was issued by the Standards Council on December 6, 2017, with an effective date of December 26, 2017.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a public input of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

*1. Revise 14.7.6 to read as follows:*

**14.7.6 Integrated Fire Protection and Life Safety Systems.** Integrated fire protection and life safety systems shall be tested in accordance with 9.11.4.1.

*2. Add a new 15.7.6 to read as follows:*

**15.7.6 Integrated Fire Protection and Life Safety Systems.**

**15.7.6.1** Integrated fire protection and life safety systems shall be tested in accordance with 9.11.4.1.

**15.7.6.2** Integrated fire protection and life safety systems in high-rise buildings shall be tested in accordance with 9.11.4.2.

*3. Revise 16.7.6 to read as follows:*

**16.7.6 Integrated Fire Protection and Life Safety Systems.** Integrated fire protection and life safety systems shall be tested in accordance with 9.11.4.1.

4. Add a new 17.7.6 to read as follows:

**17.7.6 Integrated Fire Protection and Life Safety Systems.**

**17.7.6.1** Integrated fire protection and life safety systems shall be tested in accordance with 9.11.4.1.

**17.7.6.2** Integrated fire protection and life safety systems in high-rise buildings shall be tested in accordance with 9.11.4.2.

**Issue Date:** December 6, 2017

**Effective Date:** December 26, 2017

(Note: For further information on NFPA Codes and Standards, please see [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo))

Copyright © 2017 All Rights Reserved

NATIONAL FIRE PROTECTION ASSOCIATION