



Tentative Interim Amendment

NFPA[®] 101[®]

Life Safety Code[®]

2018 Edition

Reference: 18.7.10, 19.7.10, 20.7.10 and 21.7.10

TIA 18-8

(SC 17-12-16 / TIA Log #1330)

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 101[®], *Life Safety Code[®]*, 2018 edition. The TIA was processed by the Technical Committee on Health Care Occupancies, and the Correlating Committee on Safety to Life, and was issued by the Standards Council on December 6, 2017, with an effective date of December 26, 2017.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a public input of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

1. *Revise 18.7.10 to read as follows:*

18.7.10 Integrated Fire Protection and Life Safety Systems. Integrated fire protection and life safety systems shall be tested in accordance with 9.11.4.1.

2. *Revise 19.7.10 to read as follows:*

19.7.10 Integrated Fire Protection and Life Safety Systems.

19.7.10.1 Integrated fire protection and life safety systems shall be tested in accordance with 9.11.4.1.

19.7.10.2 Integrated fire protection and life safety systems in high-rise buildings shall be tested in accordance with 9.11.4.2.

3. *Revise 20.7.10 to read as follows:*

20.7.10 Integrated Fire Protection and Life Safety Systems. Integrated fire protection and life safety systems shall be tested in accordance with 9.11.4.1.

4. *Revise 21.7.10 to read as follows:*

21.7.10 Integrated Fire Protection and Life Safety Systems.

21.7.10.1 Integrated fire protection and life safety systems ~~in existing high-rise buildings~~ shall be tested in accordance with 9.11.4.1.

21.7.10.2 Integrated fire protection and life safety systems in high-rise buildings shall be tested in accordance with 9.11.4.2.

Issue Date: December 6, 2017

Effective Date: December 26, 2017

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2017 All Rights Reserved

NATIONAL FIRE PROTECTION ASSOCIATION