



Tentative Interim Amendment

# NFPA 13D

## Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes

2013 Edition

**Reference:** 6.5.3

**TIA 13-2**

(SC 12-3-3/TIA Log #1041)

**Note:** Text of the TIA issued and incorporated into the text of 6.3.4, therefore no separate publication is necessary.

*1. Move 6.5.3 to 6.3.4 as follows:*

**6.3.4** A warning sign, with minimum 1/4 in. letters, shall be affixed adjacent to the main shutoff valve and shall state the following:

**WARNING:** The water system for this home supplies fire sprinklers that require certain flows and pressures to fight a fire. Devices that restrict the flow or decrease the pressure or automatically shut off the water to the fire sprinkler system, such as water softeners, filtration systems, and automatic shutoff valves, shall not be added to this system without a review of the fire sprinkler system by a fire protection specialist. Do not remove this sign.

**Issue Date:** August 9, 2012

**Effective Date:** August 29, 2012

(Note: For further information on NFPA Codes and Standards, please see [www.nfpa.org/codelist](http://www.nfpa.org/codelist))

Copyright © 2012 All Rights Reserved  
NATIONAL FIRE PROTECTION ASSOCIATION