



Tentative Interim Amendment

NFPA[®] 13

Standard for the Installation of Sprinkler Systems

2019 Edition

Reference: Table 17.2.2.1 note

TIA 19-1

(SC 18-4-1 / TIA Log #1351)

Note: Text of the TIA was issued and approved for incorporation into the document prior to printing.

1. *Revise Table 17.2.2.1 note to read as follows:*

* Limited to single- and double-row racks with minimum ~~Minimum~~ 8 ft (2.4 m) ~~aisle~~ aisles.

Issue Date: August 14, 2018

Effective Date: September 3, 2018

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2018 All Rights Reserved

NATIONAL FIRE PROTECTION ASSOCIATION