



Errata

NFPA 15

Standard for Water Spray Fixed Systems for Fire Protection

2017 Edition

Reference: 6.1.2.2 and 6.1.2.3

Errata No.: 15-17-2

The Committee on Water Spray Fixed Systems notes the following errors in the 2017 edition of NFPA 15, *Standard for Water Spray Fixed Systems for Fire Protection*.

1. Correct the units of measure as indicated below:

6.1.2.2 The electrical clearances in Table 6.1.2.2 shall apply to altitudes of 3300 ft (1000 ~~ft~~m) or less.

6.1.2.3 At altitudes in excess of 3300 ft (1000 ~~ft~~m), the electrical clearance shall be increased at the rate of 1 percent for each 330 ft (100 ~~ft~~m) increase in altitude above 3300 ft (1000 m).

Issue Date: March 20, 2019

(Note: Electronic products and pamphlet reprints may have this errata incorporated. For current information about the NFPA Codes and Standards, including this errata, please see www.nfpa.org/docinfo)

Copyright © 2019 All Rights Reserved

NATIONAL FIRE PROTECTION ASSOCIATION