



Tentative Interim Amendment

NFPA[®] 24

Standard for the Installation of Private Fire Service Mains and Their Appurtenances

2019 Edition

Reference: 2.3.1, 2.3.2, and Table 10.2.1.1

TIA 19-1 REVISED October 4, 2019

(TIA Log #1425)

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 24, *Standard for the Installation of Private Fire Service Mains and Their Appurtenances*, 2019 edition. The TIA was processed by the Technical Committee on Private Water Supply Piping Systems, and the Correlating on Automatic Sprinkler Systems, and was issued by the Standards Council on July 17, 2019, with an effective date of August 6, 2019.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards development procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a public input of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards development process.

1. Add to 2.3.1 ASME Publications as follows:

ASME B16.15, Cast Copper Alloy Threaded Fittings: Classes 125 and 250, 2018.

ASME B16.18, Cast Copper Alloy Solder Joint Pressure Fittings, 2018.

ASME B16.22, Wrought Copper and Copper Alloy Solder-Joint Pressure Fittings, 2018.

2. Add to 2.3.2 ASTM Publications as follows:

ASTM A403/A403M, Standard Specification for Wrought Austenitic Stainless Steel Piping Fittings, 2018a.

3. Revise Table 10.2.1.1 to read as follows:

Table 10.2.1.1 Fittings Materials Dimensions

| Materials and Dimensions | Standard |
|---|-------------|
| Cast Iron | |
| ... | |
| Ductile Iron | |
| ... | |
| Malleable Iron | |
| ... | |
| Copper | |
| <u>Wrought Copper and Copper Alloy Solder-Joint Pressure Fittings</u> | ASME B16.22 |
| <u>Cast Copper Alloy Solder Joint Pressure Fittings</u> | ASME B16.18 |
| Bronze Fittings | |

Cast Copper Alloy Threaded Fittings: Classes 125 and 250

ASME B16.15

Stainless Steel

Specification for Wrought Austenitic Stainless Steel Piping Fittings

ASTM A403/A403M

Issue Date: July 17, 2019

Effective Date: August 6, 2019

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2019 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION