



Tentative Interim Amendment

## NFPA<sup>®</sup> 25

### *Standard for the Inspection, Testing and Maintenance of Water-Based Fire Protection Systems*

**2017 Edition**

**Reference:** 6.3.1.1.2 (New) and 6.3.1.6.2

**TIA 17-1**

*(SC 16-8-10 / TIA Log #1221)*

**Note:** Text of the TIA was issued and approved for incorporation into the document prior to printing.

*1. Add a new paragraph 6.3.1.1.2 to read as follows:*

**6.3.1.1.2** Pressure gauges maintained in accordance with 8.3.3.2.2 shall be provided for the test.

*2. Revise paragraph 6.3.1.6.2 to read as follows:*

**6.3.1.6.2** Pressure gauges maintained in accordance with Chapter 13 shall be provided for the test.

**Issue Date:** August 4, 2016

**Effective Date:** August 24, 2016

(Note: For further information on NFPA Codes and Standards, please see [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo))

Copyright © 2016 All Rights Reserved  
NATIONAL FIRE PROTECTION ASSOCIATION