



Errata

NFPA 70®

National Electrical Code®

2020 Edition

Reference: 225.30

Errata No: 70-20-3

The National Electrical Code-Making Panel 10 and the Correlating Committee on National Electrical Code note the following error in the 2020 edition of NFPA 70, *National Electrical Code*.

1. *Update the references in 225.30 to read as follows:*

225.30 Number of Supplies. A building or other structure that is served by a branch circuit or feeder on the load side of a service disconnecting means shall be supplied by only one feeder or branch circuit unless permitted in 225.30(A) through (EF). For the purpose of this section, a multiwire branch circuit shall be considered a single circuit.

Where a branch circuit or feeder originates in these additional buildings or other structures, only one feeder or branch circuit shall be permitted to supply power back to the original building or structure, unless permitted in 225.30(A) through (EF).

Issue Date: March 10, 2020

(Note: Electronic products and pamphlet reprints may have this errata incorporated. For current information about the NFPA Codes and Standards, including this errata, please see www.nfpa.org/docinfo)

Copyright © 2020 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION