



Tentative Interim Amendment

NFPA[®] 72[®]

National Fire Alarm and Signaling Code[®]

2019 Edition

Reference: A.24.3.10 and I.1.2.14

TIA 19-1

(SC 18-8-25 / TIA Log #1377)

Note: Text of the TIA was issued and approved for incorporation into the document prior to printing.

1. *Revise A.24.3.10 to read as follows:*

A.24.3.10 ~~A fire~~ Fire emergency voice/alarm communications systems (EVACS) ~~control unit that is~~ are listed in accordance with ANSI/UL 864, *Standard for Control Units and Accessories for Fire Alarm Systems*, ~~or an emergency alarm system control unit~~ can be used for MNS as long as the control unit has also been evaluated to ANSI/UL 2572, *Mass Notification Systems*. ~~The unique requirements in Chapter 24 for mass notification systems are included in ANSI/UL 2572. A control unit is permitted to provide multiple life safety services when evaluated to the respective requirements.~~ A control unit only listed in accordance with ANSI/UL 2572, *Mass Notification Systems*, cannot be used as a fire alarm control unit.

2. *Add a new reference to Annex I to read as follows:*

I.1.2.14 UL Publications.

...

ANSI/UL 2572, *Mass Notification Systems*, 2nd edition, 2016.

Issue Date: August 14, 2018

Effective Date: September 3, 2018

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2018 All Rights Reserved

NATIONAL FIRE PROTECTION ASSOCIATION