



## Errata

## NFPA 99

### *Health Care Facilities Code*

#### 2018 Edition

**Reference:** 6.7.5.1.2.2 and 6.7.6.2.1.5(B)

**Errata No:** 99-18-1

The Technical Committee on Electrical Systems and the Correlating Committee on Health Care Facilities notes the following errors in the 2018 edition of *NFPA 99, Health Care Facilities Code*.

*1. Correct 6.7.5.1.2.2 to read as follows:*

**6.7.5.1.2.2** The following portions of Article 700 of *NFPA 70* shall be amended as follows:

- (1) 700.4 shall not apply.
- (2) 700.10-(D)(1) through (3) shall not apply.
- (3) 700.17 Branch Circuits for Emergency Lighting. Branch circuits that supply emergency lighting shall be installed to provide service from a source complying with 700.12 when the normal supply for lighting is interrupted or where single circuits supply luminaires containing secondary batteries.
- (4) 700.2832 shall not apply.

*2. Correct 6.7.6.2.1.5(B) to read as follows:*

**6.7.6.2.1.5 Life Safety Branch.**

**(A)** For the purposes of this code, Article 700 of *NFPA 70* shall only be applied to the life safety branch.

**(B)** The following portions of Article 700 of *NFPA 70* shall be amended as follows:

- (1) 700.4 shall not apply.
- (2) 700.10-(D)(1) through (3) shall not apply.
- (3) 700.17 Branch Circuits for Emergency Lighting. Branch circuits that supply emergency lighting shall be installed to provide service from a source complying with 700.12 when the normal supply for lighting is interrupted or where single circuits supply luminaires containing secondary batteries.
- (4) 700.2832 shall not apply.

Issue Date: September 22, 2017

**(Note: Electronic products and pamphlet reprints may have this errata incorporated. For current information about the NFPA Codes and Standards, including this errata, please see [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo))**