



## NFPA® 99

### *Health Care Facilities Code*

#### 2021 Edition

**Reference:** 5.1.3.10.2.4

**TIA 99-21-1**

(SC 20-12-18 / TIA Log #1521)

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 99, *Health Care Facilities Code*, 2021 edition. The TIA was processed by the Technical Committee on Piping Systems, the Correlating Committee on Health Care Facilities and was issued by the Standards Council on December 3, 2020, with an effective date of December 23, 2020.

*1. Revise 5.1.3.10.2.4 to read as follows:*

**5.1.3.10.2.4** Cryogenic fluid central supply systems shall have a minimum work space clearance of 3 ft (1 m) around ~~three sides of the storage container, three sides of the vaporizer(s), and the~~ cabinet opening or front side of the pressure-regulating manifold for system maintenance and operation. [55:17.2.4].

**Issue Date:** December 3, 2020

**Effective Date:** December 23, 2020

(Note: For further information on NFPA Codes and Standards, please see [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo))

Copyright © 2020 All Rights Reserved  
NATIONAL FIRE PROTECTION ASSOCIATION