Utah State Fire Marshal's Office

Fire Alarm Certification Program
Basic Fire Alarm Technician
Task Book
September 2016

Task Book Assigned To:
Individual's Name
Company Name
Date Issued by State Fire Marshal's Office

The material contained in this book accurately defines the performance expected of the position for which it was developed. This task book is approved for use as a position qualification document in accordance with the instructions contained herein.

UTAH STATE FIRE MARSHAL'S OFFICE BASIC FIRE ALARM TECHNICIAN PROGRAM September 2016

EVALUATOR

DO NOT COMPLETE THIS UNLESS YOU ARE RECOMMEDNING THE APPLICANT FOR CERTIFICATION VERIFICATION OF COMPLETED TASK BOOK FOR THE POSITION OF BASIC; FIRE ALARM; or MASTER TECHNICIAN FINAL EVALUATOR'S VERIFICATION I verify that all tasks have been performed and are documented with appropriate initials. FINAL EVALUATOR'S SIGNATURE AND DATE EVALUATOR'S PRINTED NAME, TITLE, BUSINESS NAME, AND PHONE NUMBER FINAL EVALUATOR'S SIGNATURE AND DATE EVALUATOR'S PRINTED NAME, TITLE, BUSINESS NAME, AND PHONE NUMBER FINAL EVALUATOR'S SIGNATURE AND DATE EVALUATOR'S PRINTED NAME, TITLE, BUSINESS NAME, AND PHONE NUMBER

UTAH STATE FIRE MARSHAL

TASK BOOK for

BASIC FIRE ALARM TECHNICIAN

A Task Book (TB) has been developed for this position to meet the requirements as established in Utah Code R710-11 as administered by the Utah State Fire Marshal's Office. The Task Book lists the performance requirements (tasks) for the specific position in a format that allows an applicant to be evaluated against written guidelines. Successful performance of all tasks, as observed and recorded by an evaluator, will result in a recommendation to the State Fire Marshal's Office that the applicant is eligible to be certified as a Basic Fire Alarm Technician.

Evaluation and confirmation of the applicant's performance of all the tasks may involve more that one evaluator. All bullet statements within a task that require an action (contain an action verb) must be demonstrated before that task can be signed off. A more detailed description of this process, definitions of terms, and responsibilities are included in NFPA 72.

The Company is responsible for:

- Selecting technician candidate that meet its needs and meet employment requirements.
- Ensuring that the technician candidate meets the requirements included in the prerequisites for this certification.
- Explaining to the technician candidate the purpose and processes of the Task Book as well as the applicant's responsibilities.
- Providing opportunities for evaluation and/or making the technician candidate available for evaluation.
- Provide an evaluator for assignments.
- Tracking progress of the technician candidate.
- Confirming Task Book completion.
- Determining eligibility and recommendation for examination.

The Basic Technician Candidate is Responsible for:

- Reviewing and understanding the instructions in the Task Book.
- Identifying desired objectives/goals.
- Providing background information to an evaluator
- Satisfactorily demonstrating completion of all tasks listed in the Task Book.
- Assuring the Evaluation Record is complete.
- Notifying company personnel when the Task Book is completed and providing a copy.
- Keeping the original Task Book in personal records.

The Evaluator is Responsible for:

- Understanding the Fire Alarm Basic Technician Task Book, examination and certification program.
- Being qualified and proficient in the systems being evaluated.

- Meeting with the technician candidate and determining past experience, current qualifications, and desired objectives/goals.
- Reviewing tasks with the technician candidate.
- Explaining to the technician candidate the evaluation procedures that will be utilized and which objectives may be attained.
- Identifying tasks to be performed during the evaluation period.
- Accurately evaluating and recording demonstrated performance of tasks. Satisfactory performance shall be documented by dating and initialing completion of the task.

The Final Evaluator is Responsible for:

- Signing the verification statement inside the front cover of the Task Book when all tasks have been initiated and if the technician candidate is recommended for examination.

R710-11 Fire Alarm Inspection, Testing and Maintenance Manipulative Skills Task Book

		Business	Evaluator Initial,
		Address	Certification No.
	Explain how task was performed	where task was	Completion date
Task	and why.	Completed.	of task.
Determine if original installation			
drawings including floor plan			
and wiring diagrams are on site.			
Determine if the previous year's			
inspection and testing records are			
on site.			
Determine if the building has			
been remodeled or altered since			
the last inspection.			

	Visual Inspection	
Fire Alarm Control Panel (1) Fuses		
(2) Interfaced equipment		
(3) Lamps and LEDs		
(4) Primary power supply		
(5) Trouble signals		
In-building fire emergency voice/alarm communications equipment		
Batteries Check for corrosion or leakage, Tightness of connections, Electrolyte level in lead-acid batteries		
Remote annunciators		
Notification appliance circuit power extenders		
Remote power supplies		
Transient Suppressors (Lightning protection)		
Fiber-Optic Cable Connections		

Initiating Devices – Verify devices	
are free from damage, visible and	
unobstructed.	
(a) Air Sampling	
(h) Dust Datastans	
(b) Duct Detectors	
(c) Electromechanical releasing	
devices	
(d) Fire Extinguishing Systems or	
Suppression System Switches	
(a) Manual fine alama haves	
(e) Manual fire alarm boxes	
(f) Heat data store	
(f) Heat detectors	
(a) Dadient energy fine detectors	
(g) Radiant energy fire detectors	
(h) Video image smoke and fire	
detectors	
detectors	
(i) Smoke detectors	
(j) Projected beam smoke	
detectors	
detectors	
(k) Supervisory Signal Devices	
(k) Supervisory Signal Devices	
(l) Waterflow devices	
Combination Systems	
(a) Fire extinguisher monitoring	
device/systems	
(b) Carbon monoxide	
detectors/systems	
Fire alarm control interface and	
emergency control function	
interface.	
Guard's tour equipment	
Alarm Notification Appliances -	
verify that appliances are free of	
damage and are unobstructed	
Exit Marking Audible Notificatio	
Appliances	
F	
Area of refuge two-way	
Communication system	

(a) Control equipment (1) Fuses		
(2) Interfaces		
(3) Lamps		
(4) Primary (main Power supply)		
Secondary power batteries		
Initiating devices		
Notification appliances		
Mass notification system Transceivers		
Verify that no changes have been made that affect equipment performance		
	TESTING	
Monitoring company notified tha testing will begin and expected duration		
testing will begin and expected		
testing will begin and expected duration Building occupants notified that testing will begin and expected duration Precautions taken to prevent inadvertent actuation of		
testing will begin and expected duration Building occupants notified that testing will begin and expected duration Precautions taken to prevent		
testing will begin and expected duration Building occupants notified that testing will begin and expected duration Precautions taken to prevent inadvertent actuation of suppression systems Fire Alarm Control Panel - Inputs (1) Verify correct receipt of		

Mass notification System,

Et Alema Carta ID IO (
Fire Alarm Control Panel-Outputs (1) Verify operation of evacuation signals	
(2) Verify door unlocking mechanism	
(3) Verify magnetic door release	
(4) Verify smoke or fire/smoke damper operation	
(5) Verify fan shut-down where required	
FACP Circuit Supervision (1) Verify detection of open circuits	
(2) Verify detection of ground faults	
(3) Verify detection of loss of ac power	
(4) Verify detection of loss of secondary power supply (batteries)	
FACP Trouble Signals	
(1) Verify operation of audible	
and visual trouble signals.	
Verify ring-back feature	
where applicable. (2) Verify the intended	
function of disconnect	
switches.	
(3) Verify ground-fault	
Monitoring circuit.	
(4) Verify transmission of	
signals to off-premises	
location.	
Emergency communications	
Equipment	
(a) Amplifier/tone generators	
Verify switching and operation	
Of backup equipment.	

(b) Call-in signal silence	
, ,	
Operate/function and verify	
receipt of visual and	
audible signals at control	
unit.	
(c) Off-hook indicator (ring	
down)	
Install phone set or remove	
phone from hook and verify	
receipt of signal at control	
unit.	
(d) Phone jacks	
visually inspect phone jack	
and initiate communications	
path through jack.	
(e) Phone set	
Activate each phone set and	
verify correct operation.	
(f) System performance	
Operate system with a	
minimum of any five	
handsets simultaneously.	
Verify voice quality/clarity.	
verify voice quanty/ciarry.	
I .	
Engine-Driven Generator	
Engine-Driven Generator Verify operation of the generator	
Verify operation of the generator	
Verify operation of the generator Secondary (Standby) Power Supply	
Verify operation of the generator Secondary (Standby) Power Supply (1) Disconnect ac power and	
Verify operation of the generator Secondary (Standby) Power Supply (1) Disconnect ac power and verify trouble signal	
Verify operation of the generator Secondary (Standby) Power Supply (1) Disconnect ac power and verify trouble signal (2) Verify system's standby and	
Verify operation of the generator Secondary (Standby) Power Supply (1) Disconnect ac power and verify trouble signal (2) Verify system's standby and alarm current demand and	
Verify operation of the generator Secondary (Standby) Power Supply (1) Disconnect ac power and verify trouble signal (2) Verify system's standby and alarm current demand and verify the batteries ability to	
Verify operation of the generator Secondary (Standby) Power Supply (1) Disconnect ac power and verify trouble signal (2) Verify system's standby and alarm current demand and verify the batteries ability to meet the standby and alarm	
Verify operation of the generator Secondary (Standby) Power Supply (1) Disconnect ac power and verify trouble signal (2) Verify system's standby and alarm current demand and verify the batteries ability to meet the standby and alarm requirements	
Verify operation of the generator Secondary (Standby) Power Supply (1) Disconnect ac power and verify trouble signal (2) Verify system's standby and alarm current demand and verify the batteries ability to meet the standby and alarm requirements (3) Activate and run the alarm	
Verify operation of the generator Secondary (Standby) Power Supply (1) Disconnect ac power and verify trouble signal (2) Verify system's standby and alarm current demand and verify the batteries ability to meet the standby and alarm requirements (3) Activate and run the alarm under battery power for 5	
Verify operation of the generator Secondary (Standby) Power Supply (1) Disconnect ac power and verify trouble signal (2) Verify system's standby and alarm current demand and verify the batteries ability to meet the standby and alarm requirements (3) Activate and run the alarm under battery power for 5 minutes or 15 minutes if the	
Verify operation of the generator Secondary (Standby) Power Supply (1) Disconnect ac power and verify trouble signal (2) Verify system's standby and alarm current demand and verify the batteries ability to meet the standby and alarm requirements (3) Activate and run the alarm under battery power for 5	
Verify operation of the generator Secondary (Standby) Power Supply (1) Disconnect ac power and verify trouble signal (2) Verify system's standby and alarm current demand and verify the batteries ability to meet the standby and alarm requirements (3) Activate and run the alarm under battery power for 5 minutes or 15 minutes if the	
Verify operation of the generator Secondary (Standby) Power Supply (1) Disconnect ac power and verify trouble signal (2) Verify system's standby and alarm current demand and verify the batteries ability to meet the standby and alarm requirements (3) Activate and run the alarm under battery power for 5 minutes or 15 minutes if the system has voice/evacuation	
Verify operation of the generator Secondary (Standby) Power Supply (1) Disconnect ac power and verify trouble signal (2) Verify system's standby and alarm current demand and verify the batteries ability to meet the standby and alarm requirements (3) Activate and run the alarm under battery power for 5 minutes or 15 minutes if the system has voice/evacuation requirement	
Verify operation of the generator Secondary (Standby) Power Supply (1) Disconnect ac power and verify trouble signal (2) Verify system's standby and alarm current demand and verify the batteries ability to meet the standby and alarm requirements (3) Activate and run the alarm under battery power for 5 minutes or 15 minutes if the system has voice/evacuation requirement Uninterruptible power supply UPS	
Verify operation of the generator Secondary (Standby) Power Supply (1) Disconnect ac power and verify trouble signal (2) Verify system's standby and alarm current demand and verify the batteries ability to meet the standby and alarm requirements (3) Activate and run the alarm under battery power for 5 minutes or 15 minutes if the system has voice/evacuation requirement Uninterruptible power supply UPS Verify by building owner that	
Verify operation of the generator Secondary (Standby) Power Supply (1) Disconnect ac power and verify trouble signal (2) Verify system's standby and alarm current demand and verify the batteries ability to meet the standby and alarm requirements (3) Activate and run the alarm under battery power for 5 minutes or 15 minutes if the system has voice/evacuation requirement Uninterruptible power supply UPS Verify by building owner that the power source complies with	
Verify operation of the generator Secondary (Standby) Power Supply (1) Disconnect ac power and verify trouble signal (2) Verify system's standby and alarm current demand and verify the batteries ability to meet the standby and alarm requirements (3) Activate and run the alarm under battery power for 5 minutes or 15 minutes if the system has voice/evacuation requirement Uninterruptible power supply UPS Verify by building owner that the power source complies with NFPA 111.	
Verify operation of the generator Secondary (Standby) Power Supply (1) Disconnect ac power and verify trouble signal (2) Verify system's standby and alarm current demand and verify the batteries ability to meet the standby and alarm requirements (3) Activate and run the alarm under battery power for 5 minutes or 15 minutes if the system has voice/evacuation requirement Uninterruptible power supply UPS Verify by building owner that the power source complies with	
Verify operation of the generator Secondary (Standby) Power Supply (1) Disconnect ac power and verify trouble signal (2) Verify system's standby and alarm current demand and verify the batteries ability to meet the standby and alarm requirements (3) Activate and run the alarm under battery power for 5 minutes or 15 minutes if the system has voice/evacuation requirement Uninterruptible power supply UPS Verify by building owner that the power source complies with NFPA 111.	

(1) Battery replacement verify that the recharge battery voltage or current is within manufacture's		
recommendations		
(2) Test operation of battery charger		
(3) Perform discharge test		
(4) Perform load voltage test		
(5) Perform specific gravity test		
(b) Nickel-cadmium type (1) Battery replacement verify that the recharge battery voltage or current is within manufacture's recommendations		
(2) Test operation of battery charger		
(3) Perform discharge test		
(4) Perform load voltage test		
(c) Sealed lead-acid type (1) Battery replacement verify that the recharge battery voltage or current is within manufacture's recommendations		
(2) Test operation of battery charger		
(3) Perform discharge test		
(4) Perform load voltage test		

Remote Annunciators	
Verify the correct operation and	
identification at the annunciators	
Conductors - Metallic	
(1) Test for stray voltage	
(2) Test for ground faults	
(=) = ==== g============================	
(2) Test for short singuit faults	
(3) Test for short-circuit faults	
(4) Test for Loop resistance	
(5) Test for a trouble signal with	
the introduction of a fault on	
any circuit monitored for	
integrity	
Conductors – Nonmetallic	
(1) Test all circuits for integrity	
(1) Test all elledits for integrity	
(2) Test fiber entire transmission	
(2) Test fiber optic transmission	
line	
(3) Test for a trouble signal with	
The introduction of a fault	
In any supervised circuit	
Initiating Devices	
(a) Electromechanical releasing	
device	
(1) Non-restorable-type link	
(2) Restorable-type link	
(b) Test fire extinguishing	
system(s) or suppression	
= =	
systems(s) alarm switch	
(c) Test fire-gas and other	
detectors	
(d) Test heat detectors	
(1) Fixed-temperature, rate-of-	
rise, rate of compensation,	
restorable line, spot type	
(excluding pneumatic tube	
type)	
-JP-/	
(2) Fixed temperature	
(2) Fixed-temperature,	
Non-restorable line type	

(j) Initiating devices, supervisory(1) Sprinkler control valve switch		
(2) High or low-air pressure switch		
(3) Room temperature switch		
(4) Water level switch		
(5) Water temperature switch		
(k) Mechanical electrosonic, or pressure-type waterflow device		
(l) Multi-sensor detector or multi-criteria detector or combination detector		
Test Special Hazard Equipment (a) Abort switch (dead-man type)		
(b) Abort switch (recycle type)		
(c) Abort switch (special type)		
(d) Cross zone detection circuit		
(e) Matrix-type circuit		
(f) Release solenoid circuit		
(g) Squibb release circuit		
(h) Verified, sequential, or counting zone circuit		

(i) Verify supervision of all		
Above circuit.		
Combination systems		
(a) Fire extinguisher electronic		
monitoring device/system		
(b) Carbon monoxide device/		
system.		
Guard's tour equipment		
Guard's tour equipment		
A 1 4:6: 4: 1:		
Alarm notification appliances		
(a) Audible		
(b) Audible textual notification		
appliances (speakers and		
other appliances to convey		
voice message)		
(c) Visible appliances		
Exit marking audible		
Notification appliance		
Emergency control functions		
Verify operation and receipt of		
signals		
Area of refuge two-way		
Communication system		
Special procedures		
(a) Alarm verification		
(a) Marin vernication		
(b) Multiplex systems		
Off-site Monitored Systems		
(a) Verify receipt of the correct		
initiating device signals at the		
monitoring facility within 90		
seconds of activation		
seconds of activation		
(b) If two separate phone lines		
are in use, test both lines		
are in use, test both lines		
(a) Tast line!		
(c) Test line seizure capability		

(d) Test digital alarm radio transmitter		
Test Emergency Communications Equipment (a) Amplifier/tone generators		
(b) Call-in signal silence		
(c) Phone jacks		
(d) Phone set		
(f) System performance (minimum of any 5 handsets simultaneously)		
Test Combination Systems (a) Fire extinguisher monitoring device/system		
Test Interface Equipment (Test supervision)		
Test Fire Safety Functions		
(a) Fan control		
(b) Smoke damper operation		
(c) Elevator recall		
(d) Elevator power shutdown		
(e) Door holder release		
(f) Door unlocking		

Test Special Procedures (a) Alarm verification		
(b) Multiplex systems (1) Verify communications between sending and receiving units under both primary and secondary power		
(2) Verify communications between sending and receiving units under open circuit and short circuit trouble conditions		
(3) Verify communications between sending and receiving units in all directions where multiple pathways are provided		
(4) If redundant central control equipment is provided, switchover and all required functions and operations and features shall be verified		
Test Low-Power Radio Systems (Wireless Systems)		
Mass notification systems (a) Functions		
(b) Fuses		
(c) Interfaced equipment		
(d) Lamps and LEDs		
(e) Primary (main) power supply		
(f) Audible textual notification appliances		
(g) Visible		

(h) Control unit functions and no diagnostic failures are indicated.		
(i) Control unit reset		
(j) Control unit security		
(k) Audible/visible functional test		
(l) Software backup		
(m) Secondary power test		
(n) Wireless signals		
(o) Antenna		
(p) Transceivers		
Notify Monitoring Company that testing has been completed		
Notify Building Occupants that testing has been completed		