

**DELTA FIRE SYSTEMS, INC.**

1507 SOUTH PIONEER RD
PO BOX 26587
SALT LAKE CITY, UT 84126-0587
PHONE: 801-972-4500
EMAIL: slc.frontdesk@deltafire.us

Proposal: FQ1905300970**PROPOSAL****Job Name:** Rasmussen Residence**Invoice To:** Rasmussen, Joanne**Site Address:** 13536 N NOAH CT
KAMAS, UT 84036-128313536 N NOAH CT
KAMAS, UT 84036-1283**Contact:** Joanne Rasmussen
801-819-4007
rasmussen.joanne24@gmail.com

☐ Request For Proposal (RFP) ☐ Service Follow Up Proposal ☒ Inspection Follow Up Proposal

Open Date: 05/30/2019**Expiry Date:** 07/29/2019**Sales Rep:** Jaynes, Skyler A**Email:** skyler.jaynes@deltafiresystems.us**Work Description:** Delta Fire Systems, Inc. has recently completed the 2019 annual inspection of the building fire system and a few deficiencies have been noted.

1. Antifreeze needs to be replaced with factory pre mixed glycerine.
2. No head box, heads, or head wrench.

Cost.....\$895

NOTE:

- a) The rental of a hi-lift is not included & will be added if one is used.
- b) Any possible electrical work will need to be done by others
- c) Any possible painting or patching of sheetrock or ceiling tiles would need to be done by others.
- d) Price provided is an estimate only.

PROPOSED TOTAL**\$895.00**



DELTA FIRE SYSTEMS, INC.

1507 SOUTH PIONEER RD
PO BOX 26587
SALT LAKE CITY, UT 84126-0587
PHONE: 801-972-4500
EMAIL: slc.frontdesk@deltafire.us

Proposal: FQ1905300970

Authorized Signature _____

Date: _____

Print Name: _____

PO#: _____