

Re: Engelhard plans for fire suppression system

Bruce e <engelhard.bruce@gmail.com>

Wed 9/11/2019 10:16 AM

To: Arun Mr <arunfss@live.com>

Arun,

Good talking to you this morning. Sprinklers required only in living space: second floor of structure above garage which includes Rec Room, Bath and Suite (bedroom). No sprinklers needed in breezeway or attic as per conversations with Stuart Grey and Daniel Egbert. Looking forward to hearing back from you with your estimate.

Bruce

On Sep 11, 2019, at 9:43 AM, Arun Mr <arunfss@live.com> wrote:

Thank you.
Do you have a Scope of Work. or Specs?
Color etc.

Cheers

Arun (Mr.)

Projects & Compliance

Fire Suppression Services Incorporated

3802 S. 2300 E.

Millcreek UT 84109

(801) 440-9906 Cell, (no Text)

(801) 277-6464 Main Office

When removing a panel or device from the system, record the proper jumper and address settings to insure the replacement is setup correctly.

UT Code 105 If you Add-Change-Delete or Move a Device, Head, Pipe or Wall- A City Permit is REQUIRED

There may be times when we are powerless to prevent injustice, but there must never be a time when we fail to protest

From: Bruce e <engelhard.bruce@gmail.com>

Sent: Wednesday, September 11, 2019 9:32 AM

To: arunfss@live.com <arunfss@live.com>

Subject: Engelhard plans for fire suppression system