



Fire Suppression Services, Inc.

3802 South 2300 East
Salt Lake City, Utah 84109-3421
Contractor License No. 92-252208-5501
801.277.6464 • 800.273.6465 • 801.278.2199 - FAX

26371

DATE 9/8/2018

B
I
L
L
I
N
G

Capitol Reef Resort
PO Box 750160
2600 East Highway 24
Torrey, UT 84775

J
O
B
S
I
T
E

Capitol Reef Resort
2600 East Highway 24
Torrey, UT 84775

Billing		Job Site		SALESMAN :		TANK		CARTRIDGE	
PHONE		435-425-3761		Heath Dangerfield		DATE		TYPE	
FAX		435-425-3300		EE # 61931				DATE	
CONTACT		Duane		E-MAIL :		MONTHLY			
DIRECT #				Duane@Capitolreefresort.com					
☒ WET SYSTEM		☐ DRY CHEM SYS		☐ ALARMS		☐ INSTALLATION		Mileage One-Way	
☐ WATER SPRINKLER		☐ EMER LIGHTING		☐ CLEAN AGENT		☐ TIME & MATERIALS		Drive Time One-Way 0 H 00 Min	
☐ EXTINGUISHERS		☐ STEAM CLEAN		☐ EMERGENCY		☒ REPAIR		UNIT PRICE NON TAX TAXABLE	
Saturday, September 08, 2018						\$ -		\$ -	
SCOPE OF WORK - REPAIRED LEAK ON FIRE WATER						\$ -		\$ -	
RISER DUE TO SPIKE OF CITY WATER - INSTALLED						\$ -		\$ -	
ADDITIONAL BRACING TO PREVENT INCIDENT FROM						\$ -		\$ -	
HAPPENING AGAIN						\$ -		\$ -	
1 EMERGENCY STOP DROP AND GO (NO CHARGE)						\$ -		\$ -	
PARTS						\$ -		\$ -	
1 10' 6" STICK 2 1/2" INCH PIPE						\$ 95.11		\$ 95.11	
3 2 1/2" INCH VICTAULIC COUPLING						\$ 20.40		\$ 61.20	
3 FEET 1 1/2" INCH PIPE						\$ 7.26		\$ 21.78	
1 4" INCH RISER CLAMP						\$ 14.85		\$ 14.85	
1 2 1/2" INCH RISER CLAMP						\$ 12.42		\$ 12.42	
1 2" INCH VICTAULIC COUPLING						\$ 19.80		\$ 19.80	
1 PUMP RENTAL						\$ 35.00		\$ 35.00	
DAY 1 LABOR 9 / 7 / 2018						\$ -		\$ -	
2 HEATH (3 HOURS DRIVE TIME NO CHARGE) 2 HOURS INSPECTION						\$ 85.00		\$ 170.00	
2 WATER TECH NIGHT RATE- RANDY (GATHERING PARTS)						\$ 127.50		\$ 255.00	
1.5 WATER TECH - BARD (GO TO FIRE SUPPLY HOUSE BEFORE CLOSING)						\$ 85.00		\$ 127.50	
DAY 2 LABOR 9 / 8 / 2018 WEEKEND RATE APPLIES						\$ -		\$ -	
6 HEATH (3 HOURS DRIVE TIME NO CHARGE) 6 HOURS MAKING REPAIRS						\$ 127.50		\$ 765.00	
14 WATER TECH - RANDY (MAKING REPAIRS)						\$ 127.50		\$ 1,785.00	
						\$ -		\$ -	
						\$ -		\$ -	
						\$ -		\$ -	
						\$ -		\$ -	
info@Capitolreefresort.com Jessica@Capitolreefresort.com						\$ -		\$ -	
1 TRANSPORTATION - 426 MILES X 0.75 = 319.50						\$ 319.50		\$ -	
HAZARDOUS MATERIAL DISPOSAL CHARGE								\$ -	
DUE WHEN LAST COMPANY NUMBER ON PROPERTY				8% MISCELLANEOUS MATERIALS, INSURANCE, ETC.		\$ 269.01		\$ -	
EXTINGUISHER				CODE		SUBTOTAL		\$ 3,631.67	
EM / EX LIGHTING						TRANSPORTATION		\$ 319.50	
						Non-Taxable Total		\$ 3,631.67	
HOOD CLEANING				REFILE		Taxable Sales		\$ -	
				NONE		SALES TAX		\$ -	
RISER						Freight		\$ -	
						Handling		\$ -	
I, RECEIPT OF COPY: CUSTOMER ACKNOWLEDGES RECEIPT OF COPY AND THAT HE UNDERSTANDS ALL OF THIS AGREEMENT AND PARTICULARLY PARAGRAPHS 1, 2, 3, 4 AND 5 ON THE REVERSE WHICH SETS FORTH COMPANY'S MAXIMUM LIABILITY. THE SYSTEMS HAVE BEEN SERVICED IN ACCORDANCE WITH NATIONAL FIRE PROTECTION STANDARDS AND CODES OR CURRENT MFG. SERVICE REQUIREMENTS AND DOES NOT CERTIFY THE DESIGN AND / OR THE INSTALLATION CRITERIA. CLAIMS WILL NOT BE HONORED AFTER TEN (10) DAYS FROM DATE OF SERVICE.									
Net 15 Days		RECEIVED IN GOOD ORDER AND ACCEPTED				TOTAL		\$ 3,951.17	
		WORK AUTHORIZATION NUMBER # 29266							
		PURCHASE / WORK ORDER NUMBER							
☐ Cash		BY X							
☐ Check		BUYER SHALL PAY SELLER FOR THIS PURCHASE							
☐ Credit									

INTEREST WILL BE CHARGED ON OVERDUE ACCOUNTS.

3% PER MONTH

MINIMUM BILLING OF \$35.00

"THIS INVOICE IS ALSO YOUR STATEMENT"

THANK YOU



Fire Suppression Services, Inc.

3802 South 2300 East
Salt Lake City, Utah 84109-3421
(801) 277-6464 Fax (801) 278-2199
(800) 273-6465

WORK AUTHORIZATION

JOB NO: 29266

DATE: 9-8-18

SALESMAN: Randy

CUST. P.O.: _____

INVOICE: _____

JOB Capital Reef Resort

2600 UT-24

Torrey UT 84775

Duane@ReefResort.com

DESCRIPTION OF WORK Emergency sprinkler leak on main riser

PERSON TO CONTACT AT JOB SITE Dwayne

T & M ☒ CONTRACT ☐ AMOUNT \$

Day 1 9-8-18

Heath 2

Randy 2 OT

Burd 1.5

INSPECTED LEAK CALLED IN PARTS

GATHERED UP PARTS NEED AT YARD/FROM BURD

WENT TO PART STORE BEFORE CLOSING

10' 2 1/2" PIPE

3 2 1/2" VIC COUPLING

3' 1 1/2" PIPE

1 4" RISER CLAMP

1 2" VIC COUPLING

1 2 1/2" RISER CLAMP

9-8-18

Heath 12 OT

Randy 14 OT

FOUND CITY WATER HAD PRESSURE

SPIKE WHICH HAMMERED THE SYSTEM

BLOWING OUT PIPE WORK AND VIC COUPLINGS

CITY WATER

Drove to site cut out pipe THAT WAS DAMAGED FROM PRESSURE SPIKE. BUILT NEW PIECE, add extra SUPPORT to main riser WITH WENT TO HELP PREVENT additional damage FROM FUTURE PRESSURE SPIKES. REFILLED SYSTEM cleaned up WENT BACK TO SHOP

SUBSISTENCE AND MILEAGE 4 transport, 2 wet Tech, 1 pump

SUBCONTRACTS AND MISC. _____

REMARKS: ANTI-FREEZE IN SYSTEM IS OUT OF SPEC NEEDS TO BE RECTIFIED

BEFORE WINTER

WORK AUTHORIZED BY X [Signature]

NAME (PRINTED) Duane P. Dasse Jr

TITLE General Manager

SUBJECT TO TERMS AND CONDITIONS ON REVERSE SIDE