



POWER SUPPLY FOR CHANNEL MT TAPE LIGHT. PLACE IN DISCREET LOCATION OUT OF DIRECT VIEW. PROVIDE TAPE LIGHT FOR (3) LEVELS OF SHELVING. COORDINATE WITH ARCHITECT.

CIRCUIT EXHAUST FAN TO LIGHTING CIRCUIT.

JUNCTION BOX AND POWER PROVIDED FOR FUTURE EXTERIOR LIGHTING. MOUNT AS PER ARCHITECT.

- A. COORDINATE WITH ARCHITECT FOR MOUNTING HEIGHT OF ALL SUSPENDED LIGHT FIXTURES.
- B. CONNECT ALL EMERGENCY AND EXIT LIGHT FIXTURES TO THE UNSWITCHED SIDE OF THE LIGHTING BRANCH CIRCUIT. LIGHT FIXTURES WITH EMERGENCY DRIVERS SHALL BE NORMALLY SWITCHED WITH THE AREA LIGHTING, BUT HAVE THEIR EMERGENCY DRIVERS CONNECTED AHEAD OF THE LIGHT SWITCH OR LIGHTING CONTROL PANEL RAYLE.
- C. IT IS THE INTENT OF THE CONSTRUCTION DOCUMENTS THAT CONDUIT IS TO BE INSTALLED WITHIN WALLS AND ABOVE CEILINGS CONCEALED WHERE POSSIBLE.
- D. COORDINATE MOUNTING HEIGHTS OF ALL PENDANT AND WALL MOUNTED LIGHT FIXTURES WITH ARCHITECTURAL ELEVATIONS.

LIGHTING AND CONTROLS ARE DESIGNED TO MEET IECC 2015

LIGHTING CONTROL PANEL WILL BE PROGRAMMED TO TURN LIGHTS ON AND OFF FOR HOURS OF OPERATION.

OVERRIDE SWITCHES ARE PROVIDED IF SOMEONE IS IN THE BUILDING BEFORE OR AFTER HOURS.

OCCUPANCY SENSORS WILL CONTROL LIGHTING IN RESTROOM, OFFICE, AND MILL ROOM.

LOW VOLTAGE SWITCHES WILL ACT AS OVERRIDES TO TIME SCHEDULING.

EXTERIOR LIGHTS WILL COME ON WITH PHOTOCELL AND BE PROGRAMMED OFF.

MAIN LEVEL LIGHTING EXEMPT FROM DAYLIGHTING REQUIREMENTS PER IECC 2015 C405.2.3 - 2.4. (AREA 'A-Z' OCCUPANCY)

DAYLIGHT AREAS EXEMPT FROM DAYLIGHTING REQUIREMENTS PER IECC 2015 405.2.3 (1) (LESS THAN 150 W)

445 SOUTH 400 WEST
SALT LAKE CITY, UT 84101



ROCKY MOUNTAIN
CONSULTING ENGINEERS, INC.
2117 South 3600 West, Salt Lake City, UT 84119
(801) 566-0503 www.rmceut.com

PROJECT #:	18185
DRAWN BY:	DWS SL
CHECKED BY:	DWS
DATE:	04/04/2019

E101

5

5

LIGHTING PLAN

SCALE: 1/8" = 1'-0"