



BEWILDER BREWERY

445 SOUTH 400 WEST
SALT LAKE CITY, UT 84101


#

KEYED NOTES

1. NEW 400A, 120/208V, 3Ø, NEMA 3R CT ENCLOSURE.
2. 400A, 120/208V, 3Ø, NEMA 3R MAIN SERVICE DISCONNECT.
3. ELECTRIC METER AS PER RMP NEW SERVICE REQUIREMENTS.
4. NEW RMP PAD MOUNTED TRANSFORMER. PROVIDE PAD/Vault AS REQUIRED.
5. PROVIDE CORD DROP FROM CEILING DOWN TO 5' AFF. TO FEED EQUIPMENT. UTILIZED WIRE MESH STRAIN RELIEF FITTINGS TO PROTECT WIRE FROM PULLING OUT OF BOX.
6. EC TO COORDINATE EXACT REQUIREMENTS CONNECTIONS, AND LOCATION FOR PORTABLE PUMP WITH OWNER PRIOR TO CONSTRUCTION.
7. EC TO RE-FEED EXISTING PANELS FROM NEW SERVICE EQUIPMENT. SEE ONE-LINE DIAGRAM FOR MORE INFORMATION.

GENERAL NOTES

- A. REFER TO ELECTRIC SITE PLAN FOR MORE INFORMATION ON NEW ELECTRICAL SERVICE REQUIREMENTS AND COORDINATE WITH RMP.
- B. EC TO PROVIDE EXACT LOCATIONS AND ELECTRICAL REQUIREMENTS AND CONNECTIONS WITH ALL BREWERY EQUIPMENT PRIOR TO CONSTRUCTION.



REVISIONS

ROCKY MOUNTAIN
CONSULTING ENGINEERS, INC.
2117 South 3600 West Salt Lake City, UT 84119
(801) 566-0503 www.rmceut.com

PROJECT #: 18185
DRAWN BY: DWS
CHECKED BY: DWS
DATE: 04/04/2019
(C) ROCKY MOUNTAIN CONSULTING ENGINEERS, INC. - 2019

SHEET TITLE:

POWER PLAN

E201

1
E201

POWER PLAN

SCALE: 1/8" = 1'-0"

