

BEAM SCHEDULE		
DESIGNATION	SIZE	
SB1	(2) 2x10 DF-L #2	
SB2	-	
SB3	-	
SB4	-	
SB5	-	
SB6	-	
SB7	-	
SB8	-	
SB9	-	
SB10	-	
SB11	-	
SB12	-	

	EN	SED GIN 291 E. 950 1.426.6500	JEE s. orem	,UTAH )redwo

POST SCHEDULE		
DESIGNATION	SIZE	
P1	ONE TRIMMER/STUD	
P2	TWO TRIMMERS/STUDS	
P3	THREE TRIMMERS/STUDS	
P4	FOUR TRIMMERS/STUDS	
P5	4x4 DF-L #2 POST	
P6	6x6 DF-L #2 POST	
P7	3 ½"x5 ¼" PARALLAM	
P8	5 ¼"x5 ¼" PARALLAM	
P9	8x8 DF-L #2 POST	
P10	10x10 DF-L #2 POST	

NOTES:

1. SEE GENERAL STRUCTURAL NOTES SHEET (SN.1)
FOR TYPICAL BEARING POST REQUIREMENTS.

2. POSTS INDICATE NUMBER OF TRIMMERS WHEN
SPECIFIED AS HEADERS. ALL OTHER POST
DESIGNATIONS REFER TO FULL HEIGHT KING STUDS.

3. INSTALL (2) TRIMMERS (MIN.) EACH SIDE OF HEADER
GREATER THAN 6'-0" IN LENGTH (U.N.O.)

4. INSTALL (2) KING STUDS (MIN.) EACH SIDE OF HEADER
ON OPENINGS GREATER THAN 8'-0" (U.N.O.)

5. INSTALL (2) KING STUDS (MIN.) AT ALL HOLDOWN
LOCATIONS OR AS NOTED ON HOLDOWN SCHEDULE.
(U.N.O.)

BEAM HANGER SCHEDULE				
DESIGNATION	DESCRIPTION	NOTES		
SH1	IUS	-		
SH2	-	-		
SH3	-	-		

FLOOR SHEATHING SCHEDULE		
MATERIAI	8d NAILS SPACING	
WATERIAL	EDGE	FIELD
3" T&G STRUCTURAL II PLYWOOD OR OSB	6"	12"

WALL FRAMING SCHEDULE ALL EXTERIOR BEARING WALLS TO BE 2x6 DF-L STUDS @ 24"

TOP PLATE SPLICE SCHEDULE USE (XX) 16d NAILS ON TOP PLATE SPLICES - SEE DETAIL 3 / S.2

	HOLDOWN AND STRAP SCHEDULE			
	DESIGNATION	HOLDOWN OR STRAP	MIN. STUDS	DETA
TYP.	(AA)	STHD8 / 8RJ	2	6/S
	BB	STHD8 / 8RJ	2	6/S
\1/ \(\hat{A}\)	<u></u>	STHD8 / 8RJ	2	6/S
	<u> </u>	STHD8 / 8RJ	2	6/S
₹ <	€E	STHD8 / 8RJ	2	6/S
	NOTE:			

HOLDOWNS ARE DIMENSIONED TO FINISHED EDGE OF WINDOWS AND DOORS. ADJUST HOLDOWN PLACEMENT AS REQUIRED SO THAT HOLDOWN IS LOCATED ON KING STUDS, AS PER ENGINEERING SPECS. HOLDOWN DIMENSIONS ARE APPROXIMATIONS - CONTRACTOR TO VERIFY.

	SHEAR WALL SCHEDULE:				
		8d NAILS	SPACING	1½" 16 GA.	STAPLE
MARK	MATERIAL	EDGE	FIELD	EDGE	FIELD
Λ	7/16" STRUCT. II PLYWOOD OR OSB	6"	6" (12")	4"	6"
2	7/16" STRUCT. II PLYWOOD OR OSB	4"	6" (12")	2 <u>1</u> "	6"
<u>3</u>	7/16" STRUCT. II PLYWOOD OR OSB	3"	6" (12")	N/A	N/A
4	7/16" STRUCT. II PLYWOOD OR OSB	2"	6" (12")	N/A	N/A
NOTES: 1. FIELD NAILING IS TO BE 12" O.C. WHEN STUD SPACING IS 16" O.C. OR LESS.					

- 2. ALL SHEAR WALLS ARE BLOCKED AT ALL FREE EDGES WITH STUD FRAMING @
- 24" O.C. (U.N.O.)

  3. ALL ANCHOR BOLTS SHALL BE PER ASTM A307 AND HAVE 7" MIN. EMBEDMENT.

  4. WHERE SHEAR WALL PANELS ARE APPLIED TO BOTH FACES OF A WALL, PANEL JOINTS SHALL BE OFFSET TO FALL ON DIFFERENT FRAMING MEMBERS.

  5. FOR SHEAR WALLS "A" AND "A", ABUTTING PANEL EDGES ARE TO HAVE (2) 2X\_STUDS STITCHED TOGETHER W/ 16D SINKERS @ 6" O.C.

ECT NO:	XX	
DATE:		
SCALE:		
N BY:	XX	
KED BY:	XX	
STAMP		
	N BY: KED BY:	

REVISION