

NOT USED

SCALE

-

9

NOTE: GC TO REFER TO A7-0 FLOOR PLAN FOR NUMBER OF STANDARDS

NOTE TO GC: DO NOT PAINT SURFACE MOUNTED RECESSED STANDARDS

#10 X 1/2" SCREWS THROUGH EACH STUD AND STANDARD, CENTERED ON STUD AND 6"-8" O.C. TYP.

GYP. BD. PAINT AS SPECIFIED

16" O.C.

Ø OF STANDARD & METAL STUD

Ø OF STANDARD & METAL STUD

Ø RT-1 TYP.

SURFACE MOUNTED STANDARD

SCALE

1-1/2" = 1'-0"

8

FLOOR TAPE / SYMBOL SURFACE PREPARATION AND APPLICATION INSTRUCTIONS

SURFACE MUST BE COMPLETELY DRY.

SURFACE MUST BE CLEAN AND FREE OF ANY CONTAMINANTS WHICH MAY INCLUDE BUT NOT LIMITED TO OILS, GREASE, SAND, DIRT, DUST, LOOSE AGGREGATE, CURING COMPOUND, MUD, SOIL AND SALT, ADHESIVES, ETC...

DO NOT APPLY PRODUCT DIRECTLY ON SEAMS, JOINTS, DETERIORATING MARKING OR SUBSTRATES.

TAPES APPLIED DIRECTLY OVER SEAMS AND JOINTS MUST BE CUT THOUGH 1" ON BOTH SIDES OF THE JOINTS OR SEAMS TO PREVENT DE-BONDING OF THE TAPE.

DO NOT OVERLAP TAPE, USE BUTT SPLICES

FIRMLY TAMP THE PRODUCT IN THE SAME DIRECTION AS IT WAS APPLIED ON THE INITIAL PASS. A MINIMUM OF THREE PASSES TOTAL. USE A TAMPER DEVICE WITH A MINIMUM 150 LB. (90KG) LOAD AND A TAMPING SURFACE A MINIMUM 2" WIDER THAN THE WIDTH OF TAPE BEING APPLIED. NEVER TWIST THE TAMPERING DEVICE DURING TAMPING. REPEAT TAMPING AS NECESSARY TO INSURE TAPE HAS COMPLETELY CONFIRMED TO THE SURFACE.

ALL USERS SHOULD TEST A SMALL PIECE OF PRODUCT FOR SATISFACTORY ADHESION PRIOR TO INSTALLING LARGE PORTIONS.

*IF REMOVAL IS REQUIRED, PLACE A SMALL SCRAPER BLADE UNDERNEATH TAPE AND PULL IN AN UPWARD DIRECTION AT A 180° ANGLE. IF TAPE HAS NOT BEEN DAMAGED, MATERIAL WILL BE REMOVABLE IN TACT OR IN LARGE PIECES.

*FOR BEST ADHESION AND CONFORMABILITY, PLEASE DO NOT EXPOSE TAPE TO COLD TEMPERATURES UNTIL THE MOMENT OF INSTALLATION.

CLEAN

MARK

APPLY

TAMP

STRIPING DETAILS

SCALE

1/2" = 1'-0"

6

A

CONTINUOUS STRIPING

RT-1

1'-5"

36" MIN. FROM FACE OF EQUIPMENT

30" MIN.

4"

4"

KEEP AREA CLEAR

RT-3

ELECTRICAL EQUIPMENT CLEAR AREA

B

RT-2

2'-0" TYP.

1'-0" TYP.

KEEP AREA CLEAR

RT-3

2"

36"

2"

36" WIDE EMPLOYEE PATHWAY

C

RT-2

DIAGONAL LINES TO BE CONTINUOUS

2'-0" TYP.

1'-0" TYP.

KEEP AREA CLEAR

RT-3

2"

44"

2"

44" WIDE CUSTOMER PATHWAY

GENERAL NOTES:

1. TEXT STATING "KEEP AREA CLEAR" TO BE PLACED IN FRONT OF DOORWAYS AND PANELS. FOR PATHWAYS, PLACE TEXT EVERY 10'-0" U.O.N. CENTERED ON PATH TO MATCH COLOR PER FINISH SCHEDULE. ORIENTATION TO MATCH DIRECTION OF TRAVEL. FONT SIZING TO MATCH BORDER WIDTH. TEXT AVAILABLE IN VINYL ADHESIVE PRODUCT FROM SUPERIOR MARK.

2. ALL ELECTRICAL STRIPING TO BE CONTINUOUS. BOTH EMPLOYEE AND CUSTOMER PATHWAYS TO BE APPLIED IN 24" SOLID STRIPS WITH A 12" SPACING IN BETWEEN. REFER TO STRIPING DETAILS A, B, & C. WHEN OVERALL PATHWAY IS < THAN 5'-0" IN LENGTH, THE PATHWAY SHOULD BE CONTINUOUS.

3. SEE DETAIL 7/- FOR SURFACE PREPARATION AND INSTALLATION GUIDELINES.

GENERAL NOTES APPLICABLE TO THIS DETAIL:

A. THIS DETAIL APPLIES ONLY TO DRY-TYPE TRANSFORMERS RATED 112.5 kVA OR LESS.

B. FIELD VERIFY LOCATION OF EXISTING STRUCTURAL BEAMS ON SITE. NOTIFY ARCHITECT OF ANY DISCREPANCIES PRIOR TO PROCEEDING.

C. PROVIDE MIN. CODE REQUIRED CLEARANCES AROUND ALL SIDES WITH A MINIMUM OF 10'-0" CLEAR A.F.F. TO B.O. MOUNTING STRUCTURE.

C. PROVIDE SEISMIC BRACING AS REQUIRED BY CODE.

DRY-TYPE TRANSFORMER

VIBRATION ISOLATOR

4" STRUC. CHANNEL

1/2" DIAM. A36 THREADED ROD TO PARALLEL STRUC. CHANNEL

1/2" LOCKNUT

2" O.D. X 1/4" FENDER WASHER

DOUBLE 1/2" HEX NUT

1/2" DIAM. THREADED ROD TO UNISTRUT HANGER ABOVE

2" O.D. X 1/4" FENDER WASHER

DOUBLE 1/2" HEX NUT

(E) BEAM, PATCH AND REPAIR FIREPROOFING AS NEEDED. TYP.

P1000 W/ (2) P2785 BEAM CLAMP. TYP. BOTH SIDES

DRY-TYPE TRANSFORMER. SEE ELECTRICAL

1/2" DIAM. A36 THREADED ROD. TYP. OF (4)

SECONDARY FEEDERS IN FLEXIBLE METALLIC CONDUIT TO PANEL BOARD BELOW

MASON INDUSTRIES ND SERIES NEOPRENE VIBRATION ISOLATOR. TYP. OF (4)

PROVIDE SEISMIC BRACING BACK TO WALL AS REQ'D BY LOCAL CODES

4" STRUC. CHANNEL (4C5.4#) TYP. OF (2)

1/2" DIAM. A36 THREADED ROD TO TIE STRUC. CHANNELS TOGETHER. TYP. OF (2)

APPLIES TO FOUR LOCATIONS

TRANSFORMER SUPPORT DETAIL

SCALE

N.T.S.

5

DRY-TYPE TRANSFORMER

VIBRATION ISOLATOR

4" STRUC. CHANNEL

1/2" DIAM. A36 THREADED ROD TO PARALLEL STRUC. CHANNEL

1/2" LOCKNUT

2" O.D. X 1/4" FENDER WASHER

DOUBLE 1/2" HEX NUT

1/2" DIAM. THREADED ROD TO UNISTRUT HANGER ABOVE

2" O.D. X 1/4" FENDER WASHER

DOUBLE 1/2" HEX NUT

(E) BEAM, PATCH AND REPAIR FIREPROOFING AS NEEDED. TYP.

P1000 W/ (2) P2785 BEAM CLAMP. TYP. BOTH SIDES

DRY-TYPE TRANSFORMER. SEE ELECTRICAL

1/2" DIAM. A36 THREADED ROD. TYP. OF (4)

SECONDARY FEEDERS IN FLEXIBLE METALLIC CONDUIT TO PANEL BOARD BELOW

MASON INDUSTRIES ND SERIES NEOPRENE VIBRATION ISOLATOR. TYP. OF (4)

PROVIDE SEISMIC BRACING BACK TO WALL AS REQ'D BY LOCAL CODES

4" STRUC. CHANNEL (4C5.4#) TYP. OF (2)

1/2" DIAM. A36 THREADED ROD TO TIE STRUC. CHANNELS TOGETHER. TYP. OF (2)

APPLIES TO FOUR LOCATIONS

TRANSFORMER SUPPORT DETAIL

SCALE

N.T.S.

5

DRY-TYPE TRANSFORMER

VIBRATION ISOLATOR

4" STRUC. CHANNEL

1/2" DIAM. A36 THREADED ROD TO PARALLEL STRUC. CHANNEL

1/2" LOCKNUT

2" O.D. X 1/4" FENDER WASHER

DOUBLE 1/2" HEX NUT

1/2" DIAM. THREADED ROD TO UNISTRUT HANGER ABOVE

2" O.D. X 1/4" FENDER WASHER

DOUBLE 1/2" HEX NUT

(E) BEAM, PATCH AND REPAIR FIREPROOFING AS NEEDED. TYP.

P1000 W/ (2) P2785 BEAM CLAMP. TYP. BOTH SIDES

DRY-TYPE TRANSFORMER. SEE ELECTRICAL

1/2" DIAM. A36 THREADED ROD. TYP. OF (4)

SECONDARY FEEDERS IN FLEXIBLE METALLIC CONDUIT TO PANEL BOARD BELOW

MASON INDUSTRIES ND SERIES NEOPRENE VIBRATION ISOLATOR. TYP. OF (4)

PROVIDE SEISMIC BRACING BACK TO WALL AS REQ'D BY LOCAL CODES

4" STRUC. CHANNEL (4C5.4#) TYP. OF (2)

1/2" DIAM. A36 THREADED ROD TO TIE STRUC. CHANNELS TOGETHER. TYP. OF (2)

APPLIES TO FOUR LOCATIONS

TRANSFORMER SUPPORT DETAIL

SCALE

N.T.S.

5

CUBBY STORAGE

SCALE

N.T.S.

3

4'-0" MAX

3'-0"

10" CLR. MAX

7'-9 1/2" A.F.F. B.O. GYP. BD. CEILING

0'-0" A.F.F. FINISH FLOOR

1/2" GYP. BD. OVER 3 20GA. MTL. STUD FRAMING ABOVE PLATFORM, TO UNDERSIDE OF STRUCTURE

1/2" PLYWOOD DIVIDERS, 10" MAX. WIDE X 3'-0"H X 4'-0"D

MANAGER'S OFFICE FRAMING; SEE 1/-

HOLD-DOWN DETAIL

SCALE

3" = 1'-0"

2

(1) 1/2" DIAM. EXPANSION ANCHOR. BOLT TO SLAB ON GRADE. 2 1/2" MIN. EMBEDMENT. TYP.

DOUBLE STUD AT TIE DOWN

SIMPSON S/LTT20 W/ (6) #10 SCREWS

(E) SLAB

HOLD-DOWN ASSEMBLY AND BACKING - SEE B/-

NOTE: SEISMIC ZONES 3 & 4 ONLY.

FRAMING PLAN

SCALE

1/2" = 1'-0"

1

2

4

3

6" X 20 GA. 'C' STUD JOISTS AT 16" O.C. MAX.

5'-2 1/2"

6'-9"

NEW STORE

ATHLETA

GAP INC.
STORE DEVELOPMENT
2 FOLSOM STREET
SAN FRANCISCO, CA 94105

ORACLE I.D.:
140261

STORE NUMBER:
7341

STORE LOCATION:
STATION PARK
230 NE PROMONTORY
SPACE C-120
FARMINGTON, UT 84025

DESIGN TYPE:
DERBY B

GENERATION:
21Q34

PROTOTYPE DATE:
1/8/2021

OPENING:
2021

ARCHITECT INFO:

brr

ARCHITECT OF RECORD:
MARTIAH MEYER
8131 METCALF AVE
SUITE 300
OVERLAND PARK, KS 66204
www.brrarch.com
TEL: 913-262-9095
FAX: 913-262-9044

CONSULTANT INFO:

PROFESSIONAL STAMP:

ISSUE TYPE:

LL/PERMIT/BID: 02/19/21

REVISIONS:

DRAWN BY: KDA

A/E JOB NUMBER: 65011072

TITLE SHEET:

MANAGER CUBBY STORAGE AND MISC. DETAILS

SHEET NUMBER:

A7-2