



FIRE SPRINKLER PLAN

1/8" = 1'-0"
100

SPRINKLER GENERAL NOTES

1. THE ABBREVIATION GC, WHEREVER IT APPEARS IN THESE MECHANICAL AND ELECTRICAL DRAWINGS, SHALL REFER TO THE GENERAL CONTRACTOR.
2. THE CONTRACTOR FOR THIS DIVISION OF WORK IS REQUIRED TO READ THE SPECIFICATIONS AND REVIEW DRAWINGS FOR ALL DIVISIONS OF WORK AND IS RESPONSIBLE FOR THE COORDINATION OF THIS WORK AND THE WORK OF ALL SUBCONTRACTORS WITH ALL DIVISIONS OF WORK. IT IS THIS CONTRACTOR'S RESPONSIBILITY TO PROVIDE ALL SUBCONTRACTORS WITH A COMPLETE SET OF BID DOCUMENTS.
3. FIRE PROTECTION PLANS, SPRINKLER DRAWINGS, MUST BE ENGINEERED AND WET SIGNED BY A LANDLORD APPROVED, LICENSED REGISTERED FIRE PROTECTION CONTRACTOR IN THE LOCAL JURISDICTION. FINAL INSTALLATION MUST COMPLY WITH NFPA 13 AND STATE AND LOCAL AUTHORITIES HAVING JURISDICTION.
4. SPRINKLER HEAD LAYOUT IS A SUGGESTED LAYOUT. COORDINATE SPRINKLER HEAD LAYOUT AND PIPE ROUTING WITH ARCHITECTURAL PLANS, STRUCTURAL PLANS, HVAC CONTRACTOR, ELECTRICAL CONTRACTOR AND THE G.C. THIS CONTRACTOR SHALL INCLUDE IN THE BID AND BE RESPONSIBLE FOR EXACT QUANTITY OF SPRINKLER HEADS REQUIRED FOR COVERAGE AND FINAL APPROVAL.
5. LOCATE SPRINKLER MAIN AND RELATED SHUT OFF VALVES IN AN ACCESSIBLE LOCATION WITHIN THE STOCKROOM.
6. DESIGN DENSITY FOR FITTING ROOMS, RESTROOMS, AND OFFICES SHALL BE LIGHT HAZARD, 0.10/1500 SF.
7. DESIGN DENSITY FOR SALES AREAS AND STOCK AREAS SHALL BE ORDINARY HAZARD GROUP 2, 0.20/1500 SF.

SPRINKLER CODED NOTES

- 200 INSTALL SPRINKLER HEADS ABOVE AND BELOW DUCTWORK AS REQUIRED BY NFPA 13. COORDINATE INSTALLATION OF HEADS WITH HVAC CONTRACTOR AND G.C.
- 201 DO NOT ROUTE PIPE ABOVE ELECTRICAL EQUIPMENT AND PANEL.

SPRINKLER HEAD LEGEND

SYMBOL	DESCRIPTION	REMARKS
⊗	BRONZE UPRIGHT HEAD	
⊗	BRONZE UPRIGHT HEAD - EXISTING	
●	CONCEALED HEAD	
○	NON-FREEZE SPRINKLER HEAD IN CAVITY	
⊙	RECESSED HEAD	

NOTE TO CONTRACTOR:
SEE "GENERAL SHEETS" IN THIS SET FOR RESPONSIBILITY MATRIX ITEMS AND REFER TO SPECIFICATION BOOK FOR GENERAL NOTES.

CHANGES TO THE DESIGN OF ANY SYSTEM IDENTIFIED ON THESE DRAWINGS OR SPECIFICATIONS SHALL BE SUBMITTED TO THE ENGINEER OF RECORD FOR REVIEW AND APPROVAL PRIOR TO THE FABRICATION AND INSTALLATION. ANY MODIFICATIONS WITHOUT THE ORIGINATING ENGINEER'S WRITTEN AUTHORIZATION AND APPROVAL SHALL BE THE RESPONSIBILITY, AS WELL AS THE COST TO CORRECT SUCH MODIFICATION, OF THE CONTRACTOR.

SPRINKLER SUBMITTAL REQUIREMENTS

THIS FIRE PROTECTION CONTRACTOR SHALL PREPARE DETAILED SHOP DRAWINGS AND CALCULATIONS FOR THEIR WORK. SUBMIT TO THE G.C. FOR ARCHITECTURAL APPROVAL OF HEAD LOCATIONS AND TYPES.

THIS FIRE PROTECTION CONTRACTOR IS RESPONSIBLE FOR SUBMITTING COORDINATED DRAWINGS, HYDRAULIC CALCULATIONS, HEAD TYPES AND COLORS TO ALL AUTHORITIES HAVING JURISDICTION FOR APPROVAL. NO WORK SHALL BEGIN UNTIL ALL APPROVALS HAVE BEEN RECEIVED.

RESPONSIBILITY MATRIX LEGEND

STOREFRONT EXTRUSION		L	O	FACTORY FINISHED
ITEM	L = LANDLORD O = OWNER (GAP INC.) GC= GENERAL CONTRACTOR	FURNISHED BY	INSTALLED BY	COMMENTS

RESPONSIBILITY MATRIX

ITEM	FURNISHED BY	INSTALLED BY	COMMENTS
SPRINKLER MAIN TO LEASE SPACE	E	E	
SPRINKLER BRANCHES AND LATERAL GRID PIPING	E	E	
BACK-FLOW PREVENTOR AND FLOW DETECTOR	E	E	
BRONZE UPRIGHT HEADS IN OPEN OR EXPOSED CEILING AREAS	E/GC	E/GC	

- REMARKS:
- NOTE:
1. THE RESPONSIBILITY MATRIX ONLY DELINEATES ITEMS SUPPLIED AND/OR INSTALLED BY OWNER AND/OR LANDLORD. ANY WORK SHOWN IN THE CONSTRUCTION DOCUMENTS NOT DEFINED AS RESPONSIBILITY OF OWNER OR LANDLORD IS FURNISHED AND INSTALLED BY GENERAL CONTRACTOR. SEE BID CLARIFICATION LETTER FOR ANY VARIATION BY SCOPE OF WORK RESPONSIBILITY.
 2. GENERAL CONTRACTOR IS RESPONSIBLE FOR THE UNLOADING OF ANY OWNER SUPPLIED CONSTRUCTION ITEMS.

RESPONSIBILITY MATRIX BASED ON SIGNED LEASE EXHIBIT DATED 01/21/2021

NEW STORE



GAP INC.
STORE DEVELOPMENT
2 FOLSOM STREET
SAN FRANCISCO, CA 94105

ORACLE ID:

140261

STORE NUMBER:

7341

STORE LOCATION:

STATION PARK
230 NE PROMONTORY
SPACE C-120
FARMINGTON, UT 84025

DESIGN TYPE: DERBY B
GENERATION: 21Q34
PROTOTYPE DATE: 1/8/2021
OPENING: 2021

ARCHITECT INFO:



ARCHITECT OF RECORD:

MARIAH MEYER
8131 METCALF AVE
SUITE 300
OVERLAND PARK, KS 66204

www.brrarch.com

TEL: 913-262-9095
FAX: 913-262-9044

CONSULTANT INFO:



8345 LENEXA DRIVE, SUITE 300
LENEXA, KS 66214
TEL 913.742.5000 FAX 913.742.5001

WWW.HENDERSONENGINEERS.COM

2050004241
UT. CORPORATE NUMBER: 4977264-0143
09/30/21

PROFESSIONAL STAMP:

THIS DOCUMENT IS RELEASED
FOR THE PURPOSE OF
PRELIMINARY SUBMITTAL
SEAN O. EISLER
LICENSE # 7804825-2202

IT IS NOT TO BE USED FOR
CONSTRUCTION
PURPOSES.

ISSUE TYPE:

LL/PERMIT/BID: 02/19/21

REVISIONS:

DRAWN BY: HEI

A/E JOB NUMBER: 65011072

TITLE SHEET:
FIRE SPRINKLER PLAN

SHEET NUMBER:

F1-0