





FIRE ALARM PLAN

FIRE ALARM CODED NOTES

THERMOSTAT FAN WIRE IS WIRED THROUGH THE AND SHUTS DOWN THE HVAC UNIT UPON SENSING ACCESSIBLE LOCATION. INSTALL REMOTE TEST/RESET ACTIVATE FIRE ALARM SYSTEM UPON SENSING SMOKE.

THIS SPACE RESERVED FOR FIRE ALARM PANEL. PROVIDE A SMOKE DETECTOR ABOVE THE POWER SUPPLY IN ACCORDANCE WITH NFPA 72.

MANUAL PULL STATION

AREA SMOKE DETECTOR

STROBE LIGHT WITH cd AS INDICATED, CEILING MOUNTED.

STROBE LIGHT WITH cd AS INDICATED, WALL MOUNTED.

HORN WITH cd STROBE LIGHT AS INDICATED, WALL MOUNTED @ 80" AFF

FIRE ALARM CONTROL PANEL

FACP REMOTE ANNUNCIATOR

PROVIDE MINIMUM cd OUTPUT AS INDICATED IN

PROVIDE COVER PLATES FOR FIRE ALARM PULL STATIONS IF PERMITTED BY CODE.

FIRE ALARM SYSTEM SHOWN ON THESE DRAWINGS ARE FOR SCHEMATIC AND BIDDING PURPOSES ONLY. FIRE ALARM SYSTEM CONTRACTOR SHALL SUBMIT FIRE DRAWINGS, EQUIPMENT CUT SHEETS, ETC. PER LOCAL CODE AND NFPA72 TO LOCAL AUTHORITIES HAVING JURISDICTION AND OWNER'S INSURANCE COMPANY FOR APPROVAL PRIOR TO ORDERING EQUIPMENT. ENGINEER WILL NOT APPROVE FIRE ALARM DRAWINGS, EQUIPMENT CUT SHEETS, ETC. INCLUDE IN BID ALL COSTS FOR PERMITS AND FEES. ALL PANELS AND PERIPHERAL DEVICES SHALL BE STANDARD PRODUCT OF SINGLE MANUFACTURER AND SHALL DISPLAY THE MANUFACTURER'S NAME ON EACH COMPONENT. ACCEPTABLE MODELS (UNLESS LANDLORD REQUIRES DIFFERENT): SILENT KNIGHT 5700 OR 5808.

FIRE ALARM SPECIFICATIONS

2) FIRE ALARM SYSTEM SHALL BE DESIGNED LANDLORD, INSURANCE AGENCY, AND ACCEPTABLE TO THE AUTHORITY HAVING

(100) EXISTING DUCT MOUNTED SMOKE DETECTOR. VERIFY THE NORMALLY CLOSED CONTACT ON THE SMOKE DETECTOR SMOKE. SMOKE DETECTOR MUST BE INSTALLED IN AN STATION AS REQUIRED. COORDINATE LOCATION OF TEST STATION WITH G.C. SMOKE DETECTOR TO BE WIRED TO

(102) FIRE ALARM DEVICES FURNISHED AND INSTALLED BY FIRE ALARM CONTRACTOR SPECIFIED AT G.C.'S EXPENSE. FIRE ALARM CONTRACTOR IS TO CONNECT DEVICES TO FIRE ALARM PANEL.

FIRE ALARM LEGEND

NOTE: UNLESS SHOWN OTHERWISE ON PLANS, FIRE ALARM LEGEND.

A. FIRE ALARM SYSTEM

1) THE FIRE ALARM CONTROL PANEL IS EXISTING TO REMAIN LOCATED IN LANDLORD SPACE. MODIFY THE EXISTING FIRE ALARM SYSTEM AND PROVIDE ALL NECESSARY EQUIPMENT AND CONNECTIONS COMPATIBLE WITH LANDLORD EQUIPMENT FOR A FULLY FUNCTIONAL FIRE ALARM

TO MEET THE REQUIREMENTS OF NFPA 72, JURISDICTION.

SCALE: 1/8" = 1'-0"

NEW STORE

SATHLETA

GAP INC. STORE DEVELOPMENT 2 FOLSOM STREET SAN FRANCISCO, CA 94105

٩

DERBY B DESIGN TYPE: GENERATION: 21Q34 1/8/2021 PROTOTYPE DATE: 2021 OPENING:

ARCHITECT INFO:



3

MARIAH MEYER 8131 METCALF AVE SUITE 300 OVERLAND PARK, KS 66204 www.brrarch.com

CONSULTANT INFO:

FAX:913-262-9044



WWW.HENDERSONENGINEERS.COM UT. CORPORATE NUMBER: 4977264-0143

09/30/21

PROFESSIONAL STAMP:

THIS DOCUMENT IS RELEASED FOR THE PURPOSE OF PRELIMINARY SUBMITTAL WILLIAM R. WINSTON LICENSE # 11811162-2202

IT IS NOT TO BE USED FOR CONSTRUCTION PURPOSES.

ISSUE TYPE:

LL/PERMIT/BID:

REVISIONS:

DRAWN BY: **HEI** A/E JOB NUMBER: 65011072

TITLE SHEET: FIRE ALARM PLAN

SHEET NUMBER: F2-0