



- NOTES
1. PROVIDE OPENING THROUGH ROOF AND ROOF DECK INSULATION NO LARGER THAN REQUIRED TO ALLOW DUCTS TO PASS THROUGH.
 2. INSTALL ROOFTOP UNIT LEVEL TO ENSURE PROPER CONDENSATE DRAINAGE. FLASH AND COUNTERFLASH ROOF CURB, SEAL ROOF PENETRATIONS, ETC. TO ENSURE WEATHER TIGHT INSTALLATION.



- ## CODING NOTES
- | | |
|-----|--|
| 100 | HEATED AIR CURTAIN. SEE AIR CURTAIN SCHEDULE FOR ADDITIONAL INFORMATION. |
| 101 | SUSPEND FROM STRUCTURE ABOVE. 3/8", 16 ALL THREAD ROD AND KINETICS NOISE SRH-1 SPRING VIBRATION ISOLATORS. |
| 102 | INSTALL BOTTOM AT TOP OF GLASS. COORDINATE INSTALLATION WITH EAS EQUIPMENT, TRAFFIC COUNTER EQUIPMENT, EXIT LIGHT, AND LIGHTS. |



NEW STORE



GAP INC.
STORE DEVELOPMENT
2 FOLSOM STREET
SAN FRANCISCO, CA 94105

ORACLE I.D.:

STORE NUMBER:
7341

STORE LOCATION:
**STATION PA
230 NE PROMONTORY
SPACE C-120
FARMINGTON, UT 84025**

DESIGN TYPE:	DERBY B
GENERATION:	21Q34
PROTOTYPE DATE:	1/8/2021
OPENING:	2021

ARCHITECT INFO:

brr

MARIAH MEYER
8131 METCALF AVE
SUITE 300
OVERLAND PARK, KS 66204
www.brrarch.com
TEL: 913-262-9095
FAX: 913-262-9044