

Business
Business: A-1 AUTOBODY & PAINT INC

Phone #: 6445270

Business License #: 1048

50

West

BURTON

Avenue

South Salt Lake

UT

84115

Inspection Overview
Date of Inspection: 07/27/2022

Passed: No

Inspected by: Mathes,
Robert

Inspection Type: Inspection - General

Business License: No Business
License

Unit:
Reason: Scheduled

Shift:
Violation Information
Violation Count: 11

Violations

Violation Code	Description	Comments
1008.3.5	Emergency lighting facilities shall be arranged to provide initial illumination that is not less than an average of 1 footcandle (11 lux) and a minimum at any point of 0.1 footcandle(1 lux) measured along the path of egress at floor level. Illumination levels shall be permitted to decline to 0.6 footcandle (6 lux) average and a minimum at any point of 0.06 footcandle (0.6 lux) at the end of the emergency lighting time duration. A maximum-to-minimum illumination uniformity ratio of 40 to 1 shall not be exceeded. In Group I-2 occupancies, failure of a single lamp in a luminaire shall not reduce the illumination level to less than 0.2 foot-candle (2.2 lux).	Emergency lighting shall be installed within the warehouse.
1013.3	Exit signs shall be internally or externally illuminated. Exception: Tactile signs required by Section 1013.4 need not be provided with illumination.	Internally illuminated exit signs shall be installed within the warehouse

105.6.16	<p>An operational permit is required:</p> <ol style="list-style-type: none"> 1.To use or operate a pipeline for the transportation within facilities of flammable or combustible liquids. This requirement shall not apply to the off-site transportation in pipelines regulated by the Department of Transportation (DOTn) nor does it apply to piping systems. 2.To store, handle or use Class I liquids in excess of 5 gallons (19 L) in a building or in excess of 10 gallons (37.9 L) outside of a building, except that a permit is not required for the following: <ol style="list-style-type: none"> 2.1.The storage or use of Class I liquids in the fuel tank of a motor vehicle, aircraft, motorboat, mobile power plant or mobile heating plant, unless such storage, in the opinion of the fire code official, would cause an unsafe condition. 2.2.The storage or use of paints, oils, varnishes or similar flammable mixtures where such liquids are stored for maintenance, painting or similar purposes for a period of not more than 30 days. 3.To store, handle or use Class II or Class IIIA liquids in excess of 25 gallons (95 L) in a building or in excess of 60 gallons (227 L) outside a building, except for fuel oil used in connection with oil-burning equipment. 4.To store, handle or use Class IIIB liquids in tanks or portable tanks for fueling motor vehicles at motor fuel-dispensing facilities or where connected to fuel-burning equipment. <p>Exception: Fuel oil and used motor oil used for space heating or water heating.</p> <ol style="list-style-type: none"> 5.To remove Class I or II liquids from an underground storage tank used for fueling motor vehicles by any means other than the approved, stationary on-site pumps normally used for dispensing purposes. 6.To operate tank vehicles, equipment, tanks, plants, terminals, wells, fuel-dispensing stations, refineries, distilleries and similar facilities where flammable and combustible liquids are produced, processed, transported, stored, dispensed or used. 7.To place temporarily out of service (for more than 90 days) an underground, protected above-ground or above-ground flammable or combustible liquid tank. 8.To change the type of contents stored in a flammable or combustible liquid tank to a material that poses a greater hazard than that for which the tank was designed and constructed. 9.To manufacture, process, blend or refine flammable or combustible liquids. 10.To engage in the dispensing of liquid fuels into the fuel tanks of motor vehicles at commercial, industrial, governmental or manufacturing establishments in accordance with Section 5706.5.4 or to engage in on-demand mobile fueling operations in accordance with Section 5707. 11.To utilize a site for the dispensing of liquid fuels from tank vehicles into the fuel tanks of motor vehicles, marine craft and other special equipment at commercial, industrial, governmental or manufacturing establishments in accordance with Section 5706.5.4 or, where required by the fire code official, to utilize a site for on-demand mobile fueling operations in accordance with Section 5707. 	<p>An operational hazardous materials permit shall be required for the use the spray paint booth and flammable liquid.</p>
2404.4	<p>Spray booths and spray rooms shall be protected by an approved automatic fire-extinguishing system complying with Chapter 9. Protection shall extend to exhaust plenums, exhaust ducts and both sides of dry filters where such filters are used.</p>	<p>The spraybooth shall have an approved fire suppression system. The fire suppression system shall be connected to an approved fire alarm system.</p>

907.5	<p>A fire alarm system shall annunciate at the fire alarm control unit and shall initiate occupant notification upon activation, in accordance with Sections 907.5.1 through 907.5.2.3.3. Where a fire alarm system is required by another section of this code, it shall be activated by:</p> <ol style="list-style-type: none"> 1. Automatic fire detectors. 2. Automatic sprinkler system waterflow devices. 3. Manual fire alarm boxes. 4. Automatic fire-extinguishing systems. <p>Exception: Where notification systems are allowed elsewhere in Section 907 to annunciate at a constantly attended location.</p>	Occupant notification devices shall be installed within the building for the fire alarm system.
5003.4	<p>Safety Data Sheets (SDS) shall be readily available on the premises for hazardous materials regulated by this chapter. Where a hazardous substance is developed in a laboratory, available information shall be documented.</p> <p>Exception: Designated hazardous waste.</p>	Safety Data Sheets shall be readily available at all times.
506.1.1	An approved lock shall be installed on gates or similar barriers where required by the fire code official.	<p>The gate shall have Knox lock.</p> <p>The only approved providers are knoxbox.com and State Fire protection.</p>
111.1	If during the inspection of a premises, a building or structure, or any building system, in whole or in part, constitutes a clear and inimical threat to human life, safety or health, the fire code official shall issue such notice or orders to remove or remedy the conditions as shall be deemed necessary in accordance with this section, and shall refer the building to the building department for any repairs, alterations, remodeling, removing or demolition required.	<p>The apartment located in the basement of the building shall not be allowed to be occupied until the approved Fire and Life Safety Systems are installed and constructed. The doors leading to the apartment in the basement shall be locked, labeled unoccupied space, and not an exit.</p> <p>Unless all of the fire and life safety codes are met to utilize that space then it shall remain unoccupied. This depends on the use of the space, and occupancy classification.</p>
111.1.1	Structures or existing equipment that are or hereafter become unsafe or deficient because of inadequate means of egress, that constitute a fire hazard, are otherwise dangerous to human life or the public welfare, or involve illegal or improper occupancy or inadequate maintenance, shall be deemed an unsafe condition. A vacant structure that is not secured against unauthorized entry as required by Section 311 shall be deemed unsafe.	The apartment in the basement does not have the correct fire and life safety equipment in place to allow for occupancy. This area is considered an unsafe condition within the space.
604.2	Illumination shall be provided for service equipment areas, motor control centers and electrical panelboards.	The HVAC room in the basement shall have emergency lighting
604.1	Identified electrical hazards shall be abated. Identified hazardous electrical conditions in permanent wiring shall be brought to the attention of the responsible code official. Electrical wiring, devices, appliances and other equipment that is modified or damaged and constitutes an electrical shock or fire hazard shall not be used.	All electrical outlets shall be properly covered (open outlets in the basement)

Notes:

Signatures

Signatures

Type	First Name	Last Name	Signature Date	Signature Graphic
------	------------	-----------	----------------	-------------------

Inspector

Robert

Mathes

07/27/2022

