


1. Dedicated Function Alarm Panel to monitor ONLY the following:
 - 1.1. Smoke Detection
 - 1.2. Pull-Station.
 - 1.3. Contacts from paint mixing room Fire Suppression Contacts
2. There is no wet suppression sprinkler system/valve.
- and
- 2.1. WIRING DEPICTED ON THESE PLANS IS SCHEMATIC
3. Power for ALL Fire Alarm panels, Fire Alarm Power Supplies (& Dialers where necessary), must be provided by a DEDICATED AC BRANCH CIRCUIT

WARNING TO OCCUPANT:
2022-06-13 This design is subject to the Proviso that **NO HAZARDOUS or FLAMMABLE MATERIALS** of any kind are permitted to be stored on-site.
Recommend: adding a Safety Storage Cabinet for paint/thinners.
Further Code Review and permitting will be required .



Fire Suppression Services Inc.
3802 S. 2300 E. Millcreek
Utah 84109-3421
(801) 277-6464

Owner Company inc
OWNER STREET
OWNERS CITY 84115
Owner Name
(801) 573-8045

Drawn by:
Arun
Date drawn:
2022-06-10
Date issued:
2022-06-13

Revisions

Δ	2022-mm-dd CONFIRM part#s
Δ	2022-mm-dd CONFIRM BREAKER Number & Loci
Δ	yyyy-mm-dd revThree
Δ	yyyy-mm-dd RevFour

Project# projVIPCOLOR

Owner Owner Company inc
Tenant VIP Color
Site 3141 S. Main St
South Salt Lake City 84143
sitePhone

Drawing

FA-01

Fire Alarm Symbols/Legend				
Symbol	Description	#	Part Number	Mounting
	Fire Alarm Panel	1	FL-FACP-32-LTE-VS	Wall, @ 66"
	Smoke	1	SystemSensor 2-WB	Above FACP
	Pull station	2	SK-Pull DA	
	Horn strobe	1	SystemSensor P2R	Above door outside valve room
	Batteries	2	Duracell: SLA12-8A	inside FACP

For Professional Automotive Equipment Mike Rudert (801) 292-2224 xt 111



Dedicated Function Fire Alarm @ OwnerName of tenanted space: VIP Color

Dedicated Function Fire Alarm VIP Color Rev-05.dwg