



Fire Inspection Report Printoff

Business

Business: VALLEY COLLISION

Phone #:			Business License #: 1003855
2521	South	300	West
South Salt Lake	UT	84115	

Inspection Overview

Date of Inspection: 12/01/2022	Passed: No	Inspected by: Mathes, Robert
Inspection Type: Inspection - General	Business License: Current	Unit:
Reason: Scheduled		Shift:

Violation Information

Violation Count: 7

Violations

Violation Code	Description	Comments
907.5	<p>A fire alarm system shall annunciate at the fire alarm control unit and shall initiate occupant notification upon activation, in accordance with Sections 907.5.1 through 907.5.2.3.3. Where a fire alarm system is required by another section of this code, it shall be activated by:</p> <ol style="list-style-type: none"> 1. Automatic fire detectors. 2. Automatic sprinkler system waterflow devices. 3. Manual fire alarm boxes. 4. Automatic fire-extinguishing systems. <p>Exception: Where notification systems are allowed elsewhere in Section 907 to annunciate at a constantly attended location.</p>	The fire suppression systems for the spray booths shall be monitored and occupant notification shall be installed.
604.5	<p>Extension cords and flexible cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords and flexible cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors.</p>	Extension cords shall not be used as permanent wiring. Extension cords shall not be plugged into power strips resulting in overloading the circuit.
105.6.16	<p>An operational permit is required:</p> <ol style="list-style-type: none"> 1. To use or operate a pipeline for the transportation within facilities of flammable or combustible liquids. This requirement shall not apply to the off-site transportation in pipelines regulated by the Department of Transportation (DOTn) nor does it apply to piping systems. 2. To store, handle or use Class I liquids in excess of 5 gallons (19 L) in a building or in excess of 10 gallons (37.9 L) outside of a building, except that a permit is 	Hazardous Operational Permit shall be required for this location

not required for the following:

2.1. The storage or use of Class I liquids in the fuel tank of a motor vehicle, aircraft, motorboat, mobile power plant or mobile heating plant, unless such storage, in the opinion of the fire code official, would cause an unsafe condition.

2.2. The storage or use of paints, oils, varnishes or similar flammable mixtures where such liquids are stored for maintenance, painting or similar purposes for a period of not more than 30 days.

3. To store, handle or use Class II or Class IIIA liquids in excess of 25 gallons (95 L) in a building or in excess of 60 gallons (227 L) outside a building, except for fuel oil used in connection with oil-burning equipment.

4. To store, handle or use Class IIIB liquids in tanks or portable tanks for fueling motor vehicles at motor fuel-dispensing facilities or where connected to fuel-burning equipment.

Exception: Fuel oil and used motor oil used for space heating or water heating.

5. To remove Class I or II liquids from an underground storage tank used for fueling motor vehicles by any means other than the approved, stationary on-site pumps normally used for dispensing purposes.

6. To operate tank vehicles, equipment, tanks, plants, terminals, wells, fuel-dispensing stations, refineries, distilleries and similar facilities where flammable and combustible liquids are produced, processed, transported, stored, dispensed or used.

7. To place temporarily out of service (for more than 90 days) an underground, protected above-ground or above-ground flammable or combustible liquid tank.

8. To change the type of contents stored in a flammable or combustible liquid tank to a material that poses a greater hazard than that for which the tank was designed and constructed.

9. To manufacture, process, blend or refine flammable or combustible liquids.

10. To engage in the dispensing of liquid fuels into the fuel tanks of motor vehicles at commercial, industrial, governmental or manufacturing establishments in accordance with Section 5706.5.4 or to engage in on-demand mobile fueling operations in accordance with Section 5707.

11. To utilize a site for the dispensing of liquid fuels from tank vehicles into the fuel tanks of motor vehicles, marine craft and other special equipment at commercial, industrial, governmental or manufacturing establishments in accordance with Section 5706.5.4 or, where required by the fire code official, to utilize a site for on-demand mobile fueling operations in accordance with Section 5707.

5003.5.1 Individual containers, cartons or packages shall be conspicuously marked or labeled in an approved manner. Rooms or cabinets containing compressed gases shall be conspicuously labeled: COMPRESSED GAS.

All hazardous material containers shall be properly labeled.

603.1.7	Working clearances between oil-fired appliances and electrical panelboards and equipment shall be in accordance with NFPA 70. Clearances between oil-fired equipment and oil supply tanks shall be in accordance with NFPA 31.	All fuel fired heating appliances shall have a minimum of 3 feet clearance around them.
906.2	<p>Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.</p> <p>Exceptions:</p> <ol style="list-style-type: none"> 1.The distance of travel to reach an extinguisher shall not apply to the spectator seating portions of Group A-5 occupancies. 2.Thirty-day inspections shall not be required and maintenance shall be allowed to be once every 3 years for dry-chemical or halogenated agent portable fire extinguishers that are supervised by a listed and approved electronic monitoring device, provided that all of the following conditions are met: <ol style="list-style-type: none"> 2.1.Electronic monitoring shall confirm that extinguishers are properly positioned, properly charged and unobstructed. 2.2.Loss of power or circuit continuity to the electronic monitoring device shall initiate a trouble signal. 2.3.The extinguishers shall be installed inside of a building or cabinet in a noncorrosive environment. 2.4.Electronic monitoring devices and supervisory circuits shall be tested every 3 years when extinguisher maintenance is performed. 2.5.A written log of required hydrostatic test dates for extinguishers shall be maintained by the owner to verify that hydrostatic tests are conducted at the frequency required by NFPA 10. 3.In Group I-3, portable fire extinguishers shall be permitted to be located at staff locations. 	Obstructed fire extinguisher on the northeast corner of the structure.
5004.2	<p>Rooms, buildings or areas used for the storage of liquid or solid hazardous materials shall be provided with spill control and secondary containment in accordance with Sections 5004.2.1 through 5004.2.3.</p> <p>Exception: Outdoor storage of containers on approved containment pallets in accordance with Section 5004.2.3.</p>	The areas that are utilizing corrosive liquids were leaking on the floor and secondary containment.

Notes:

Signatures

Signatures

Type	First Name	Last Name	Signature Date	Signature Graphic
Inspector	Robert	Mathes	12/01/2022	