



Fire Suppression Services, Inc.

3802 South 2300 East
Salt Lake City, Utah 84109-3421
Contractor License No. 92-252208-5501
801.277.6464 • 800.273.6465 • 801.278.2199 - FAX

26617

DATE 2/25/2019

B
I
L
L
I
N
G

Coopers

2309 Washington Boulevard
Ogden, Utah 84401

J
O
B
S
I
T
E

Coopers

2309 Washington Boulevard
Ogden, Utah 84401

Billing		Job Site		SALESMAN :		TANK		CARTRIDGE	
PHONE		801-528-5131		Zach & Mike	EE # 61931	DATE	TYPE	DATE	
FAX		801-528-5134							
CONTACT	Tony Crowson	Steve		E-MAIL :					
DIRECT #		Robert							
	WET SYSTEM	DRY CHEM SYS		ALARMS	INSTALLATION	Mileage One-Way		TIME	
	WATER SPRINKLER	EMER LIGHTING		ANTI FREEZE	TIME & MATERIALS	Drive Time One-Way	0 H 00 Min	0:00	
	EXTINGUISHERS	BACKFLOW		EMERGENCY	REPAIR	UNIT PRICE	NON TAX	TAXABLE	
Monday, February 25, 2019						\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	
SCOPE OF WORK: ANNUAL FIRE ALARM INSPECTION						\$ -	\$ -	\$ -	
1	INSPECTION OF ALARM SYSTEM - HONEYWELL ADEMCO VISTA 32-FB					\$ 180.00	\$ 180.00	\$ -	
1	INSPECTION OF ANNUNCIATOR - HONEYWELL					\$ 25.00	\$ 25.00	\$ -	
MET WITH OWNER AND GENERAL MANAGER TO HAVE THE SYSTEM BE						\$ -	\$ -	\$ -	
PLACE ON TEST WITH MONITORING						\$ -	\$ -	\$ -	
TESTED THE FOLLOWING DEVI CES:						\$ -	\$ -	\$ -	
3	DUCT DETECTORS					\$ -	\$ -	\$ -	
3	TAMPER VALVES					\$ -	\$ -	\$ -	
1	WATERFLOW SWITCH					\$ -	\$ -	\$ -	
4	HORNSTROBES					\$ -	\$ -	\$ -	
11	TOTAL DEVICES					\$ 4.50	\$ 49.50	\$ -	
TESTED BATTERIES - FAILED AND REPLACED						\$ -	\$ -	\$ -	
RESTORED SYSTEM TO NORMAL						\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	
1	12 VOLT 8 AMP BATTERY					\$ 53.50	\$ 53.50	\$ -	
						\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	
1	COMPLIANCE ENGINE REPORTING FEE					\$ 30.00	\$ 30.00	\$ -	
						\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	
1	TRANSPORTATION					\$ 35.00	\$ -	\$ -	
HAZARDOUS MATERIAL DISPOSAL CHARGE								\$ -	
DUE WHEN		LAST COMPANY		NUMBER ON PROPERTY		8% MISCELLANEOUS MATERIALS, INSURANCE, ETC.		\$ 27.04	
EXTINGUISHER						CODE		SUBTOTAL \$ 365.04	
EM / EX LIGHTING								TRANSPORTATION \$ 35.00	
HOOD CLEANING								Non-Taxable Total \$ 365.04	
RISER								Taxable Sales \$ -	
								SALES TAX \$ -	
								Freight \$ -	
								Handling \$ -	
I, RECEIPT OF COPY: CUSTOMER ACKNOWLEDGES RECEIPT OF COPY AND THAT HE UNDERSTANDS ALL OF THIS AGREEMENT AND PARTICULARLY PARAGRAPHS 1,2,3,4 AND 5 ON THE REVERSE WHICH SETS FORTH COMPANY'S MAXIMUM LIABILITY. THE SYSTEMS HAVE BEEN SERVICED IN ACCORDANCE WITH NATIONAL FIRE PROTECTION STANDARDS AND CODES OR CURRENT MFG. SERVICE REQUIREMENTS AND DOES NOT CERTIFY THE DESIGN AND / OR THE INSTALLATION CRITERIA. CLAIMS WILL NOT BE HONORED AFTER TEN (10) DAYS FROM DATE OF SERVICE.									
Net 15 Days		RECEIVED IN GOOD ORDER AND ACCEPTED				TOTAL		\$ 400.04	
		WORK AUTHORIZATION NUMBER # 30176							
		PURCHASE / WORK ORDER NUMBER							
BY X									
BUYER SHALL PAY SELLER FOR THIS PURCHASE									

INTEREST WILL BE CHARGED ON OVERDUE ACCOUNTS.

3% PER MONTH

MINIMUM BILLING OF \$35.00

"THIS INVOICE IS ALSO YOUR STATEMENT"

THANK YOU



Fire Suppression Services, Inc.

3802 South 2300 East
Salt Lake City, Utah 84109-3421
(801) 277-6464 Fax (801) 278-2199
(800) 273-6465

WORK AUTHORIZATION

JOB NO: 30176

DATE: 2/25/2019

SALESMAN: TACA HAZBOM

CUST. P.O.: _____

INVOICE: _____

JOB COOPER'S SPORTS BAR & GRILL

2309 WASHINGTON BLVD.

OGDEN, UT 84401

DESCRIPTION OF WORK Alarm Inspection

PERSON TO CONTACT AT JOB SITE

T & M ☒ CONTRACT ☐ AMOUNT \$

Est. MIKS
2 2

Met with owner & GM Had system placed on
Test w/monitoring

Tested all connected alarm devices

tested notification

tested panel battery

* Replaced panel battery

Restored system to normal

MATERIALS

(1) 12V 8AH Battery

SUBSISTENCE AND MILEAGE _____

SUBCONTRACTS AND MISC. _____

REMARKS: _____

WORK AUTHORIZED BY X AS

NAME (PRINTED) Steve Trajillo

TITLE General Manager

SUBJECT TO TERMS AND CONDITIONS ON REVERSE SIDE

Fire Alarm Inspection Report

This form is to be completed by the system inspection and testing contractor at the time of the system test. It shall be permitted to modify this form as needed to provide a more complete and/or accurate record. Insert N/A in all unused lines. Attach additional sheets, data, or calculation as needed to provide a complete record.

1. Property Information

Property Name:	Cooper's Sports Bar & Grill	Sprinkled:	Yes		
Property Address:	2309 Washington Blvd. Oden, Ut. 84401				
Inspection Date:	Feb 25, 2019	Time:	10:00 AM	Compliant / Deficient:	COMPLIANT
	Initial/ Acceptance	Annual	Semiannual	Quarterly	Monthly
Inspection Type:		✓			

2. Inspection & Testing Contractor

Company Name:	Fire Suppression Services
Company Address:	3802 S. 2300 E. Millcreek, Ut. 84109
Company Phone:	801-277-6464

3. Central Station Monitoring Information

Monitoring Company:	Denco
Company Phone:	1-801-627-2720
Monitoring Account #:	N/A
Transmission Format:	N/A
Entity Alarms Are Retransmitted:	Ogden City Fire Department
Phone:	N/A

4. Notifications Made Prior To Testing

Monitoring Organization:	Contact:	Denco	Time:	10:30 AM
Building Management:	Contact:	Steve Trujillo	Time:	N/A
Building Occupants:	Contact:	N/A	Time:	N/A
Authority Having Jurisdiction:	Contact:	N/A	Time:	N/A

5. Description of System Or Service

5.1 Control Panel(s)

Manufacturer:	Honeywell	Model:	Ademco Vista 32-FB	Quantity:	1
Location:	Water heater/ Roof Access Room				
Means Of Transmission:	Pots	Primary Line Connected To Panel:	N/A		
Primary (Main) Power:	120Vac	Secondary Line Connected To Panel:	N/A		
Over Current Protection Type:	Circuit Breaker	Disconnect Location:	N/A	Amps:	20
Secondary Power:	Battery	Standby Mode (Hours):	24	Alarm (Minutes):	5

5.2 Remote Power Panel(s)

Manufacturer:	N/A	Model:	N/A	Quantity:	N/A
Location(s):	N/A				
Over Current Protection Type:	N/A	Disconnect Location:	N/A	Amps:	N/A
Secondary Power:	N/A	Standby Mode (Hours):	N/A	Alarm (Minutes):	N/A

Manufacturer:	N/A	Model:	N/A	Quantity:	N/A
Location(s):	N/A				
Over Current Protection Type:	N/A	Disconnect Location:	N/A	Amps:	N/A
Secondary Power:	N/A	Standby Mode (Hours):	N/A	Alarm (Minutes):	N/A

5.3 Annunciator(s)

Manufacturer:	Honeywell	Model:	N/A	Quantity:	1
Annunciator Location(s):	Front Entry				

6. Testing Results

6.1 Control Panel And Related Equipment

Description	Visual Inspection		Functional Test		N/A	Comments
	(Pass)	(Fail)	(Pass)	(Fail)		
Control Unit	✓		✓			
Lamps/LEDs/LCDs	✓		✓			
Fuses	✓		✓			
Trouble Signals	✓		✓			
Disconnect Switches	✓		✓			
Ground-fault	✓		✓			
Supervision	✓		✓			
Local annunciator	✓		✓			
Remote annunciators	✓		✓			
Remote power panels					N/A	

6.2 Secondary Power

Description	Visual Inspection		Functional Test		N/A	Comments
	(Pass)	(Fail)	(Pass)	(Fail)		
Battery Condition	✓		✓			
Load Voltage	✓		✓			
Discharge Test	✓		✓			
Charger Test	✓		✓			
Remote Panel Batteries	✓		✓			

6.3 Auxiliary Functions

Description	Visual Inspection		Functional Test		N/A	Comments
	(Pass)	(Fail)	(Pass)	(Fail)		
Door Releasing					N/A	
Door Unlocking					N/A	
Elevator Recall					N/A	
Elevator Shunt Trip					N/A	
HVAC Shutdown					N/A	

6.4 Supervising Station Signal Receipts

Description	Yes	No	N/A	Time	Comments
Alarm Signal	✓				
Alarm Restoration	✓				
Trouble Signal	✓				
Trouble Restore	✓				
Supervisory Signal	✓				
Supervisory Restore	✓				

6. Testing Results (Continued)

6.5 Public Emergency Alarm Reporting System

Description	Yes	No	N/A	Time	Comments
Alarm Signal	✓				
Alarm Restoration	✓				
Trouble Signal	✓				
Trouble Restore	✓				
Supervisory Signal	✓				
Supervisory Restore	✓				

6.6 Alarm & Supervisory Alarm Initiating Device (Supplementary Sheet Attached)

Yes ✓ No

6.7 Notification Appliances (Supplementary Sheet Attached)

Yes ✓ No

6.8 Interface Equipment (Supplementary Sheet Attached)

Yes No ✓

7. Notifications That Testing Is Complete

Comments

Monitoring Organization:	Denco	Time:	11:00 AM	
Building Management:	Steve Trujillo	Time:	11:10 AM	
Building Occupants:	N/A	Time:	N/A	
Authority Having Jurisdiction:	N/A	Time:	N/A	
Other (Specify)	N/A	Time:	N/A	

8. Device Counts

Alarm Devices	Quantity	N/A	Notification Devices	Quantity	N/A
Photo Smoke Detectors	0	N/A	Bells	0	N/A
Ion Smoke Detectors	0	N/A	Horns	0	N/A
Photo Smoke/ CO Detectors	0	N/A	Horn/Strobes	4	
Photo Smoke/ Heat Detectors	0	N/A	Strobes	0	N/A
Pull Stations	0	N/A	Speakers	0	N/A
Heat Detectors	0	N/A	Speaker/Strobes	0	N/A
Duct Detectors	3		Low Frequency Horn/Strobes	0	N/A
Tamper Valves	3		Sounder Bases	0	N/A
Water Flow Switches	1		Other Devices (Specify)		
Temperature Switches	0	N/A			N/A
Pressure Switches	0	N/A			N/A
Sync Modules	0	N/A			N/A
Monitor Modules	0	N/A			N/A
Control Relays	0	N/A			N/A

11. System Restored To Normal Operation

Date:


Feb 25, 2019

Time:

9:45 AM

12. Inspection Report Notes, Comments & Recommendations**13. Certification**

Signature:



Printed Name:

Zach Hagblom

Date:

Feb 25, 2019

Organization:

Fire Suppression Services

Title:

Alarm Technician

Phone:


801-793-8937

Qualifications:

AE-248

14. Defects Or Malfunctions Not Corrected At Conclusion of System Inspection**15. Acceptance by Owner or Owner's Representative**

Signature:



Printed Name:

Steve Trujillo

Date:

Feb 25, 2019

Organization:

Cooper's Sports Bar & Grill

Title:

General Manager

Phone:

1-801-915-8302

Backup Battery Inspection						
Location:	FACP					
Type:	Sealed Lead Acid					
Nominal Voltage:	12					
Amp/Hour Rating:	8					
Quantity:	1					
Comments			Pass	Fail	N/A	Notes
Visual Inspection:	New		✓			Replaced 02/25/2019
Voltage Reading:	New	N/A	✓			N/A
Amp/Hour Reading:	New	N/A	✓			N/A
Location:	N/A					
Type:	N/A					
Nominal Voltage:	N/A					
Amp/Hour Rating:	N/A					
Quantity:	N/A					
Comments			Pass	Fail	N/A	Notes
Visual Inspection:	N/A		✓			N/A
Voltage Reading:	N/A	N/A	✓			N/A
Amp/Hour Reading:	N/A	N/A	✓			N/A
Location:	N/A					
Type:	N/A					
Nominal Voltage:	N/A					
Amp/Hour Rating:	N/A					
Quantity:	N/A					
Comments			Pass	Fail	N/A	Notes
Visual Inspection:	N/A		✓			N/A
Voltage Reading:	N/A	N/A	✓			N/A
Amp/Hour Reading:	N/A	N/A	✓			N/A
Location:	N/A					
Type:	N/A					
Nominal Voltage:	N/A					
Amp/Hour Rating:	N/A					
Quantity:	N/A					
Comments			Pass	Fail	N/A	Notes
Visual Inspection:	N/A		✓			N/A
Voltage Reading:	N/A	N/A	✓			N/A
Amp/Hour Reading:	N/A	N/A	✓			N/A
Location:	N/A					
Type:	N/A					
Nominal Voltage:	N/A					
Amp/Hour Rating:	N/A					
Quantity:	N/A					
Comments			Pass	Fail	N/A	Notes
Visual Inspection:	N/A				N/A	N/A
Voltage Reading:	N/A	N/A			N/A	N/A
Amp/Hour Reading:	N/A	N/A			N/A	N/A

6.6 Supplementary Initiating Device Test Results

[illegible]

6.7 Supplementary Notification Appliance Test Results

[illegible]

6.8 Interface Component Testing Sheet

[illegible]