
R-102 RESTAURANT FIRE SUPPRESSION SYSTEM









Bulletin No. 2015197

DATE: October 5, 2015

TO: Authorized ANSUL® R-102 Restaurant System Distributors and OEM's

FROM: Product Management, Restaurant Systems

SUBJECT: Garland CXBE12 Broiler

NOTICE: It is the responsibility of your company to verify that this information has been received by the


employees who currently hold valid certification credentials for design and/or service of the system(s)

referenced within this bulletin.


Tyco Fire Protection Products is pleased to announce an additional appliance-specific R-102 restaurant fire protection option for the Garland Electric Dual-Side Clamshell Broiler Model CXBE12. This is an additional option to the coverage shown in the ANSUL R-102 Restaurant Fire Suppression System Design, Installation, Recharge and Maintenance Manual (Part No. 418087-12).

The following nozzle positioning and coverage limitations must be followed.

Single 230 Nozzle Protection for Garland CXBE12 Broiler



Broiler Top View



Broiler Side View

tycoFire Protection Products

Copyright @ 2015 Tyco Fire Products LP. I All rights reserved.



Bulletin No. 2015197 October 5, 2015 Page 2

R102: UL EX3470

Specifications

Top Cooking Surface: 10.2 in. x 22.4 in.

(259 mm x 568 mm)

Bottom Cooking Surface: 10.8 in. x 22.2 in

(274 mm x 564 mm)

Total Load: 16 kW

This bulletin is a supplement to the ANSUL R-102 Restaurant System Design, Installation, Recharge, and Maintenance Manual (Part No. 418087-12), dated 2014-SEP-01.

This bulletin is NOT intended to replace the requirements and limitations outlined within the ANSUL R-102 System Manual listed in this bulletin. The information contained in this bulletin will be ADDED to the manual at the next update. However, we are providing this document immediately for appliance protection.

Should you have questions regarding this bulletin, please contact Technical Services as noted below.

Thank you for your continued support of ANSUL brand fire suppression products.



This manual is intended for use with ANSUL® R-102 Restaurant Fire Suppression Systems.

Those who install, operate, recharge, or maintain these fire suppression systems should read this entire manual. Specific sections will be of particular interest depending upon one's responsibilities.

Design, installation, recharge, and maintenance of the system must conform to the limitations detailed in this manual and performed by an individual who attended an ANSUL training program and became trained to install, recharge, design, and maintain the ANSUL system.

Fire suppression systems are mechanical devices. They need periodic care. Maintenance is a vital step in the performance of your fire suppression system. As such it must be performed in accordance with NFPA 96 (Standard for the Installation of Equipment for the Removal of Smoke and Grease-Laden Vapors from Commercial Cooking Equipment) and NFPA 17A (Standard on Wet Chemical Extinguishing Systems) by an authorized ANSUL distributor. To provide maximum assurance that the fire suppression system will operate effectively and safely, maintenance must be conducted at six-month intervals, or earlier if the situation dictates. Twelve-year maintenance must include agent tank hydrostatic testing.

ANSUL PART NO. 418087-12

ANSUL, R-102, and the product names listed in this material are marks and/or registered marks. Unauthorized use is strictly prohibited.

EXPLANATION OF SAFETY ALERTS

UL EX3470 ULC EX3470 REV. 11 2014-SEP-01

A DANGER

Indicates a hazardous situation in which a person will experience serious personal injury or death if the situation is not avoided.

↑ WARNING

Indicates a hazardous situation in which a person could experience serious personal injury or death if the situation is not avoided.

A CAUTION

Indicates a hazardous situation in which a person could experience minor or moderate personal injury if the situation is not avoided.

CAUTION

Addresses practices not related to personal injury, such as a system part malfunctioning, property damage, or system failure.

NOTICE

Addresses general practices or observations related to system function that are not related to personal injury.

REVISION RECORD

UL EX3470 ULC EX3470

2014-SEP-01 REV. 11 PAGE 1

DATE	PAGE	REV. NO.	DATE	PAGE	REV. NO.
2014-SEP-01	Complete manual has been reformatted along with several revised pages that contain updated technical information. For clarity, all pages have been changed to Revision 11, regardless of previous revision number. Technical information changes have been noted with a revision indicator ().				
			I	1	

- ▶ Indicates revised information.
- Indicates change in page sequence.

REVISION RECORD

UL EX3470 ULC EX3470

PAGE 2 REV. 11 2014-SEP-01

DATE	PAGE	REV. NO.	DATE	PAGE	REV. NO.

- ► Indicates revised information.
- Indicates change in page sequence.

UL EX3470 ULC EX3470

2014-SEP-1 REV. 11 PAGE TOC-1

SECTION	PAGES	SECTION	PAGES
I. GENERAL INFORMATION	1-1 – 1-4	III. SYSTEM COMPONENTS (Continued)	3-1 – 3-12
DESIGN AND APPLICATION	1-1	PULLEY TEE	3-8
UL LISTING	1-1		3-8
SYSTEM APPROVALS	1-1	ANSUL STAINLESS STEEL CABLE REMOTE MANUAL PULL STATION	3-8 3-9
DEFINITION OF TERMS	1-1 – 1-3	FLEXIBLE CONDUIT	3-9
II CYCTEM DECCRIPTION	0.4 0.0	MECHANICAL GAS VALVES	3-9
II. SYSTEM DESCRIPTION	2-1 – 2-2	ELECTRICAL GAS VALVES	3-10
TOTAL SYSTEM Single-Tank	2-1 2-1	MANUAL RESET RELAY	3-10
Double-Tank	2-1	ELECTRICAL SWITCHES	3-10
Three-Tank	2-2	ALARM INITIATING SWITCH	3-11
Multiple-Tank	2-2	REGULATOR TEST KIT	3-11
III. SYSTEM COMPONENTS	3-1 – 3-12	FUSIBLE LINK	3-11
EXTINGUISHING AGENT	3-1	MAXIMUM REGISTERING	3-11
		THERMOMETER	
AUTOMAN REGULATED RELEASE ASSEMBLY	3-1	HOSE/GROMMET PACKAGE	3-11
(MECHANICAL)	0.4	IN-LINE BURST DISC ASSEMBLY (MANIFOLDED SYSTEMS ONLY)	3-12
AUTOMAN REGULATED RELEASE ASSEMBLY	3-1	1/4 IN. CHECK VALVE	3-12
(ELECTRICAL)		NOZZLE AIMING DEVICE	3-12
REMOTE MECHANICAL RELEASE	3-2	STAINLESS STEEL ACTUATOR HOSE	3-12
SINGLE TANK ENCLOSURE ASSEMBLY	3-2	AGENT DISTRIBUTION HOSE AND RESTRAINING CABLE KIT	3-12
RED PAINTED BRACKET ASSEMBLY	3-2	IV. SYSTEM DESIGN	4-1 – 4-76
REGULATED ACTUATOR ASSEMBLY	3-3	NOZZLE PLACEMENT REQUIREMENTS	4-1 – 4-31
AGENT TANK ASSEMBLY	3-3	Duct Protection	4-1 – 4-3
OEM RELEASE/BRACKET ASSEMBLY (FOR OEM IN-CABINET USE ONLY)	3-3	Transition Protection Electrostatic Precipitator Protection	4-4 4-4
OEM REGULATED ACTUATOR ASSEMBLY	3-3	Plenum Protection Appliance Protection	4-5 – 4-6
TWO TANK ENCLOSURE ASSEMBLY	3-4	Fryer – Single Nozzle Protection Fryer – Multiple Nozzle Protection	4-7 – 4-9 4-10 – 4-12
24VDC REGULATED RELEASE	3-4	Tilt Skillet/Braising Pan	4-12
ASSEMBLY	3-4	Range Protection	4-13 - 4-17
ADDITIONAL SHIPPING ASSEMBLY	3-4	Griddle Protection Chain Broiler Protection	4-18 – 4-21 4-21
GAS CARTRIDGES	3-5	Horizontal Chain Broiler Protection	4-21
NOZZLES	3-5	Overhead Chain Broiler Protection	4-22
		Salamander Broiler Protection	4-23 4-23 – 4-24
SILICONE LUBRICANT	3-5	Upright Broiler/Salamander Protection	4-23 – 4-24
SWIVEL ADAPTOR	3-6	Gas-Radiant/Electric Char-Broiler	4-24
RUBBER BLOW-OFF CAP	3-6	Protection	
METAL BLOW-OFF CAP	3-6	Electric Char-Broiler Protection Lava-Rock (Ceramic) Char-Broiler	4-24 4-25
REDUCING COUPLING	3-6	Protection	4-23
CONDUIT OFFSET ASSEMBLY	3-6	Natural Charcoal Broiler Protection	4-25
"QUIK-SEAL" ADAPTOR	3-6	Alternate Ceramic/Natural	4-26
"COMPRESSION-SEAL" ADAPTOR	3-7	Charcoal Char-Broiler Protection Wood Fueled Char-Broiler Protection	4-26
"HOOD SEAL" ADAPTOR ASSEMBLY	3-7	Wok Protection Nozzle Application Chart	4-27 4-28 – 4-31
COCKING LEVER/LOCK PIN	3-7	SPECIFIC APPLICATION BY MODEL	4-32 - 4-52
DETECTORS	3-8	OVERLAPPING NOZZLE COVERAGE	4-00 – 4-00
PULLEY ELBOWS	3-8		

TABLE OF CONTENTS

UL EX3470 ULC EX3470 PAGE TOC-2 REV. 11 2014-SEP-1

SECTION	PAGES	SECTION	PAGES
IV. SYSTEM DESIGN (Continued)	4-1 – 4-76		5-1 – 5-44
TANK AND CARTRIDGE REQUIREMENTS	4-61		5-35
ACTUATION AND EXPELLANT GAS LINE REQUIREMENTS	4-61 – 4-63		5-36 – 5-38
DISTRIBUTION PIPING REQUIREMENTS	4-63 – 4-70	SWITCHES INSTALLING ALARM	5-39
General Piping Requirements Supply and Branch Line	4-63 4-64 – 4-65	INITIATING SWITCH	
Identification 1.5 Gallon System	4-66	ELECTRICAL SWITCH REQUIREMENTS	5-40 – 5-42
3.0 Gallon System 6.0 Gallon Manifolded System 9.0 Gallon System	4-67 4-68 – 4-69 4-70	WIRING 24VDC REGULATED RELEASE ASSEMBLY	5-43
DETECTION SYSTEM	4-71 – 4-73	VI. TESTING AND PLACING IN SERVICE	6-1 – 6-4
REQUIREMENTS		TESTING MANUAL PULL STATION	6-1
Detector Identification Detector/Pulley Elbow/Conduit	4-71 4-71	TESTING MECHANICAL GAS VALVES	6-1 – 6-2
Off-set Design Limitations Detector Placement Requirements Detection Line Requirements	4-71 – 4-72 4-72	TESTING ELECTRICAL GAS VALVES	6-2
Fusible Link Selection	4-72 4-72	TESTING ELECTRIC SWITCH	6-2 - 6-3
Electric Thermal Detector	4-73	TESTING DETECTION SYSTEM	6-3 – 6-4
MANUAL PULL STATION REQUIREMENTS	4-73	VII. RECHARGE AND RESETTING PROCEDURES	7-1 – 7-6
MECHANICAL GAS VALVE REQUIREMENTS	4-74	CLEANUP PROCEDURES	7-1
ELECTRICAL GAS VALVE	4-74 – 4-75	RECHARGE	7-1 – 7-4
REQUIREMENTS	4-75	RESETTING	7-4 – 7-6
Approvals	_	REPLACEMENT CARTRIDGE	7-6
ALARM INITIATING SWITCH REQUIREMENTS	4-75	VIII. MAINTENANCE EXAMINATION	8-1 – 8-12
ELECTRICAL SWITCH REQUIREMENTS	4-75		8-1 – 8-5
V. INSTALLATION INSTRUCTIONS	5-1 – 5-44		8-5
INSTALLING RELEASE ASSEMBLY COMPONENTS	5-1 – 5-3		8-6 – 8-11
INSTALLING THE DISTRIBUTION	5-4 – 5-5	EXAMINATION	
PIPING		IX. APPENDIX	9-1 – 9-18
INSTALLING THE AGENT	5-5 – 5-8	SYSTEM SELECTION GUIDE	9-1 – 9-4
DISTRIBUTION HOSE (FOR CASTERED/MOVEABLE EQUIPMENT)	1	SYSTEM COMPONENT INDEX	9-5 – 9-8
INSTALLING THE ACTUATION AND	5-8 – 5-12	PARTS LISTS	9-9 – 9-14
EXPELLANT GAS LINE INSTALLING THE DETECTION	5-13 – 5-16	MULTIPLE NOZZLE FRYER PROTECTION CALCULATION	9-15 – 9-16
SYSTEM	0 10 0 10	EXAMPLES WIRING DIAGRAM	9-16 – 9-17
INSTALLING REMOTE MANUAL PULL STATION General Installation Requirements	5-17 – 5-18 5-17	WIKING DIAGRAW	9-10 – 9-17
Installation for Remote Manual Pull Station Utilizing EMT Conduit Only	5-17 – 5-18		
INSTALLING MECHANICAL GAS VALVE	5-18 – 5-22		
INSTALLING REMOTE MANUAL PULL STATION OR MECHANICAL GAS VALVE UTILIZING FLEXIBLE CONDUIT	5-22 – 5-34		

2014-SEP-01 REV. 11 PAGE 1-1

DESIGN AND APPLICATION

The ANSUL R-102 Restaurant Fire Suppression System is developed and tested to provide fire protection for restaurant cooking appliances, hoods, and ducts. It is a pre-engineered group of mechanical and electrical components for installation by an authorized ANSUL distributor. The basic system consists of an AUTOMAN regulated release assembly which includes a regulated release mechanism and a liquid agent storage tank housed within a single enclosure. Nozzles, detectors, cartridges, liquid agent, fusible links, pulley tees, and pulley elbows are supplied in separate packages in the quantities needed for each fire suppression system arrangement.

The system provides automatic actuation; or it can be actuated manually through a remote manual pull station. The system is also capable of shutting down appliances at system actuation. For appliance shutdown requirements, refer to the current version of NFPA 17A, "Standard For Wet Chemical Extinguishing Systems," and NFPA 96, "Standard For Ventilation Control and Fire Protection of Commercial Cooking Operations."

Additional equipment includes: remote manual pull station, mechanical and electrical gas valves, and electrical switches for automatic equipment and gas line shut-off. Accessories can be added, such as alarms, warning lights, etc., to installations where required.

The R-102 system suppresses fire by spraying the plenum area, the filters, cooking surfaces, and the exhaust duct system with a predetermined flow rate of ANSULEX Low pH Liquid Fire Suppressant. When the liquid agent is discharged onto a cooking appliance fire, it cools the grease surface, and reacts with the hot grease (saponification) forming a layer of soap-like foam on the surface of the fat. This layer acts as insulation between the hot grease and the atmosphere, thus helping to prevent the escape of combustible vapors.

Exhaust fans in the ventilating system should be left on. The forced draft of these fans assists the movement of the liquid agent through the ventilating system, thus aiding in the fire suppression process. These fans also provide a cooling effect in the plenum and duct after the fire suppression system has been discharged. The system is UL listed with or without fan operation.

Make up or supply air fans, internal to the exhaust hood(s) being protected, shall be shut down upon system actuation.

Along with the fire suppression system, the total system design must include hand portable fire extinguisher(s) located within the cooking/restaurant area that can be used to manually suppress a fire that may be burning in an unprotected area. Class K extinguisher(s) must be provided for hazards where there is a potential for fires involving combustible cooking media (vegetable or animal oils and fats). Refer to NFPA 10, "Standard For Portable Fire Extinguisher," for additional information.

UL LISTING

The R-102 Restaurant Fire Suppression System has been tested and is listed by Underwriters Laboratories, Inc. as a pre-engineered system. The system is in compliance with UL Test Standard 300. These tests require extinguishment of fires which are initiated in deep fat fryers, ranges, griddles, char-broilers, woks, upright broilers, chain-broilers, filters, plenum chambers, hoods, and ducts after pre-loading each appliance with a prescribed amount of cooking grease. Each fire is allowed to progress to maximum intensity before the fire suppression system is actuated.

SYSTEM APPROVALS

- UL EX3470
- ULC EX3470
- ► COA #5663 (NYC)

DEFINITION OF TERMS

Actuation Gas Line: Piping and/or stainless steel braided hose assemblies from the AUTOMAN Regulated Release Assembly which supplies high pressure nitrogen or carbon dioxide to the Regulated Actuator Assembly for multiple-tank system actuation.

Agent Tank: A pressure vessel containing the liquid agent.

AUTOMAN Regulated Release Assembly (Electrical): An assembly which contains the regulated release mechanism, agent tank (ordered separately), expellant gas hose, solenoid, and electric switch within a metal enclosure. The enclosure contains knockouts to facilitate component hookups.

AUTOMAN Regulated Release Assembly (Mechanical): An assembly which contains the regulated release mechanism, agent tank (ordered separately), and expellant gas hose within a metal enclosure. The enclosure contains knockouts to facilitate component hookups.

Authority Having Jurisdiction: The "authority having jurisdiction" is the organization, office, or individual responsible for "approving" equipment, an installation, or a procedure. The phrase "Authority Having Jurisdiction" is used in a broad manner since jurisdictions and "approval" agencies vary as do their responsibilities. Where public safety is primary, the "authority having jurisdiction" may be a federal, state, local, or other regional department or individual such as a fire chief, fire marshal, chief of a fire prevention bureau, labor department, health department, building official, electrical inspector, or others having statutory authority. For insurance purposes, an insurance company representative may be the "authority having iurisdiction." In many circumstances the property owner or his designated agent assumes the role of the "authority having jurisdiction;" at government installations, the commanding officer or departmental official may be the "authority having jurisdiction."

Blow-Off Cap: A siliconized rubber or metal cap which covers the end of the nozzle to protect the nozzle tip and minimize cooking grease migration into the nozzle orifice.

Branch Line: The agent distribution piping which extends from the supply line to the nozzle(s).

SECTION 1 – GENERAL INFORMATION

UL EX3470 ULC EX3470

PAGE 1-2 REV. 11 2014-SEP-01

DEFINITION OF TERMS (Continued)

Bursting Disc: A disc installed in the tank adaptor which minimizes the remote chance of siphoning of the agent into the discharge piping during extreme temperature variations.

Cartridge: A hermetically sealed, steel pressure vessel containing nitrogen or carbon dioxide gas used to pressurize the agent tank.

➤ Cooking Appliance: Includes, but is not limited to, fryers, griddles, ranges, upright broilers, chain broilers, natural charcoal broilers, or char-broilers (electric, lava rock, gas-radiant, or mesquite).

Cooking Area: Cooking area is defined as the maximum surface that requires protection. Each type of appliance has a defined cooking area with parameters that vary for each appliance. For example, the cooking area for a griddle is the entire flat cooking surface, while a fryer may have two areas that need consideration, depending on whether the fryer has a dripboard or not.

Conduit Offset Assembly: A pre-formed piece of conduit which can be installed between the ANSUL regulated release and the conduit to allow the wire rope for the detection, gas valve and remote manual pull station to be installed in a more convenient manner.

Depth: When referring to depth as a linear dimension, it is the horizontal dimension measured from front to back of the appliance or plenum.

Detector: A device which includes the detector bracket, detector linkage, and fusible link used for automatic operation of the fire suppression system.

Detector Linkage: A device used to support the fusible link.

Discharge Hose Assembly: An agent distribution hose to be used with castered cooking appliances with castered supports to allow the movement of the appliance for service or cleaning purposes.

Distribution Piping: Piping which delivers the extinguishing agent from the tank to each discharge nozzle. See also Supply or Branch lines.

Ducts (or Duct System): A continuous passageway for the transmission of air and vapors which, in addition to the containment components themselves, may include duct fittings, dampers, duct filters, duct transitions, in-line or end-duct pollution control units (PCUs), and/or other items or air handling equipment.

Electrostatic Precipitator: A device used to aid in the cleaning of the exhaust air. This device is normally installed at or near the base of the ventilation duct or may be included as an integral part of a pollution control unit (PCU).

Expellant Gas Line: Piping and/or hose which supplies the nitrogen or carbon dioxide gas from the regulated release assembly/regulated actuator assembly to each agent tank.

Flexible Conduit: A flexible means to route stainless steel cable from the AUTOMAN Regulated Release to a manual pull station or mechanical gas valve.

Flow Number: Term used in system design to describe the flow capacity of each nozzle used to determine the quantity of tanks needed to cover a certain group of hazards.

Fusible Links: A fixed temperature heat detecting device employed to restrain the operation of a mechanical control until its designed temperature is reached, allowing separation of the link and system operation.

Gas Valve: An electrically or mechanically operated device used to shut off the gas supply to the cooking equipment when the system is actuated.

Gas Valve Air Cylinder: An air cylinder, located in the release mechanism, which operates pneumatically to mechanically unlatch a mechanical gas valve actuator, causing the gas valve to close upon system actuation.

High Proximity: Indicates a distance (vertically) between the nozzle tip and the surface of the appliance being protected.

Hood: A device provided for cooking appliances to direct and capture grease-laden vapors and exhaust gases from cooking appliances. It shall be constructed in a manner which meets the requirements of NFPA 96.

Liquid Agent: A potassium-based solution used for the knockdown and suppression of fire.

Low Proximity: Indicates a distance (vertically) between the nozzle tip and the surface of the appliance being protected.

Maximum Length of Cooking Appliance: The maximum dimension, on any side, which may be protected by one nozzle.

Maximum Piping: Specified length of piping and number of fittings which must not be exceeded for each system.

Medium Proximity: Indicates a distance (vertically) between the nozzle tip and the surface of the appliance being protected.

Minimum Piping: Minimum length of distribution piping required between the agent tank outlet and any nozzle protecting a ▶ range, fryer, or wok.

Nozzle: A device designed to deliver the liquid agent with a specific flow rate and stream pattern.

Overlapping Protection: When discharge nozzles are spaced equally apart over one or more appliances requiring protection. Nozzles used in this manner provide area protection of eligible appliances within the protected area. Two types of overlapping protection is available: full hood continuous protection and group protection. Overlapping protection is in addition to appliance specific coverages.

Plenum: The space enclosed by the filters and the portion of the hood above the filters.

Pre-engineered System: NFPA 17A defines a pre-engineered system as one which has "...predetermined flow rates, nozzle pressures, and quantities of liquid agent." The R-102 system, as prescribed by UL (Underwriter's Laboratories), has specific pipe sizes, maximum and minimum pipe lengths and numbers of fittings, and number and types of nozzles. The hazards protected by this system are also specifically limited as to type and size by UL based upon actual fire tests. All limitations on hazards that can be protected and piping and nozzle configurations are contained in the R-102 installation and maintenance manual which is part of the UL listing.

2014-SEP-01 REV. 11 PAGE 1-3

DEFINITION OF TERMS (Continued)

Pulley Elbow: A device used to change the direction of the wire rope which runs between: the regulated release mechanism and the detectors, the regulated release mechanism and the mechanical gas valve, and/or the regulated release mechanism and the remote manual pull station.

Pulley Tee: A device used to change the direction of two wire ropes which run from a regulated release or a regulated actuator to two remote manual pull stations, or from two regulated releases or regulated actuators to a single mechanical gas valve or from one regulated release or regulated actuator to two gas valves.

Regulated Actuator Assembly: An assembly which contains the regulator, pneumatic actuator, agent tank, and expellant gas hose within a metal enclosure. This assembly is used to pressurize additional agent tanks in a multiple tank system.

Regulated Release Mechanism: An enclosed device within the AUTOMAN regulated release assembly which releases the expellant gas, activates alarms, and/or shuts off other devices when signaled automatically by a detector or manually with a remote pull station.

Regulator: A device used to regulate the pressure from the nitrogen cartridge into the agent tank(s) when the system is actuated.

Remote Manual Pull Station: A device which provides manual actuation of the system from a remote location.

Remote Mechanical Release: A device that provides actuation gas, activates alarms, and/or shuts off other devices when signaled automatically by a detector, or manually with a remote pull station.

Salamander Broiler: A broiler very similar in design to the upright broiler. A salamander broiler is used for general broiling of meats and fish, toasting, and holding/warming foods. Most contain a removable grease drip tray.

Series Detector: Any detector located in-line between the regulated release assembly and the terminal detector.

Silicone Lubricant: A heat-resistant organic compound used to lubricate O-rings, rubber and mechanical components.

Supply Line: The agent distribution piping which extends from the agent tank outlet and serves as a manifold for the branch lines.

Terminal Detector: The last in a series of detectors, or the only detector used in a single-detector system. This detector is thus named because it is at the point at which the wire rope ends, or "terminates." There is only one terminal detector per detection system.

Transition: An extension of the hood or canopy which allows for the smooth transmission of gases, air, and vapors between the hood opening and the base of the ventilation duct.

Vent Plug: A device used to prevent pressure build-up within the agent tank or agent distribution lines due to temperature fluctuations.

R-102 Restaurant Fire Suppression Manual

SECTION 1 – GENERAL INFORMATION

UL EX3470 ULC EX3470

PAGE 1-4 REV. 11 2014-SEP-01

NOTES:

UL EX3470 **ULC EX3470**

2014-SEP-01 **REV. 11** PAGE 2-1

TOTAL SYSTEM

There are four types of R-102 Restaurant Fire Suppression Systems:

- 1. Single-tank System
- 2. Double-tank System
- 3. Three-tank System (1 Cartridge)
- 4. Multiple Tank System (Three Tanks or More Multiple Cartridges)

The type of system required for the particular installation will be determined through the guidelines covered in "System Design." Additional equipment which may be required to complete the system design is explained in the "System Components" section. Additional devices covered are: remote manual pull stations, mechanical and electrical gas shut-off valves, electrical switches, and pressure switches.

Single-Tank System

The R-102 single-tank system is available with a stainless steel enclosure and consists of:

- 1. AUTOMAN Regulated Release Assembly (Electrical or Mechanical)
- 2. Nitrogen Cartridge and/or Carbon Dioxide Cartridge
- 3. ANSULEX Low pH Liquid Fire Suppressant
- 4. Discharge Nozzles
- 5. Detection Components
- 6. Additional Devices (As Required)

The regulated release assembly contains the regulated release mechanism, agent tank, expellant gas hose for agent tank hookup, and enclosure knockouts to facilitate installing detection system and additional equipment. Refer to "System Components" section for individual component descriptions.




FIGURE 2-1


Double-Tank System

The R-102 double-tank system is available with stainless steel enclosures and consists of:

- 1. AUTOMAN Regulated Release Assembly (Electrical or Mechanical)
- Nitrogen Cartridge and/or Carbon Dioxide Cartridge
- ANSULEX Low pH Liquid Fire Suppressant
- 4. Enclosure or Bracket Assembly
- 5. Discharge Nozzles
- 6. Detection Components
- 7. Additional Devices (As Required)

The regulated release assembly contains the regulated release mechanism, agent tank, expellant gas hose for agent tank hookup, and enclosure knockouts to facilitate installing expellant piping, detection system, and additional equipment.

The enclosure or bracket assembly is mounted separately but within the guidelines of the regulated release assembly expellant gas piping requirements to ensure simultaneous actuation of the system. Refer to "System Components" section for individual component descriptions.



PAGE 2-2 REV. 11 2014-SEP-01

TOTAL SYSTEM (Continued)

Three-Tank System (1 Cartridge with Three 3.0 Gal Tanks ONLY)

The R-102 three-tank system is available with stainless steel enclosures and consists of:

- AUTOMAN Regulated Release Assembly (Electrical or Mechanical)
- 2. Double Tank Enclosure Assembly
- 3. Nitrogen Cartridge
- 4. ANSULEX Low pH Liquid Fire Suppressant
- 5. Discharge Nozzles
- 6. Detection Components
- 7. Additional Devices (As Required)

The regulated release assembly contains the regulated release mechanism, agent tank, expellant gas hose for agent tank hookup, and enclosure knockouts to facilitate installing expellant piping, detection system, and additional equipment.

The double tank enclosure assembly is mounted separately but within the guidelines of the regulated release assembly expellant gas piping requirements to ensure simultaneous actuation of the system. Refer to "System Components" section for individual component descriptions.




FIGURE 2-3

Multiple Tank System (Three Tanks or More – Multiple Cartridges)

The R-102 multiple-tank system is available with stainless steel enclosures and consists of:


- AUTOMAN Regulated Release Assembly (Electrical or Mechanical) or AUTOMAN Remote Release Assembly(ies)
- 2. Nitrogen Cartridge(s) and/or Carbon Dioxide Cartridge(s)
- 3. Regulated Actuator Assembly(ies)
- 4. ANSULEX Low pH Liquid Fire Suppressant
- 5. Enclosure or Bracket Assembly(ies)
- 6. Discharge Nozzles
- 7. Detection Components
- 8. Additional Devices (As Required)

The regulated release assembly contains the regulated release mechanism, agent tank, expellant gas hose for agent tank hookup, and enclosure knockouts to facilitate installing actuation piping, expellant piping, detection system, and additional equipment.

The remote release assembly(ies) is used in large systems or multi-hood systems to actuate regulated actuator assembly(ies) ONLY. The remote release assembly contains a release mechanism (unregulated), with enclosure knockouts to facilitate installing the actuation piping, expellant piping, detection system, and additional equipment.

Each regulated actuator assembly is mounted separately but within the guidelines of the regulated release assembly actuation/expellant gas piping requirements to ensure simultaneous actuation of the system. The assembly contains the pneumatic actuator, regulator, agent tank, expellant gas hose for agent tank hookup, and enclosure plugs to facilitate installing expellant piping.

Each enclosure or bracket assembly is mounted separately but within the guidelines of the regulated release assembly or regulated actuator assembly expellant gas piping requirements to ensure simultaneous actuation of the system. Refer to "System Components" section for individual component descriptions.



UL EX3470 ULC EX3470 2014-SEP-01 **REV. 11** PAGE 3-1

EXTINGUISHING AGENT

ANSULEX Low pH Liquid Fire Suppressant (1.5 gallon - Part No. 79694 or 3.0 gallon - Part No. 79372) is a potassium-based solution designed for fast knock-down and suppression of grease-related fires. The agent is shipped in plastic containers which provide one complete tank charge. (Refer to Section V. Page 5-2.1, for maximum agent fill capacity.) Agent storage life expectancy is twelve years and can be stored at a temperature of -40 °F to 130 °F (-40 °C to 54 °C). Note: When installing agent in R-102 system, temperature range is 32 °F (0 °C) to 130 °F (54 °C). The distributor must record the batch numbers and date of shipment receipt to be filed with each installation record.

"ANSULEX" LOW pH LIQUID FIRE SUPPRESSANT







1.5 GALLON SHIPPING WT. 19 LB (8.6 kg)

FIGURE 3-1

REGULATED RELEASE ASSEMBLY (MECHANICAL)

The AUTOMAN Regulated Mechanical Release Assembly (Part No. 429853) contains the regulated release mechanism, expellant gas hose for agent tank hookup, and enclosure knockouts to facilitate installing actuation piping; expellant piping; detection system; and additional equipment. This regulated release assembly is used in single, double, and multiple-tank systems and must be mounted to a rigid surface. The release mechanism can be used to interconnect both the actuation and expellant gas lines as required per system design. The regulator is designed to allow a constant flow of gas into the tank at 110 psi (7.6 bar) when the system is actuated. The agent tank must be ordered separately.

In single, double, and multiple-tank systems, the provided expellant gas hose connects the agent tank to the bottom outlet of the regulator. In double and multiple-tank system configurations, the back outlet of the regulator is used as an expellant gas feed for one additional tank-enclosure or tank-bracket hookup. The enclosure contains the required knockouts to facilitate this connection. If a pressure switch is to be attached to the regulator, additional fittings are required.

The tank is mounted within the enclosure. The tank contains an adaptor/tube assembly with a burst disc union. The burst disc helps prevent siphoning of the agent up the pipe due to significant temperature fluctuations in the area where the tank is located. The tank is stainless steel and, under normal conditions, requires hydrostatic testing every twelve years.

The detection and additional equipment required per system design are connected to the release mechanism. The enclosure contains knockouts to facilitate detection and additional hookups.

The system can be actuated automatically or manually.

Automatic actuation occurs when a fusible link within the detection system separates in a fire condition. Manual actuation of the system occurs when personnel pull on the remote manual pull station pull ring.

AUTOMAN REGULATED RELEASE ASSEMBLY (MECHANICAL)





FIGURE 3-2

REGULATED RELEASE ASSEMBLY (ELECTRICAL)

The AUTOMAN Regulated Electrical Release Assembly (Part No. 429856) is identical to the mechanical version except it also contains a factory installed 120 VAC solenoid and electrical switch.

The solenoid is used to provide electrical actuation of the release mechanism. The electric switch is used to protect the solenoid by opening the circuit to the solenoid once the system is fired. Additional electrical switches can be added as required for automatic equipment and gas shut-off accessories, as well as initiating audible and visual alarms.

AUTOMAN REGULATED RELEASE ASSEMBLY (ELECTRICAL)*



▶ * Note: AUTOMAN Regulated Electrical Release (Part No. 429856) is not intended to be used with electric detection.

SECTION 3 – SYSTEM COMPONENTS

UL EX3470 ULC EX3470

PAGE 3-2 REV. 11 2014-SEP-01

REMOTE MECHANICAL RELEASE

The Remote Mechanical Release (Part No. 433485) is used to actuate up to five R-102 regulated actuators. The remote mechanical release utilizes a 101-10 carbon dioxide cartridge as the actuation pressure to operate the regulated actuators. The release is housed in a stainless steel enclosure.

Also available is an OEM Remote Release/Bracket Assembly (Part No. 439946). The OEM Remote Release/Bracket contains the same release mechanism as the standard Remote Release, and must be installed in a suitable equipment enclosure either horizontally or vertically. The remote release contains all the necessary mounting and conduit holes needed to fully install the assembly. **Note:** OEM Release/Bracket Assembly must be installed high enough in cabinet so that there is sufficient room to install and remove cartridge.





FIGURE 3-4

SINGLE TANK ENCLOSURE ASSEMBLY

The Single Tank Enclosure Assembly (Part No. 429870) is used in double and multiple-tank systems and must be mounted to a rigid surface near the regulated release or regulated actuator assembly its expellent gas line will be connected to.

The enclosure is designed for mounting either a 1.5 gallon (Part No. 429864) or a 3.0 gallon tank (Part No. 429862) in a minimum amount of space.

ENCLOSURE ASSEMBLY




RED PAINTED BRACKET ASSEMBLY

The Bracket Assembly (Part No. 429878) is used in double and multiple-tank systems and must be mounted to a rigid surface near the regulated release assembly or regulated actuator assembly that its expellant gas line will be connected to.

The tank bracket is constructed of mild steel and painted red. It is designed for mounting the tank in a minimum amount of space. The Bracket Assembly can only be utilized with 3.0 gallon tanks (Part No. 429862).

BRACKET ASSEMBLY



UL EX3470 ULC EX3470

2014-SEP-01 REV. 11 PAGE 3-3

REGULATED ACTUATOR ASSEMBLY


The Regulated Actuator Assembly (Part No. 429850) contains the regulator, pneumatic actuator, expellant gas hose for agent tank hookup, and enclosure knockouts to facilitate installing expellant piping. This assembly is used in multiple-tank systems and must be mounted to a rigid surface.

The regulator contains two outlets 135° apart. One outlet is used to interconnect the expellant gas hose to the enclosed agent tank. The other outlet connects an expellant gas line to an additional enclosure or bracket assembly. The regulator is

- ▶ designed to allow a constant flow of expellant gas into each
- ▶ agent tank at 110 psi (7.6 bar).

The pneumatic actuator is designed to puncture the expellant gas cartridge seal upon receiving pressure from the regulated release assembly actuation piping. The enclosure contains a knockout to facilitate distribution piping hookup.


REGULATED ACTUATOR ASSEMBLY



AGENT TANK ASSEMBLY

The agent tank shipping assembly (3 Gallon (Part No. 429862) and 1.5 Gallon (Part No. 429864)) consists of a stainless steel tank and an adaptor/tube assembly. The adaptor/tube assembly contains a burst disc. The burst disc prevents agent leakage due to significant temperature fluctuations in the area where the tank is located. Under normal conditions, the tank requires hydrostatic testing every twelve years. The date of manufacture is stamped on the tank nameplate.


The tank is shipped uncharged and must be filled with only ANSULEX Low pH Liquid Fire Suppressant during installation.



OEM RELEASE/BRACKET ASSEMBLY (FOR OEM IN-CABINET USE ONLY)

The OEM Regulated Mechanical Release/Bracket Assembly (Part No. 79493) contains the same regulated release mechanism as the standard AUTOMAN Regulated Release Assembly. The OEM Regulated Electrical Release/Bracket Assembly (Part

- No. 437324*), is identical to the mechanical version except that it contains a factory installed 120 VAC solenoid and electrical switch. These release/bracket assemblies must be installed in a suitable equipment enclosure either horizontally or vertically. They contain all the necessary mounting and conduit holes needed to fully install the assembly. The agent tank is installed separately and need not be bracketed once it is piped and filled. Note: OEM Release/Bracket Assembly must be installed high enough in cabinet so that there is sufficient room to install and remove cartridge.
- ➤ *Note: OEM Regulated Electrical Release/Bracket Assembly (Part No. 437324) is not intended to be used with electric detection.



OEM REGULATED ACTUATOR ASSEMBLY

The OEM Regulated Actuator Assembly (Part No. 418691) includes the regulator, pneumatic actuator, expellant gas hose and OEM bracket. Also available is an OEM Regulated Actuator Assembly with all the above mentioned components except for the bracket. This assembly is Part No. 418522.




FIGURE 3-10

SECTION 3 – SYSTEM COMPONENTS

UL EX3470 ULC EX3470

PAGE 3-4 REV. 11 2014-SEP-01

TWO TANK ENCLOSURE ASSEMBLY

The Two Tank Enclosure Assembly (Part No. 429872) consists of two expellant gas hoses, two grommets, and the mounting enclosure. The assembly is used in 9-gallon systems. It can be coupled with a 3-gallon regulated release assembly or a 3-gal-

▶ lon regulated actuator assembly to give a total of 9 gal (34.1 L) of agent. Agent tanks must be ordered separately.

The tank enclosure is designed to mount in a minimum amount of space.





FIGURE 3-11

► 24VDC REGULATED RELEASE ASSEMBLY

The 24VDC Regulated Release Assembly (Part No. 429859) is used where electric, thermostat detection is required via the use of a releasing control unit. This assembly consists of a 24VDC AUTOMAN II-C regulated release mechanism, expellant gas hose, and enclosure knockouts to facilitate installing actuation piping, expellant piping, detection system, and additional equipment. Agent tank must be ordered separately.

The system can be actuated automatically or manually. Automatic actuation occurs when the control panel receives a signal from the detection circuit. The panel then sends an electrical signal to the 24VDC regulated release, causing it to actuate. When actuation occurs, the gas cartridge is punctured, pressurizing the agent tank and discharging the agent through the distribution piping. Manual actuation of the system occurs when personnel pull on the remote manual pull station pull ring.



NOTE: AGENT TANK MUST BE ORDERED SEPARATELY (SEE PAGE 3-3)

SHIPPING WT. 34 LB (15.4 kg)

ADDITIONAL SHIPPING ASSEMBLIES

Several complete shipping assemblies are available containing both the release or actuator mechanism and the agent tank. When ordering a complete shipping assembly, order the following part numbers:

9 5				
Part No.	Description	on	Shippin lb	g Wt. <u>(kg)</u>
430299		n Mechanical Release Assembly including: Mechanical Regulated Release Assembly 3.0 Gallon Tank Assembly	33	(15)
430300		n Mechanical Release Assembly including: Mechanical Regulated Release Assembly 1.5 Gallon Tank Assembly	30	(14)
430309	Shipping 429850	n Regulated Actuator Assembly including: Regulated Actuator Assembly 3.0 Gallon Tank Assembly	36	(16)
430316		Assembly 1.5 Gallon Tank Assembly	18	(8)
430317	Shipping 429870 429862	n Stainless Steel Enclosure Assembly including: Single Tank Mounting Box Assembly 3.0 Gallon Tank Assembly Hose Assembly	20	(9)
430324	Shipping 429872	n Stainless Steel Enclosure Assembly including: Two Tank Mounting Box Assembly	40	(18)
	429862	3.0 Gallon Tank Assembly (2)		
430332		n Mounting Bracket Shipping / including: 3.0 Gallon Mounting Bracket Assembly	20	(9)
	429862	,		

UL EX3470 ULC EX3470

2014-SEP-01 REV. 11 PAGE 3-5

GAS CARTRIDGES


The R-102 system uses gas cartridges to store nitrogen or carbon dioxide expellant gases under pressure until the system is actuated, at which time the cartridge seal is punctured and the released gas expels liquid agent from one or more tanks through the discharge piping and out the discharge nozzles.

Four nitrogen gas cartridges and three carbon dioxide gas cartridges are available as shown in Figure 13.

Cartridges noted as TC/DOT are both Transport Canada (TC) and Department of Transportation (DOT) approved. Cartridges noted as DOT are Department of Transportation approved only.

Cartridge selection options are provided in Section 4 under Tank and Cartridge Requirements.

NITROGEN GAS CARTRIDGES



CARBON DIOXIDE CARTRIDGES




FIGURE 3-13

Additional cartridge shipping assemblies are available for European and Australian requirements.

Cartridge Description	European Part No.	Australian Part No.	TC/DOT Part No.
LT-20-R	428440	428948	423429
LT-30-R	428441	426553	423435
Double Tank	428446	426563	423493
LT-A-101-30	428442	426555	423491
101-10 - CO2	428443	N/A	423439
101-20 - CO2	428445	N/A	423441
101-30 - CO2	428444	N/A	423443

Note: For 101-10 cartridge, Part No. 15850 is DOT only.

NOZZLES

There are 11 types of discharge nozzles each designed to distribute the liquid agent in a uniform pattern throughout the hazard area:

1.	1/2N Nozzle	7.	245 Nozzle
2.	1F Nozzle	8.	260 Nozzle
3.	1W Nozzle	9.	290 Nozzle
4.	1N Nozzle	10.	2120 Nozzle
5.	2W Nozzle	11.	3N Nozzle

6. 230 Nozzle

Although these nozzles are similar in appearance and have certain common parts, the tip of each nozzle is designed for a specific application and must only be used in those areas. See Nozzle Application Chart in Section 4 – System Design, for

- ► individual nozzle usage. Nozzles are shipped with metal blow-► off caps included.
- ► A 25 pack of Nozzle O-rings (Part No. 439848) is also available.




FIGURE 3-14

Nozzle Identification Chart

i	•			Nozzle)
	Nozzle	Nozzle	Package	Flow	
	Type	Part No.	Quantity	No.	Nozzle Material
	1/2N Nozzle	439837	9	1/2	Chrome-Plated Body
	1F Nozzle	439836	9	1	Chrome-Plated Body
	1W Nozzle*	439839	25	1	Chrome-Plated Body
	1N Nozzle*	439838	25	1	Chrome-Plated Body
	2W Nozzle	439840	25	2	Chrome-Plated Body
	230 Nozzle	439842	25	2	Chrome-Plated Body
	245 Nozzle	439843	25	2	Chrome-Plated Body
	260 Nozzle	439844	9	2	Chrome-Plated Body
	290 Nozzle	439845	9	2	Chrome-Plated Body
	2120 Nozzle	439846	9	2	Chrome-Plated Body
	3N Nozzle	439841	9	3	Chrome-Plated Body
- 1	***************************************	!		4141	I= (D==t NI= 4000004) ====1

*Stainless steel versions are available in the 1W nozzle (Part No. 439864) and the 1N nozzle (Part No. 439865).

SILICONE LUBRICANT

Dow Corning Compound 111 (Part No. 78112) is available in a 5.3-ounce tube. Compound has excellent qualities for sealing and lubricating system components.

SECTION 3 – SYSTEM COMPONENTS

UL EX3470 ULC EX3470

PAGE 3-6 REV. 11 2014-SEP-01

SWIVEL ADAPTOR

The Swivel Adaptor Assembly consists of a swivel nut, swivel body and swivel ball. All are chrome-plated. The swivel adaptor allows any nozzle to be rotated approximately 30° in all directions. Swivel Adaptors must be ordered as a Swivel Adaptor Shipping Assembly (Part No. 423572) which contains 25 Swivel Adaptors or Part No. 419385, which contains 9 Swivel Adaptors.





FIGURE 3-15

METAL BLOW-OFF CAP

The Metal Blow-Off Cap helps keep the orifice of the nozzle free of grease or other substances that could interfere with agent distribution.

- The Metal Blow-Off Cap Package (Part No. 439861) contains 10 blow-off caps.
- Also available is a 10 pack of Stainless Steel Blow-Off Caps (Part No. 439866).



REDUCING COUPLING

The reducing coupling (Part No. 436228) is made of stainless steel material with 3/8 in. x 1/2 in. NPT inlet threads. If necessary, the reducing coupling can be utilized when installing the Agent Distribution Hose Line Kit (Part No. 435982). Two couplings are required per Agent Distribution Hose.




FIGURE 3-17

CONDUIT OFFSET ASSEMBLY

The conduit offset assembly (Part No. 435961) is used to change direction of the wire rope on detection, mechanical gas valve, and remote pull station lines. The conduit offset assembly can only be used in the area where the conduit attaches to the regulated release assembly. When using the conduit offset assembly, the maximum number of pulley elbows allowed is

▶ 16. The Conduit Offset Shipping Assembly (Part No. 436063) consists of 6 conduit offsets.




FIGURE 3-18

"QUIK-SEAL" ADAPTOR

The "Quik-Seal" adaptor is a listed mechanical bulkhead fitting that produces a liquid-tight seal around both distribution piping and detection conduit which runs through restaurant hoods and ducts. The "Quik-Seal" adaptor accepts threaded pipe or conduit. The adaptor is available for 1/4 in. (Part No. 78196), 3/8 in. (Part No. 77285), 1/2 in. (Part No. 77287), or 3/4 in. (Part No. 77289) pipe or conduit sizes. When using with EMT conduit, a conduit connector must be installed in each end of the adaptor. The "Quik-Seal" Adaptor Shipping Assembly must be ordered as stated below:

Size	Assembly Part No.	Qty.	Hole Size Required
1/4 in.	78196	24	3/4 in.
3/8 in.	77285	24	1 1/8 in.
1/2 in.	77287	24	1 1/8 in.
3/4 in.	77289	24	1 3/8 in.
3/4 In.	77289	24	1 3/8 In.

Chinning





FIGURE 3-19

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 3-7

"COMPRESSION-SEAL" ADAPTOR


This adaptor is a mechanical bulkhead fitting that produces a liquid-tight seal around pipe and conduit when installing distribution piping and detection conduit through restaurant hoods and ducts. The "Compression-Seal" adaptor is a straight-through design requiring no cutting or threading of conduit or pipe. The adaptor is available for pipe sizes of 1/4 in. (Part No. 79149), 3/8 in. (Part No. 79151), 1/2 in. (Part No. 79147), and EMT conduit size of 1/2 in. (Part No. 79153). Each "Compression-Seal" Adaptor Shipping Assembly must be ordered as stated below:

	Shipping Assembly		Hole Size
Size	Part No.	Qty.	Required
1/4 in. Pipe / 1/2 in. tube	79149	24	3/4 in.
3/8 in. Pipe / 5/8 in. tube	79151	24	1 1/8 in.
1/2 in. Pipe	79147	24	1 1/8 in.
1/2 in. EMT Conduit	79153	24	1 1/8 in.



"HOOD SEAL" ADAPTOR ASSEMBLY


This adaptor is a mechanical bulkhead fitting that produces a liquid-tight seal around 1/2 in. EMT conduit when installing the detection line through restaurant hoods and duct. The adaptor accepts a high temperature pulley elbow and, when used, correctly positions the elbow or conduit in line with the conduit adaptor hole in the detector bracket. The "Hood Seal" eliminates the need for multiple elbows when penetrating the top of a hood when installing the detection line. "Hood Seal" Adaptors are available in quantities of six as Shipping Assembly Part No. 423253.




► COCKING LEVER/LOCK PIN

The cocking lever is a component required to cock (arm) both the mechanical/electrical AUTOMAN release and the mechanical gas valve. After the AUTOMAN is cocked (armed), the lock pin must be inserted to eliminate the accidental firing of the release mechanism. These components are available as either an individual shipping assembly or a shipping assembly containing both. Listed below are the various shipping assembly part numbers.

Part No.	Description
441042	Short Handle Cocking Lever with Lock Pin (Mechanical/Electrical AUTOMAN)
441041	Long Handle Cocking Lever with Lock Pin (Mechanical/Electrical AUTOMAN)
▶26310	Cocking Lever only (AUTOMAN II-C)
416018	Cocking Lever only (Mechanical Gas Valve)
▶438031	Lock Pin



Long Handle Cocking Lever



SECTION 3 – SYSTEM COMPONENTS

UL EX3470 ULC EX3470

PAGE 3-8 REV. 11 2014-SEP-01

DETECTORS

The detector consists of three basic components: the bracket, linkage, and fusible link. (Fusible links are not included and must be ordered separately.) The bracket holds the entire assembly to the mounting surface. The linkage is used to support the fusible link. The fusible link is designed to separate at a specific temperature and release the wire rope, thereby actuating the regulated release mechanism.

The scissor style detector allows the wire rope to be strung completely through the detection system conduit and brackets first and the detector linkage assemblies are then clipped on later.

The detector consists of two types of assemblies:

The Terminal Detector (Part No. 435546) includes a test link and is placed last in a series of detectors. This detector is sometimes referred to as the end-of-line detector and is thus named because it is at the point at which the wire rope "terminates," or is anchored at the detector bracket. Only one terminal detector is required per detection system.

The Series Detector (Part No. 435547) is any detector located in-line between the regulated release assembly and the terminal detector.

When using Part No. 435546 and 435547 detectors, a total of 15 detectors can be in one detection system: 14 series detectors (Part No. 435547) and 1 terminal detector (Part No. 435546).

Note 1: Series Detector (Part No. 435547) is also available as Part No. 435548, 25/Pkg.

- ▶ Note 2: Scissor-style linkage is also available in a 10-Pack (Part
- ► No. 439515).




FIGURE 3-23

PULLEY ELBOWS

There are two types of pulley elbows used to change the direction of the wire rope by 90°. ANSUL recommends for temperatures not in excess of 700 °F (371 °C). Part No. 415670 has socket ends with set screws for 1/2 in. conduit, and Part No. 423250 has compression ring ends also for 1/2 in. conduit. Pulley elbows must be ordered in quantities of 50 as Shipping Assembly Part No. 415671 (socket end type) and Part No. 423251 (compression end type).

PART NO. 415670





FIGURE 3-24

PULLEY TEE

The Pulley Tee (Part No. 427929) is used to change the direction of two wire ropes by 90°. It must be used in areas where the temperatures are within the range of 32 °F to 130 °F (0 °C to 54 °C). Pulley tees can be used in mechanical gas valve actuation lines and remote manual pull station lines. Pulley tees cannot be used within a detection line.



FIGURE 3-25

ANSUL STAINLESS STEEL CABLE

The 1/16 in. stainless steel cable is run from the terminal detector, through conduit, all series detectors and pulley elbows, and into the regulated release mechanism trip lever. When any fusible link separates, the tension on the cable is relaxed, and the trip lever actuates the regulated release mechanism. The cable can also be used for mechanical gas valves and remote

- manual pull stations. The cable is available in 50 ft (15.2 m) (Part No. 15821) and 500 ft (152.4 m) (Part No. 79653) lengths.
- ▶ The ANSUL stainless steel cable contains a blue tracer cable.

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 3-9

Maximum

REMOTE MANUAL PULL STATION

The remote manual pull station (Part No. 434618 or 435960) is made out of a molded red composite material. The red color makes the pull station more readily identifiable as the manual means for fire suppression system operation. The pull station is compatible with the ANSUL Flexible Conduit. The molded manual pull station should be mounted at a point of egress and positioned at a height determined by the authority having jurisdiction. Trim Rings (Part No. 427074) (pack of 10), are available.

Part No. 434618 (Without Wire Rope) Part No. 435960 (With 50 ft (15.2 m) of Wire Rope)



FIGURE 3-26

FLEXIBLE CONDUIT

Flexible conduit allows for quicker installations and the convenience of being able to route the cable over, under and around obstacles. Flexible conduit can be used as a substitute for standard EMT conduit or can be used with EMT conduit. Flexible conduit can be used only with the Molded Manual Pull Station (Part No. 434618) and mechanical gas valve installations. The Flexible Conduit comes in a 500 ft (152.4 m) length (Part No. 434525) or together with 500 ft (152.4 m) of wire rope (Part No. 435959).

- ► A 50 ft (15.2 m) Flexible Conduit pre-fed with wire rope (Part
- ► No. 439104) is available.

Also available is a Flexible Conduit Strain Relief (50-pack) (Part No. 435979).

- ▶ A 50-pack of Flexible Conduit Inserts (Part No. 434347) and a
- ► 50-pack of P-Clips (Part No. 436150) are also available.
- ▶ Note 1: Flexible conduit is intended for indoor use ONLY.
- Note 2: Flexible conduit cannot be used in detection systems.

MECHANICAL GAS VALVES

The mechanical gas valves are designed to shut off the flow of gas to the appliances upon actuation of the regulated release assembly. The valves are available in sizes of 3/4 in., 1 in., 1 1/4 in., 1 1/2 in., and 2 in. ANSUL style; and 2 1/2 in. and 3 in. ASCO style. The valves are rated for natural and LP gas. Both styles are UL Listed and includes the air cylinder, tubing, and fittings (Part No. 15733) for connection to the release mechanism.

		Maximum
Part		Operating
No.	Description	Pressure
55598	3/4 in. Gas Valve (ANSUL)	10 psi (0.69 bar)
55601	1 in. Gas Valve (ANSUL)	10 psi (0.69 bar)
55604	1 1/4 in. Gas Valve (ANSUL)	10 psi (0.69 bar)
55607	1 1/2 in. Gas Valve (ANSUL)	10 psi (0.69 bar)
55610	2 in. Gas Valve (ANSUL)	10 psi (0.69 bar)
25937	2 1/2 in. Gas Valve (ASCO)	5 psi (0.35 bar)
25938	3 in. Gas Valve (ASCO)	5 psi (0.35 bar)

	Flow Capacity (CFH)	BTU/HR, at 1 in. P.D. 0.64 SP GR
Pipe Size	P.D. 1 in. WC	1000 BTU/ft ³
(inches)	0.64 SP GR	Natural Gas
3/4	751	751,000
1	1288	1,288,000
1 1/4	1718	1,718,000
1 1/2	2630	2,630,000
2	4616	4,616,000
2 1/2	5700	5,800,000
3	7100	7,300,000

To calculate gas flow for other than 1 inch p.d.:


New cfh = (cfh at 1 inch) x $\sqrt{\text{new p.d.}}$

To calculate gas flow for other than 0.64 SP GR:

New cfh = (cfh at 0.64) x
$$\sqrt{0.64}$$

New SP GR

	Α			В	С	
Valve Size	in.	(mm)	in.	(mm)	in.	(mm)
3/4 in.	3 3/4	(95.3)	6 3/8	(161.9)	5 1/2	(139.7)
1 in.	3 3/4	(95.3)	6 3/8	(161.9)	5 1/2	(139.7)
1 1/4 in.	4 7/8	(123.8)	7 3/8	(187.3)	6 3/8	(161.9)
1 1/2 in.	4 7/8	(123.8)	7 3/8	(187.3)	6 3/8	(161.9)
2 in.	5 7/8	(149.2)	7 7/8	(200.0)	6 11/16	(169.9)
2 1/2 in.	7 13/16	(198.4)			9 1/16	(230.2)
3 in.	7 25/32	(197.6)			9 1/16	(230.2)



C A A 2 1/2 IN. THRU 3 IN.

FIGURE 3-27

SECTION 3 – SYSTEM COMPONENTS

UL EX3470 ULC EX3470

PAGE 3-10 REV. 11 2014-SEP-01

ELECTRICAL GAS VALVES

The electrical gas valves are designed to shut off the flow of either natural or LP gas to the appliances upon actuation of the regulated release assembly. The valves are available in sizes of 3/4 in., 1 in., 1 1/4 in., 1 1/2 in., 2 in., 2 1/2 in., and 3 in. The valve is held open by an energized solenoid and upon system actuation, the switch contacts in the regulated release assembly open, thus de-energizing the circuit to the gas valve solenoid, causing the valve to close. Valves are available in 120 VAC and are UL Listed.

	Part No.	Description	Max. Operating Pressure
	13707	3/4 in. Solenoid Gas Valve (ASCO)	25 psi (1.7 bar)
	13708	1 in. Solenoid Gas Valve (ASCO)	25 psi (1.7 bar)
	550360	1 1/4 in. Solenoid Gas Valve (ASCO)	25 psi (1.7 bar)
	13709	1 1/2 in. Solenoid Gas Valve (ASCO)	25 psi (1.7 bar)
	13710	2 in. Solenoid Gas Valve (ASCO)	25 psi (1.7 bar)
•	550363	2 1/2 in. Solenoid Gas Valve (ASCO)	5 psi (0.3 bar)
•	17643	3 in. Solenoid Gas Valve (ASCO)	5 psi (0.3 bar)

	Flow Capacity	BTU/HR, at 1 in. P.D.
	(CFH)	0.64 SP GR
Pipe Size	P.D. 1 in. WC	1000 BTU/ft ³
(inches)	0.64 SP GR	Natural Gas
3/4	264.96	247,500
1	1091.01	1,119,000
1 1/4	1662.49	1,730,000
1 1/2	1818.35	1,900,000
2	3117.18	3,251,000
2 1/2	6078.49	5,821,000
3	7169.51	7,430,000

To calculate gas flow for other than 1 inch p.d.:


New cfh = (cfh at 1 inch) $x \sqrt{\text{new p.d.}}$

To calculate gas flow for other than 0.64 SP GR:

New cfh = (cfh at 0.64) x
$$\sqrt{0.64}$$

New SP GR

Va	alve	Α		В	
Si	ze	in.	(mm)	in.	(mm)
▶ 3/	4 in.	3 5/16	(81)	3 5/8	(92)
1	in.	5	(127)	6 27/32	(174)
1	1/4 in.	7 13/16	(198)	7 29/32	(201)
1	1/2 in.	5	(127)	5 19/32	(142)
2	in.	6 3/32	(155)	5 15/16	(151)
2	1/2 in.	7 13/16	(198)	7 29/32	(201)
-3	in.	7 13/16	(198)	7 29/32	(201)



MANUAL RESET RELAY

The Manual Reset Relay (Part No. 426151) is required when using an electrical gas valve shut-off system. After the electric gas valve has closed, either due to system actuation or power failure, the valve cannot be re-opened, allowing gas to flow, until the reset relay button is manually pressed, re-energizing the circuit. The reset relay is available 120 VAC. The manual reset relay is also recommended for electrical shut down.



FIGURE 3-29

ELECTRICAL SWITCHES

The electrical switches are intended for use with electric gas valves, alarms, contactors, lights, contractor supplied electric power shut-off devices and other electrical devices that are designed to shut off or turn on when the system is actuated.

Switches are available in kits: One Switch Kit (Part No. 423878), Two Switch Kit (Part No. 423879), Three Switch Kit (Part No. 423880), and Four Switch Kit (Part No. 423881). Mounting hardware and 24 in. (610 mm) long wire leads are provided with each kit. A Two-Switch Assembly without wire leads (Part No. ▶ 436770) is also available. Each switch has a set of single-pole, double-throw contacts rated at:

UL/cUL/CSA Rating
250 VAC, 21A Resistive
250 VAC, 2 HP
125 VAC. 1 HP

ENEC Rating IE4T105μ Approved 250V, 21A Resistive 8A Motor Load





FIGURE 3-30

UL EX3470 ULC EX3470 2014-SEP-01 **REV. 11 PAGE 3-11**

ALARM INITIATING SWITCH

The Alarm Initiating Switch Kit (Part No. 428311) can be field mounted within the AUTOMAN release. This switch must be used to close a supervised alarm circuit to the building main fire alarm panel when the AUTOMAN release actuates. This action will signal the fire alarm panel that there was a system actuation in the kitchen area. The switch kit contains all necessary mounting components along with a mounting instruction sheet. The switch is rated 50 mA, 28 VDC.



REGULATOR TEST KIT

The Test Kit Assembly (Shipping Part No. 56972) is required to test the regulator setting and nitrogen flow during 12-year maintenance examinations. This will ensure that the regulator is functioning properly.




FIGURE 3-32

VENT PLUG ASSEMBLY

The Vent Plug Assembly (Part No. 74274) is installed on the agent tank adaptor to prevent pressure buildup within the agent tank or distribution lines due to temperature fluctuations.

CARTRIDGE RECEIVER GASKET

The Cartridge Receiver Gasket (Part No. 181) is installed in the release and actuator assembly cartridge receiver to create a seal between the cartridge receiver assembly and the cartridge.

FUSIBLE LINK

Select correct UL Listed fusible link(s) for installation in detector(s) according to the temperature condition chart below:

SL STYLE			
Fusible Link Shipping		To Be Used Where Temperature	Color
Assembly	Temperature	Does Not	of
Part No.	Rating	Exceed	Link
439085 (25)	165 °F	100 °F (74 °C)	Black (38 °C)
439086 (25)	212 °F	150 °F (100 °C)	White (66 °C)
439087 (25)	280 °F	225 °F (138 °C)	Blue (107 °C)
439088 (25)	360 °F	290 °F (182 °C)	Red (143 °C)
439089 (25)	450 °F	360 °F (232 °C)	Green (182 °C)

► A-PC STYLE Fusible Link To Be Used Shipping Where Assembly Temperature Temperature Rating Does Not Exceed Part No. 165 °F (74 °C) 100 °F (38 °C) 439227 (10) 212 °F (100 °C) 150 °F (66 °C) 439228 (10) 439229 (10) 280 °F (138 °C) 225 °F (107 °C) 290 °F (143 °C) 360 °F (182 °C) 439230 (10)

450 °F (232 °C)


500 °F (260 °C)



439231 (10)


439232 (25)





360 °F (182 °C)

400 °F (204 °C)



SL STYLE

FIGURE 3-33

MAXIMUM REGISTERING THERMOMETER

The Maximum Registering Thermometer (Part No. 15240) may be used to indicate the highest normal temperature for the protected area. Once this is established, the correct rated fusible link can be chosen. Other methods for determining maximum temperatures may be used.

HOSE/GROMMET PACKAGE

The Hose/Grommet Package (Part No. 418511) consists of a 24 in. rubber hose and two grommets. This package is required when expellant gas hose is routed outside the AUTOMAN Regulated Release, Regulated Actuator, and/or tank enclosure assemblies.

SECTION 3 – SYSTEM COMPONENTS

UL EX3470 ULC EX3470

PAGE 3-12 REV. 11 2014-SEP-01

IN-LINE BURST DISC ASSEMBLY (MANIFOLDED SYSTEMS ONLY)

The in-line burst disc assembly is required to eliminate the siphoning of the agent up the pipe during extreme temperature variations. In addition to eliminating the siphoning effect, the common in-line burst disc assembly eliminates the possibility of one or more individual discs located in the tank adaptor from failing to burst. The assembly consists of a stainless steel body which houses the burst disc. When utilizing this assembly in a manifolded system, it is necessary to modify (remove) the burst disc located in all of the R-102 tank adaptors in the system. The in-line burst disc assembly is to be mounted as close to the tank outlet as possible. After system discharge, the assembly must be disassembled and a new burst disc installed.

Part No. Description
416970 In-Line Burst Disc Assembly
417911 Burst Disc (Pack of 10)




FIGURE 3-34

1/4 IN. CHECK VALVE

The 1/4 in. check valve (Part No. 25627) blocks the flow of actuation gas from the actuator that was actuated to the actuator(s) that was not actuated. This prevents actuation gas from escaping from an open actuator which may have had the cartridge removed.

CHECK VALVE (PART NO. 25627)





FIGURE 3-35

NOZZLE AIMING DEVICE

▶ The Nozzle Aiming Device (Part No. 439877) is available to properly aim each nozzle to the correct aiming point. The device clamps to the nozzle and emits a small laser light that reflects on the surface that it is aiming at. The nozzle can then be rotated to point at a predetermined aiming point and then tightened to hold that angle. The aiming device adaptor attaches to the nozzle. The shipping assembly consists of the aiming device and the adaptor.



STAINLESS STEEL BRAIDED ACTUATION HOSE

The Stainless Steel Actuation Hose is used to connect the actuation line compression tees between each pneumatic actuator. The hose has the same thread, 7/16-20, as the fittings. The actuation hose allows flexibility between the AUTOMAN and each regulated actuator.

Hose Part No.	Length	Couplings
31809	16 in. (406 mm)	7/16-20 x 7/16-20 Females
32335	20 in. (508 mm)	7/16-20 x 7/16-20 Females
32336	24 in. (610 mm)	7/16-20 x 7/16-20 Females
430815	42 in. (1067 mm)	7/16-20 Female x 1/4 in. NPT
	,	Male

Part No. Description 31810 Male Elbow (7/16-20 x 1/4 in. NPT) 31811 Male Tee (7/16-20 x 7/16-20 x 1/4 in. NPT) 415371 Tee (7/16-20 x 1/8 in. Male NPT x 1/8 in. Female NPT) 32338 Male Straight Connector (7/16-20 x 1/4 in. NPT) 25627 1/4 in. Check Valve



AGENT DISTRIBUTION HOSE AND RESTRAINING CABLE KIT

The Agent Distribution Hose and Restraining Cable Kit (Part No. 435982) consists of a 5 ft (1.5 m) long Agent Distribution Hose, a 3 ft (0.9 m) long Restraining Cable, and a Restraining Cable Hardware Package. The Agent Distribution Hose can be utilized with castered cooking appliances with castered supports found in commercial kitchens. The hose allows for movement of the appliance for cleaning without having to disconnect any fire suppression system discharge piping.

Note: The Agent Distribution Hose is authorized for use with only UL Listed ANSUL Wet Chemical Restaurant Fire Suppression Systems.

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 4-1

SYSTEM DESIGN

The ANSUL R-102 Restaurant Fire Suppression System may be used on a number of different types of restaurant cooking appliances and hood and duct configurations. The design information listed in this section deals with the limitations and parameters of this pre-engineered system. Those individuals responsible for the design of the R-102 system must be trained and hold a current ANSUL certificate in an R-102 training program.

The R-102 and the PIRANHA systems use compatible agents and components, therefore, they may be used together for cooking appliance, hood, and duct protection. The primary AUTOMAN Release can be either an R-102 or a PIRANHA AUTOMAN Release and can actuate up to two additional R-102 or PIRANHA Regulated Actuators. In systems utilizing a 101 remote release, any combination of the maximum number of regulated actuators can be used.

- · Both systems must actuate simultaneously.
- Each system must be designed and installed per its appropriate manual.
- Adjacent appliances requiring protection must be protected with the same type of system, either R-102 or PIRANHA, unless the center-to-center spacing between the adjacent R-102 and PIRANHA nozzles is no less than 36 in. (914 mm).
- When appliances are protected with R-102 nozzles, the hood and connecting duct above those appliances cannot be protected with PIRANHA nozzles.
- · Mixing systems in a common plenum is not allowed.

One of the key elements for restaurant fire protection is a correct system design. This section is divided into 10 sub-sections: Nozzle Placement Requirements, Tank Quantity Requirements, Actuation and Expellant Gas Line Requirements, Distribution Piping Requirements, Detection System Requirements, Manual Pull Station Requirements, Mechanical Gas Valve Requirements, Electrical Gas Valve Requirements, Electrical Switch Requirements, and Pressure Switch Requirements. Each of these sections must be completed before attempting any installation. System design sketches should be made of all aspects of design for reference during installation.

NOZZLE PLACEMENT REQUIREMENTS

This section gives guidelines for nozzle type, positioning, and quantity for duct, plenum, and individual appliance protection. This section must be completed before determining tank quantity and piping requirements.

Duct Protection - Single Nozzle

All duct protection is UL listed without limitation of maximum duct length (unlimited length). This includes all varieties of ductworks both horizontal and vertical including ducts that run at angles to the horizontal and ducts with directional bends.

Note: Ducts from multiple hoods connected to a common ductwork must be protected in compliance with NFPA 96 and all local codes.

The R-102 system uses different duct nozzles depending on the size of duct being protected.

GENERAL INFORMATION

1. Nozzles must be located 2-8 in. (51-203 mm) into the center of the duct opening, discharging up. See Figure 4-1.




FIGURE 4-1

- 000173
- 2. In installations where a UL listed damper assembly is employed, the duct nozzle can be installed beyond the 8 in. (203 mm) maximum, to a point just beyond the damper assembly that will not interfere with the damper. Exceeding the maximum of 8 in. (203 mm) in this way will not void the UL listing of the system.
- 3. Previously listed three flow number and five flow number duct protection detailed in earlier published manual (Part No. 418087-06) can also still be utilized.

DUCT SIZES UP TO 50 IN. (1270 mm) PERIMETER/ 16 IN. (406 mm) DIAMETER

- One 1W nozzle = one flow number
- 50 in. (1270 mm) perimeter maximum
- · 16 in. (406 mm) diameter maximum

DUCT SIZES UP TO 100 IN. (2540 mm)
PERIMETER/ 32 IN. (812 mm) DIAMETER

- · One 2W nozzle = two flow numbers
- 100 in. (2540 mm) perimeter maximum
- 32 in. (812 mm) diameter maximum

The chart below shows the maximum protection available from each duct nozzle.

Description	3.0 Gallon System	1.5 Gallon System
2W Nozzle	Maximum 100 in. (2540 mm) Perimeter	Maximum 100 in. (2540 mm) Perimeter
1W Nozzle	Maximum 50 in. (1270 mm) Perimeter	Maximum 50 in. (1270 mm) Perimeter

SECTION 4 - SYSTEM DESIGN

UL EX3470 ULC EX3470

PAGE 4-2 REV. 11 2014-SEP-01

Duct Protection – Multiple Nozzle

DUCT SIZES UP TO 135 IN. (3429 mm) PERIMETER – THREE FLOW OPTION

- One 1W nozzle and one 2W nozzle = three flow numbers
- 135 in. (3429 mm) perimeter maximum
- · No round duct option available
- Follow design table in Figure 4-2 to determine maximum module size for each nozzle

		1W Module	2W Module	
Side A Side B		Side B	Side B	Side B
Max	kimum	Maximum	Maximum	Maximum
in.	<u>(mm)</u>	<u>in.</u> (mm)	<u>in.</u> (mm)	<u>w. (mm)</u>
4	(101)	60.0 (1524)	23.0 (584)	37.0 (939)
5	(127)	60.0 (1524)	23.0 (584)	37.0 (939)
6	(151)	59.5 (1511)	22.5 (571)	37.0 (939)
7	(177)	59.0 (1498)	22.0 (558)	37.0 (939)
8	(203)	58.5 (1485)	22.0 (558)	36.5 (927)
9	(228)	58.0 (1473)	21.5 (546)	36.5 (927)
10	(254)	57.0 (1447)	21.0 (533)	36.0 (914)
11	(279)	56.0 (1422)	20.5 (520)	35.5 (901)
12	(304)	55.5 (1409)	20.0 (508)	35.5 (901)
13	(330)	54.5 (1384)	19.5 (495)	35.0 (889)
14	(355)	53.5 (1358)	18.5 (469)	35.0 (889)
15	(381)	52.0 (1320)	18.0 (457)	34.0 (863)
16	(406)	51.0 (1295)	17.0 (431)	34.0 (863)
17	(431)	49.5 (1257)	16.0 (406)	33.5 (850)
18	(457)	47.5 (1206)	14.5 (368)	33.0 (838)
19	(482)	46.0 (1168)	13.5 (342)	32.5 (825)
20	(508)	43.5 (1104)	12.0 (304)	31.7 (805)
21	(533)	41.0 (1041)	10.0 (254)	31.0 (787)
22	(558)	38.0 (965)	7.5 (190)	30.5 (774)
23	(584)	33.5 (850)	4.0 (101)	29.5 (749)




FIGURE 4-2

Example: Protection is required for a duct that has an "A" dimension of 8 in. (203 mm) wide and a "B" dimension of 55 in. (1397 mm) long.

Referring to the table in Figure 2, if the "A" dimension is 8 in. (203 mm), the "B" dimension must not exceed 58.5 in. (1485 mm). In this example, the "B" dimension is 55 in. (1397 mm), therefore, this duct can be protected with a three flow application.

Read over from the 8.0 in. (203 mm) line on the table to the 1W Module column. At that point, the chart shows that the "B" module length for the 1W nozzle can be 22.0 in. (558 mm). Center the 1W nozzle in that module. The 2W module can now be centered within the remaining module.

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 4-3

Duct Protection – Multiple Nozzle (Continued)

DUCT SIZES GREATER THAN 100 IN. (2540 mm) PERIMETER

- Ducts over 100 in. (2540 mm) perimeter may be modularized using 2W nozzles
- · No round duct option available
- Follow the design chart to determine maximum module size for each 2W nozzle
- When determining number of nozzles required, it is sometimes an advantage to check the chart using the shortest side as Side "A" and then recheck it using the longest side as Side "A." This comparison may reveal a need for a lesser quantity of nozzles one way versus the other way.

When working with Chart 4-1, the quantity of nozzles determined must be equally divided within the duct area.

When working with Chart 4-2, one half of the quantity of nozzles determined must be equally positioned in the top half of the area of the duct and the remaining half of the nozzles must be positioned in the bottom half of the duct area.

Example: The duct to be protected has a Side "A" of 40 in. (1016 mm) and a Side "B" of 60 in. (1524 mm). Referring to the design chart, this duct requires four nozzles. One half of 4 = 2. Therefore, two nozzles must be equally positioned in each of the two duct areas. See Figure 4-3.




CHART 4-1

SIDE "B" cm 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 66 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 in. 13 11 28 43 21 23 24 58 27 28 29 71 33



NOTE: NOZZLE QUANTITIES LISTED IN CHART 4-2 MUST BE EQUALLY DIVIDED INTO EACH OF THE TWO DUCT MODULES.


SECTION 4 - SYSTEM DESIGN

UL EX3470 ULC EX3470

PAGE 4-4 REV. 11 2014-SEP-01

Transition Protection

Transitions are protected at a point in the transition where the perimeter or the diameter is equal to or less than the maximum size duct that can be protected. The nozzle(s) must be located in the center of the area at that point, or center of the module protected when more than one duct nozzle is required. Note: Nozzles to protect ducts with a transition that is more than 4 ft (1.2 m) in height, will be required to be positioned in the opening of the transition from the hood 2 to 8 in. (50 to 203 mm) into the opening using standard duct nozzle design parameters. See Figure 4-4.




Electrostatic Precipitator Protection

Some restaurant ventilating ducts have an electrostatic precipitator installed at or near the base. These precipitators are generally small and are used to aid in the cleaning of exhaust air.

Ducts with precipitators located at or near the base can be protected using duct nozzle(s) above the precipitator and 1/2N nozzle(s) for the precipitator. One 1/2N nozzle must be used ► for each cell being protected. This nozzle is stamped with 1/2N, indicating that it is a 1/2-flow nozzle and must be counted as 1/2 flow number.

When protecting ducts equipped with precipitators, the duct nozzle(s) must be installed above the precipitator and aimed to discharge downstream. If the area above the precipitator is a duct, the nozzle(s) must be positioned according to duct protection guidelines. If the area above the precipitator is a transition, the transition guidelines must be followed.

The 1/2N nozzle must be centered 10 to 26 in. (254 to 660 mm) below the precipitator and aimed to discharge at the center of each precipitator cell. However, if it is physically impossible to mount the nozzle at 10 to 26 in. (254 to 660 mm) due to precipitator placement, the nozzle may be mounted closer than 10 in. (254 mm). See Figure 4-5.



* IF PHYSICALLY IMPOSSIBLE AT 10 TO 26 IN. (254 TO 660 mm), NOZZLE MAY BE MOUNTED CLOSER THAN 10 IN. (254 mm).

FIGURE 4-5

Note: For protection of Pollution Control Units (PCUs) or air scrubbers with or without ESPs, contact Technical Services for non-UL listed recommended application.

Plenum Protection


The R-102 system uses the 1W nozzle or the 1N nozzle for plenum protection. The 1W nozzle is stamped with 1W and

the 1N nozzle is stamped with 1N, indicating they are one-flow nozzles and must be counted as one flow number each. When protecting a plenum chamber, the entire chamber must be protected regardless of filter length.

VERTICAL PROTECTION – GENERAL

1W NOZZLE - SINGLE AND "V" BANK PROTECTION

One 1W nozzle will protect 4 linear feet (1.2 m) of plenum. The maximum distance from the end of the hood to the first and last nozzle must be no more than 2 ft (0.6 m). After the first nozzle, any additional nozzles must be positioned at a maximum of 4 ft (1.2 m) apart down the entire length of the plenum. The plenum width must not exceed 4 ft (1.2 m). (The 1W nozzle can be used on single or V-bank filter arrangements.) See Figure 4-6.



When protecting plenums with the 1W nozzle, two options of coverage are available:

Option 1: The 1W nozzle must be on the center line of the single or "V" bank filter and positioned within 1-20 in. (26-508 mm) above the top edge of the filter. See Figure 4-7.




FIGURE 4-7

Option 2: The 1W nozzle must be placed perpendicular, 8-12 in. (203-304 mm) from the face of the filter and angled to the center of the filter. The nozzle tip must be within 2 in. (50 mm) from the perpendicular center line of the filter. See Figure 4-8.




FIGURE 4-8

HORIZONTAL PROTECTION – OPTION 1 1N NOZZLE SINGLE BANK PROTECTION

▶ One 1N nozzle will protect 10 linear feet (3.0 m) of single filter bank plenum. The nozzle(s) must be mounted in the plenum, 2 to 4 in. (50 to 102 mm) from the face of the filter, centered between the filter height dimension, and aimed down the length. The nozzle must be positioned 0-6 in. (0-152 mm) from the end of the hood to the tip of the nozzle. See Figure 4-9.




FIGURE 4-9

SECTION 4 - SYSTEM DESIGN

UL EX3470 ULC EX3470

PAGE 4-6 **REV. 11** 2014-SEP-01

Plenum Protection (Continued)

HORIZONTAL PROTECTION – OPTION 2 1W NOZZLE - "V" BANK PROTECTION


One 1W nozzle will protect 6 linear feet (1.8 m) of "V" bank plenum. The nozzle must be mounted horizontally, positioned 1/3 the filter height down from the top of the filter. Nozzles can be located at 6 ft (1.8 m) spacings on longer plenums. The nozzle

must be positioned 0-6 in. (0-152 mm) from the end of the hood to the tip of the nozzle. See Figure 4-10.

1W NOZZLE 1/3 (H) HEIGHT OF FILTER (H) 6 FT (1.8 m) MAXIMUM (1.2 m) MAXIMUM Q FIGURE 4-10

TWO 1N NOZZLES - "V" BANK PROTECTION

- ► Two 1N nozzles will protect 10 linear feet (3.0 m) by 4 ft (1.2 m) wide of "V" bank plenum. The nozzles must be mounted in the
- ▶ plenum, 2 to 4 in. (50 to 101 mm) from the face of the filter, centered between the filter height dimension, and aimed down the length. The nozzle must be positioned 0-6 in. (0-381 mm) from the end of the hood to the tip of the nozzle. See Figure 4-11.



For a plenum, either single or "V" bank, with a linear extension

- ▶ longer than 10 ft (3.0 m), each bank may be protected using one
- ▶ 1N nozzle every 10 ft (3.0 m) or less depending on the overall length of the plenum. See Figure 4-12. The nozzles may point in the opposite directions as long as the entire plenum area is
- ▶ protected, and the 10 ft (3.0 m) limitation is not exceeded. See Figure 4-13. The nozzle positioning shown in Figure 4-14 is not an acceptable method of protection because the plenum area directly under the tee is not within the discharge pattern of either nozzle.




FIGURE 4-12




FIGURE 4-13




FIGURE 4-14

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 4-7

Appliance Protection

The following pages detail types of appliance protection. Each design requires several factors: correct nozzle choice, correct nozzle height above hazard, correct nozzle location and correct aiming point.

Fryer - Single Nozzle Protection

 Design requirements for fryers are broken down into two types.

A. FRYERS WITHOUT DRIPBOARDS

If the fryer does not include a dripboard, measure the internal depth (horizontal dimension from front to back) and length of the frypot.

B. FRYERS WITH DRIPBOARDS

If the fryer includes any dripboard areas, measure both the internal depth (horizontal dimension from front to back) and length of the frypot portion, and then measure the internal depth and length of the overall hazard area including any dripboard areas.

- Using Table, "Maximum Cooking Area Dimension Single Nozzle Fryer Protection," determine which nozzle is needed to protect the fryer based on the maximum dimensions listed.
 - A. If the fryer does not include a dripboard, use the maximum dimensions listed in the first column of the table to select the correct nozzle.
 - B. If the fryer includes any dripboard areas, use both the maximum frypot dimensions in the first column of the table, and the maximum overall dimensions in the second column of the table to select the correct nozzle. None of the maximum dimensions in either column may be exceeded.
- 3. If either the maximum frypot or the overall sizes are exceeded, an additional nozzle(s) will be required. Refer to the multiple nozzle requirements.

Example: A fryer with a dripboard. The inside of the frypot without the dripboard measures 18 in. in depth x 18 in. in length (457 mm x 457 mm) and the inside of the overall area including the dripboard measures 18 in. in depth x 24 in. in length (457 mm x 610 mm). From the Table "Maximum Cooking Area Dimension – Single Nozzle Fryer Protection," either the 3N or the 290 nozzle should be selected to protect the fryer, depending on the maximum nozzle height above the fryer and the positioning requirements allowed. Refer to appropriate Figures.

SECTION 4 - SYSTEM DESIGN

UL EX3470 ULC EX3470


PAGE 4-8 REV. 11 2014-SEP-01

Fryer - Single Nozzle Protection (Continued)


Maximum Area Dimensions - Single Nozzle Fryer Protection

Max. Size Frypot Only	Max. Size Overall With Dripboard	Type of Nozzle	Nozzle Height Above Top of Fryer	Nozzle Location
Full or Split Vat 14 in. x 15 in. ► (355 mm x 381 mm)	Full or Split Vat 14 in. x 21 in. (355 mm x 533 mm)	230	27 in. to 47 in. (686 mm to 1193 mm)	See Figure 4-15 and 4-16
Full or Split Vat 14 in. x 15 in. ► (355 mm x 381 mm)	Full or Split Vat 14 in. x 21 in. (355 mm x 533 mm)	245	20 in. to 27 in. (508 mm to 685 mm)	See Figure 4-15 and 4-16
Full or Split Vat 14 in. x 15 in. ► (355 mm x 381 mm)	Full or Split Vat 14 in. x 21 in. (355 mm x 533 mm)	290	13 in. to 16 in. (330 mm to 406 mm)	See Figure 4-17
Full or Split Vat 14 1/2 in. x 14 in. ▶ (368 mm x 355 mm)	Full or Split Vat 14 1/2 in. x 26 1/2 in. (368 mm x 673 mm)	290	16 in. to 27 in. (406 mm to 685 mm)	See Figure 4-17

FIGURE 4-15



NOZZLE TIP POSITIONED ANYWHERE ALONG OR WITHIN PERIMETER OF COOKING SURFACE AND AIMED TO THE CENTER OF THE COOKING AREA.




NOZZLE TIP POSITIONED ANYWHERE ALONG OR WITHIN PERIMETER OF COOKING SURFACE AND AIMED TO THE CENTER OF THE COOKING AREA.


FIGURE 4-16

Fryer - Single Nozzle Protection (Continued)

Maximum Area Dimensions - Single Nozzle Fryer Protection (Continued)

Max. Size Frypot Only	Max. Size Overall With Dripboard	Type of Nozzle	Nozzle Height Above Top of Fryer	Nozzle Location
► 14.5 in. x 16.5 in. ► (368 mm x 419 mm)	14.5 in. x 26.5 in. (368 mm x 673 mm)	290	16 in. to 21 in. (406 to 533 mm)	See Figure 4-17
19.5 in. x 19 in. ► (495 mm x 482 mm)	19.5 in. x 25 3/8 in. (495 mm x 644 mm)	290	13 in. to 16 in. (330 to 406 mm)	See Figure 4-17
19.5 in. x 19 in. ► (495 mm x 482 mm)	19.5 in. x 25 3/8 in. (495 mm x 644 mm)	3N	See Figure 4-18	See Figure 4-18
18 in. x 18 in. ► (457 mm x 457 mm)	18 in. x 27 3/4 in. (457 mm x 704 mm)	3N	25 in. to 35 in. (635 mm to 889 mm)	See Figure 4-19






FRYER WITHOUT DRIPBOARD

FRYER WITH DRIPBOARD


290 NOZZLE TIP POSITIONED OVER THE MIDPOINT OF THE HAZARD AREA \pm 3 IN. (76 mm) FROM THE MIDPOINT ALONG THE LONGEST SIDE OF THE HAZARD AND \pm 1 IN. (25 mm) FROM THE MIDPOINT ALONG THE SHORTEST SIDE OF THE HAZARD AND AIMED AT THE MIDPOINT OF THE COOKING AREA.

FIGURE 4-17



NOTE: 3N NOZZLE TIP MUST BE LOCATED WITHIN THE PERIMETER OF THE SURFACE AREA WITHIN THE FRONT HALF OF THE FRY POT AND AIMED AT THE CENTER.

FIGURE 4-19



3N NOZZLE TIP POSITIONED ANYWHERE ALONG OR WITHIN PERIMETER OF COOKING SURFACE AND AIMED TO THE CENTER OF THE COOKING AREA.

FIGURE 4-18

00228

UL EX3470 ULC EX3470

PAGE 4-10 REV. 11 2014-SEP-01

Fryer - Multiple Nozzle Protection

Design Requirements:

Fryers exceeding the coverage of a single nozzle can be divided into modules. Each module must not exceed the maximum area allowed for a single nozzle. However, when utilizing multiple nozzle protection, the longest side allowed for a fryer with dripboard can be used, regardless of whether the fryer has a dripboard or not.

The maximum size fryer that can be modularized is 864 in.² \triangleright (55742 mm²).

- Design requirements for multiple nozzle fryers are broken down into two types:
 - A. FRYERS WITHOUT DRIPBOARD(S)

If the fryer does not include a dripboard, measure the internal depth (horizontal dimension from front to back) and length of the frypot. Then, multiply the depth and length to obtain the area of the frypot in square inches.

- B. FRYERS WITH DRIPBOARD(S)
 - If the fryer includes any dripboard areas, measure both the internal depth and length of the frypot portion, and then measure the internal depth and length of the overall hazard area including any dripboard areas.
 - Determine the area of both the frypot and the area of the overall vat by multiplying corresponding depth and length dimensions.
- Divide the frypot or overall vat into modules, each of which can be protected by a single nozzle, based on the maximum dimension and area coverage of the nozzle as specified in Table, "Maximum Cooking Area Dimension – Multiple Nozzle Protection."

- A. If the module considered does not include any portion of the dripboard, use only the maximum frypot area and maximum dimension listed in the first column of the table to select the correct nozzle.
- B. If the module considered includes any dripboard areas, use both the maximum frypot area and dimension listed in the first column of the table, and the maximum overall area and dimensions listed in the second column of the table to select the correct nozzle.
- None of the maximum dimensions in either column may be exceeded. If either the maximum frypot or the overall sizes are exceeded, the area divided into modules will need to be redefined with the possibility of an additional nozzle.


Options For Modularizing Fryers


The following Figure 4-20 shows approved methods of dividing (modularizing) fryers so that each section can be properly protected. Example: A fryer with a dripboard. The inside vat without the dripboard measures 18 in. in depth x 30 in. in length (457 mm x 762 mm) and the inside of the overall vat including the dripboard measures 24 in. in depth x 30 in. in length (610 mm x 762 mm). Because the fryer is 30 in. (762 mm) in length, it exceeds the coverage of a single nozzle.

Dividing the length in half, each module now has an overall vat dimension of 24 in. in depth x 15 in. in length (610 mm x 381 mm). From the Table, "Maximum Cooking Area Dimension – Multiple Nozzle Fryer Protection," either the 3N or the 290 nozzle should be selected to protect each fryer module, depending on the maximum nozzle height above the fryer and the positioning requirements allowed. Refer to appropriate Figures, 4-15 through 4-19.

See additional examples in Appendix Section.

EACH MODULAR AREA, INCLUDING DRIPBOARD, MUST NOT EXCEED 497 IN.² (32064 mm²)










FIGURE 4-20

Fryer - Multiple Nozzle Protection (Continued)

Maximum Area Dimension - Multiple Nozzle Fryer Protection

Max. Size Module Frypot Only Full or Split Vat 21 in. x 210 in. ² (533 mm x 0.14 m ²)	Max. Size Module Overall With Dripboard Full or Split Vat 21 in. x 294 in. ² (533 mm x 0.19 m ²)	Type of Nozzle	Nozzle Height Above Top of Fryer 27 in. to 47 in. (686 mm to 1194 mm)	Nozzle Location See Figure 4-21
Full or Split Vat 21 in. x 210 in. ² (533 mm x 0.14 m ²)	Full or Split Vat 21 in. x 294 in. ² (533 mm x 0.19 m ²)	245	20 in. to 27 in. (508 mm to 686 mm)	See Figure 4-21
Full or Split Vat 21 in. x 210 in. ² (533 mm x 0.14 m ²)	Full or Split Vat 21 in. x 294 in. ² (533 mm x 0.19 m ²)	290	13 in. to 16 in. (330 mm to 406 mm)	See Figure 4-22
25 3/8 x 370.5 in ² (644 mm x 0.24 m ²)	25 3/8 x 495 in ² (644 mm x 0.32 m ²)	290	13 in. to 16 in. (330 mm to 406 mm)	See Figure 4-22
Full or Split Vat 26 1/2 in. x 203 in. ² (673 mm x 0.13 m ²)	Full or Split Vat 26 1/2 in. x 384 1/4 in. ² (673 mm x 0.25 m ²)	290	16 in. to 27 in. (406 mm to 686 mm)	See Figure 4-22
25 3/8 x 370.5 in ² (644 mm x 0.24 m ²)	25 3/8 x 495 in ² (644 mm x 0.32 m ²)	3N	See Figure 4-23	See Figure 4-23
27 3/4 x 324 in. ² (704 mm x 0.21 m ²)	27 3/4 x 497 in ² (704 mm x 0.32 m ²)	3N	25 in. to 35 in. (635 mm to 889 mm)	See Figure 4-24







FRYER WITHOUT DRIPBOARD

FRYER WITH DRIPBOARD

POSITION NOZZLE TIP ANYWHERE ALONG OR WITHIN THE PERIMETER OF THE MODULE IT IS PROTECTING AND AIM AT THE MIDPOINT OF THAT MODULAR AREA.


FIGURE 4-21





290 NOZZLE TIP POSITIONED OVER THE MIDPOINT OF THE RESPECTIVE MODULAR

AREA ± 3 IN. (76 mm) FROM THE MIDPOINT ALONG THE LONGEST SIDE OF THE MODULE AND \pm 1 IN. (25 mm) FROM THE MIDPOINT ALONG THE SHORTEST SIDE OF THE MODULE AND AIMED AT THE MIDPOINT OF THE MODULE.




FRYER WITHOUT DRIPBOARD

FRYER WITH DRIPBOARD

3N NOZZLE TIP MUST BE POSITIONED ANYWHERE ALONG OR WITHIN THE PERIMETER OF THE MODULAR IT IS PROTECTING AND AIMED AT THE MIDPOINT OF THAT RESPECTIVE MODULE AREA.

FIGURE 4-23



THE 3N NOZZLE TIP MUST BE POSITIONED ANYWHERE ALONG OR WITHIN THE PERIMETER AND FORWARD OF THE RIGHT-TO-LEFT CENTERLINE OF THE COOKING AREA. THE AIMING POINT OF THE NOZZLE MUST BE AT THE DIAGONAL CENTER OF THE MODULAR COOKING AREA.

UL EX3470 ULC EX3470

PAGE 4-12 REV. 11 2014-SEP-01


Multiple Nozzle Fryer Protection - Tilt Skillet / Braising Pan

Protection for tilt skillets or braising pans is to be based upon the coverage limitations provided for deep fat fryer protection. Refer to Section IV, DESIGN, starting on Page 4-10, for maximum fryer nozzle coverages and maximum fryer nozzle height limitations.

► Although the maximum 864 in.² (55741 mm²) total surface cooking area requirement applies to fryer protection, it does not apply to tilt skillets or braising pans.


Each tilt skillet/braising pan protected module must not exceed the fryer limitations for "MAXIMUM SIZE MODULE OVERALL WITH DRIPBOARD" coverage per nozzle as described in Table on Page 4-11.

Tilt skillets and braising pans generally utilize a hinged cover. Fryer protection nozzles are to be placed toward the front of the appliance to minimize the potential for the tilt skillet or braising pan cover to interfere with the nozzle discharge. See Figures 4-25 and 4-26.



THE NOZZLE IS TO BE PLACED TOWARD THE FRONT OF THE APPLIANCE TO MINIMIZE THE POTENTIAL FOR THE SKILLET OR BRAISING PAN COVER TO INTERFERE WITH THE NOZZLE DISCHARGE.

FIGURE 4-25



FRYER NOZZLE USED FOR TILT SKILLET OR BRAISING PAN PROTECTION MUST BE POSITIONED NEAR THE FRONT EDGE OF THE PAN AND AIMED AT THE FRONT TO BACK CENTERLINE OF THE PAN. THE DISCHARGE FROM THE NOZZLE(S) MUST COMPLETELY CLEAR THE PAN COVER WITH AN UNOBSTRUCTED VIEW TO THE BACK OF THE PAN.

FIGURE 4-26

Range Protection

The R-102 system uses five different nozzles for the protection of ranges. Two of the design options require a one-flow nozzle and three of the design options require two-flow nozzles.

NOTICE

A 13 in. (330 mm) diameter wok pan is the largest wok size that can be protected on ranges.

When protecting hot top ranges, the entire cooking surface must be protected.

Range Protection 1N (1-Flow) Nozzle – High Proximity Application

No Obstructions

Single and multiple burner ranges can be protected using a 1N
▶ nozzle. The nozzle is stamped with 1N, indicating that this is a one-flow nozzle and must be counted as one flow number.

When using this nozzle for range protection, the maximum length of the burner grates being protected with a single nozzle must not exceed 32 in. (812 mm) and the maximum area of the burner grates must not exceed 384 in.² (24774 mm²) per nozzle.

When protecting a range, the 1N nozzle must be located a maximum of 10 in. (254 mm) from each burner grate centerline and must be aimed at the center of the cooking surface. See Figures 4-27 and 4-28.





FIGURE 4-27



UL EX3470 ULC EX3470

PAGE 4-14 REV. 11 2014-SEP-01

Range Protection 245 (2-Flow) Nozzle – High Proximity Application

No Obstructions

40 in. to 50 in. (1016 mm to 1270 mm) above the cooking surface.

This high proximity application uses the 245 nozzle.

The nozzle is stamped with 245 indicating this is a two-flow nozzle and must be counted as two flow numbers.

One 245 nozzle will protect a maximum cooking area of 672 in.² (43354 mm²) with a maximum longest dimension of 28 in. (711 mm).

When using this nozzle for range protection, the nozzle must be pointed vertically down and positioned as shown in Figures 4-29 and 4-30.






FIGURE 4-29

NOTICE

Four burner grates shown in Figure 4-30. For single or double burner grates, locate nozzle at center of cooking surface or 11 3/8 in. (288 mm) maximum from nozzle centerline to center of any burner grate.





Range Protection 260 (2-Flow) Nozzle – Medium Proximity Application

No Obstructions

30 in. to 40 in. (762 mm to 1016 mm) above the cooking surface. The medium proximity application uses the 260 nozzle.

► The nozzle is stamped with 260 indicating this is a two-flow nozzle and must be counted as two flow numbers.

One 260 nozzle will protect a cooking area of 768 in.² (49548 mm²) with a maximum dimension of 32 in. (812 mm).

When using this nozzle for range protection, the nozzle must be pointed vertically down and positioned as shown in Figures 4-31 and 4-32.




FIGURE 4-31




FIGURE 4-32

NOTICE

Four burner grates shown in Figure 4-32. For single or double burner grates, locate nozzle at center of cooking surface.

UL EX3470 ULC EX3470

PAGE 4-16 REV. 11 2014-SEP-01

Range Protection 1N (1-Flow) Nozzle – Low Proximity Application

15 in. to 20 in. (381 mm to 508 m) above the cooking surface.

The low proximity 1-flow nozzle application for the protection of ranges requires the 1N nozzle.

The nozzle is stamped with 1N indicating that it is a one-flow nozzle and must be counted as one flow number,

When using the 1N nozzle for low proximity range protection with or without obstruction, the maximum length of the burner grates being protected must not be exceed 24 in. (609 mm) length, aimed along a centerline to a point 20 in. (508 mm) from the end of the length, protecting a maximum width of 18 in. (457 mm).

When protecting a range, the 1N nozzle must be located a maximum of 9 in. (228 mm) from each burner grate centerline and must be positioned above the edge of the hazard area to be protected.

The 1N nozzle tip must be positioned at or below the obstruction, if present. The protected area begins at the point straight down from the nozzle tip. The nozzle can be placed at the side of the range aimed either left or right, or can be placed in the front or back of the range. See Figures 4-33 and 4-34 for nozzle location details.




FIGURE 4-33




FIGURE 4-34

Range Protection Two 290 (2-Flow) Nozzles – Low Proximity Application


15 in. to 20 in. (381 mm to 508 mm) above the cooking surface.

The low proximity 2-flow application requires the use of two 290 nozzles.

Both nozzles are stamped with 290 indicating they are two flow nozzles and must be counted together for a total of four flow numbers.

Two 290 nozzles will protect a cooking area of 1008 in.² (65032 mm²) with a maximum dimension of 36 in. (914 mm).

When using two of these nozzles for low proximity range protection, the nozzles must be positioned along the cooking surface perimeter to 1.5 in. (38 mm) inside the perimeter, and aimed at a 45° angle along the longitudinal centerline of the range. See Figures 4-35 and 4-36.



290 NOZZLE TIP LOCATION

OF COOKING SUBFACE

1.5 IN. (38 mm) IN FROM EDGE

COOKING SURFACE

± 2 IN. (50 mm)

Range Protection (With or Without Back Shelf/Obstruction)


When this type of hazard is equipped with a back shelf or other similarly sized obstruction located above the range top, two protection options are available: One requires a 1F nozzle and the other option requires a 260 nozzle.

Range Protection 1F (1-Flow) Nozzle (With or Without Back Shelf/Obstruction)

Single and multiple burner ranges can be protected using a • 1F nozzle. The nozzle is stamped with 1F indicating that it is a one-flow nozzle and must be counted as one flow number.

When using the 1F nozzle for range protection with or without back shelf or other similarly sized obstruction, the maximum length of the burner grates being protected must not exceed 28 in. (711 mm) and the maximum area of the burner grates must not exceed 336 in. (21677 mm²). See Figure 4-37 for nozzle location details.

1F NOZZLE



1F NOZZLE LOCATED OVER FRONT EDGE OF BURNER GRATE AND ORIENTED SO NOZZLE TIP FLATS ARE PARALLEL WITH BURNER GRATE FRONT TO REAR CENTERLINE AND SHALL BE AIMED AT THE CENTER OF THE COOKING SURFACE.

FIGURE 4-37

Range Protection 260 (2-Flow) Nozzle (With or Without Back Shelf/Obstruction)

Single and multiple burner ranges can be protected using a 260 • nozzle. The nozzle is stamped with 260 indicating that it is a two-flow nozzle and must be counted as two flow numbers.

When using the 260 nozzle for range protection with or without back shelf or other similarly sized obstruction, the maximum length of burner grates being protected must not exceed 32 in. (812 mm) and the maximum area of the burner grates must not exceed 384 in.² (24774 mm²). Nozzle must be located on the front edge of the burner grates and aimed at a point 10 in. (254 mm) from the back edge of the burner grates. Nozzle must be mounted 30 to 40 in. (762 to 1016 mm) above the hazard surface. See Figure 4-38.

260 NOZZLE




FIGURE 4-38

000238a

UL EX3470 ULC EX3470

PAGE 4-18 REV. 11 2014-SEP-01

Griddle Protection 1N (1-Flow) Nozzle – High Proximity Application

The R-102 system uses four different nozzles for the protection of griddles. One of the applications requires a 1-flow nozzle and three of the applications require a 2-flow nozzle.

High Proximity Application: 35 in. to 40 in. (889 to 1016 mm) above the cooking surface.

This high proximity application uses the 1N nozzle.


The nozzle is stamped with 1N indicating this is a one-flow nozzle and must be counted as one flow number.

One 1N nozzle will protect a maximum cooking area of 1080 in.² (69677 mm²) with the maximum longest side of 36 in. (914 mm).

When using this nozzle for griddle protection, the nozzle must be positioned along the cooking surface perimeter to a maximum of 2 in. (50 mm) inside the perimeter, and aimed to the midpoint of the cooking surface. See Figure 4-39 and 4-40.

NOTICE

When using this type of griddle protection, only five flow numbers are allowed on a 1.5 gal (5.7 L) system and only 11 flow numbers are allowed on a 3 gal (11.4 L) system.






FIGURE 4-40

Griddle Protection 290 (2-Flow) Nozzle – High Proximity Application

Option 1 - Nozzle Center Located

30 in. to 50 in. (762 mm to 1270 mm) above the cooking surface. This high proximity application uses the 290 nozzle.

► The nozzle is stamped with 290 indicating this is a 2-flow nozzle and must be counted as two flow numbers.

One 290 nozzle will protect a maximum cooking area of 720 in.² (46451 mm²) with a maximum dimension of 30 in. (762 mm).

When using this nozzle for high proximity applications, the nozzle must be positioned within 1 in. (25 mm) of the center of the cooking surface and pointed vertically down. See Figure 4-41 and 4-42.




FIGURE 4-41




FIGURE 4-42

2014-SEP-01 **REV. 11 PAGE 4-19**

Griddle Protection 260 (2-Flow) Nozzle - High Proximity **Application**


Option 2 - Nozzle Perimeter Located


30 in. to 50 in. (762 mm to 1270 mm) above the cooking surface. This high proximity application uses the 260 nozzle.

► The nozzle is stamped with 260 indicating this is a two-flow nozzle and must be counted as two flow numbers.

One 260 nozzle will protect a maximum cooking area of 1440 in.² (92903 mm²) with a maximum dimension of 48 in. (1219 mm).

When using this nozzle for griddle protection, the nozzle must be positioned along the cooking surface perimeter to 2 in. (50 mm) inside perimeter, and aimed at the center of the cooking surface. See Figure 4-43 and 4-44.





Griddle Protection 290 (2-Flow) Nozzle - Medium Proximity **Application**

Option 2a - Nozzle Perimeter Located (Continued)

20 in. to 30 in. (508 mm to 762 mm) above the cooking surface. The medium proximity application uses the 290 nozzle.

► The nozzle is stamped with 290 indicating this is a two-flow nozzle and must be counted as two flow numbers.

One 290 nozzle will protect a maximum cooking area of 1440 in.² (92903 mm²) with a maximum dimension of 48 in. (1219 mm).

When using this nozzle for griddle protection, the nozzle must be positioned along the perimeter to 2 in. (50 mm) inside perimeter, and aimed at the center of the cooking surface. See Figure 4-45 and 4-46.




FIGURE 4-45

000241




FIGURE 4-46

UL EX3470 ULC EX3470

PAGE 4-20 REV. 11 2014-SEP-01

Griddle Protection 2120 (2-Flow) Nozzle – Low Proximity Application

Option 2b - Nozzle Perimeter Located (Continued)

10 in. to 20 in. (254 mm to 508 mm) above the cooking surface. The low proximity application uses the 2120 nozzle.

► The nozzle is stamped with 2120 indicating this is a two-flow nozzle and must be counted as two flow numbers.

One 2120 nozzle will protect a maximum cooking area of 1440 in.² (92903 mm²) with a maximum dimension of 48 in. (1219 mm).

When using this nozzle for griddle protection, the nozzle must be positioned along the perimeter to 2 in. (50 mm) inside perimeter, and aimed at the center of the cooking surface. See Figure 4-47 and 4-48.




FIGURE 4-47




FIGURE 4-48

Griddle Protection 2W (2-Flow) Nozzle – Low Proximity Application

Option 2c - Nozzle Perimeter Located (Continued)

10 in. to 20 in. (254 mm to 508 mm) above the cooking surface.

The low proximity application uses the 2W nozzle.

► The nozzle is stamped with 2W indicating this is a two-flow nozzle and must be counted as two flow numbers.

One 2W nozzle will protect a maximum cooking area of 1080 in.² (69677 mm²) with a maximum dimension of 36 in. (914 mm).

When using this nozzle for griddle protection, the nozzle must be positioned 0-10 in. (0-254 mm) forward or behind the right to left centerline of the hazard area. See the diagram below for nozzle location and aiming.

OVERHEAD VIEW




FIGURE 4-49

FRONT VIEW




FIGURE 4-50

Griddle Protection 1W (1-Flow) Nozzle – Low Proximity Application

15 in. to 20 in. (381 mm to 508 mm) above the cooking surface. The low proximity 1-flow nozzle application for the protection of griddles requires the 1W nozzle.

The nozzle is stamped with 1W indicating that this is a one-flow nozzle and must be counted as one flow number.

When using the 1W nozzle for low proximity griddle protection with our without obstruction, the maximum length of the cooking surface to be protected must not exceed 26 in. (660 mm). The nozzle must be centered at one end of the maximum 26 in. (660 mm) length, aimed along a centerline to a point 20 in. (508 mm) from the end of the length, protecting a maximum width of 20.5 in. (520 mm).

The 1W nozzle tip must be positioned at or below the obstruction, if present. The protected area begins at the point straight down from the nozzle tip. The nozzle can be positioned above the edge of the hazard area to be protected. See Figure 4-51 and 4-52.

Note: If the hazard area exceeds the single nozzle coverage listed above, additional nozzles will be required. The additional nozzle can be positioned in front at high proximity or at the side at low proximity.




FIGURE 4-51




FIGURE 4-52

Chain Broiler Protection

The following listed protection guidelines can be applied to any manufacturer's chain broilers, if the chain broiler meets the specified parameters. Chain broilers utilizing catalytic converters can be protected from overhead using model specific protection identified in the "Specific Application by Model" section in System Design. Or, they can be protected with standard 1N nozzle horizontal chain broiler protection with the nozzles positioned at either end of the chain broiler openings. Refer to the "Horizontal Chain Broiler Protection" section for specific design information.

Horizontal Chain Broiler Protection

The R-102 system can use two 1N nozzles for horizontal chain broiler protection. The nozzle is stamped 1N, indicating that this is a one-flow nozzle and must be counted as one flow number (total of two flow numbers for each chain broiler being protected).

Two 1N nozzles are always needed for chain broiler protection when the hazard area to be protected does not meet the "Overhead Broiler Protection" requirements. The maximum internal size of the broiler is 43 x 31 in. (1092 mm x 787 mm). The nozzles must be positioned at each end of the enclosed cooking chamber 1 to 3 in. (25 mm to 76 mm) above the surface of the chain and a maximum distance of 4 in. (101 mm) away from the broiler opening. The nozzles may be mounted at either corner as long as they are at opposite ends of the chain broiler and positioned to discharge diagonally across the top of the chain. See Figure 4-53 and 4-54.




FIGURE 4-53

UL EX3470 ULC EX3470

PAGE 4-22 REV. 11 2014-SEP-01

Horizontal Chain Broiler Protection (Continued)




FIGURE 4-54

Overhead Chain Broiler Protection

The R-102 system can use two 1W nozzles for overhead chain broiler protection. The nozzle is stamped with 1W, indicating that this is a one-flow nozzle and must be counted as one flow number.

Overhead protection is **only** available for chain broilers with exhaust opening dimensions that are not less than 60% of the internal broiler length and not less than 60% of the internal broiler width, to a minimum size of 12 in. x 12 in. (305 mm x 305 mm). Internal broiler size can not be larger than 32 in. x 34 in. (812 mm x 863 mm).

When overhead protection is used, the nozzles must be centered above the exhaust opening within 4 to 8 in. (101 to 203 mm) of each other and they must be located 10 to 26 in. (254 to 660 mm) above the top of the broiler surface. See Figure 4-55.





FIGURE 4-55

The nozzles may vary in position as long as they are evenly spaced from the exhaust center and are always 180° opposite of each other. If the opening is not square, the nozzles must be positioned along the centerline, parallel to the longest side of the opening. See Figure 4-56.






FIGURE 4-56

► Note: The Metal Blow-off Cap must be used when utilizing chain broiler protection.

Example No. 1 – Internal broiler size is 24 in. long x 20 in. wide (609 mm x 508 mm), with an opening of 16 in. x 16 in. (406 mm x 406 mm).

To determine minimum opening size, multiply the internal length and the internal width by 0.6:

Length of opening -24 in. $\times 0.6 = 14.4$ in. $(609 \text{ mm} \times 0.6 = 366 \text{ mm})$

Width of opening -20 in. $\times 0.6 = 12.0$ in. (508 mm $\times 0.6 = 304$ mm)

The minimum allowable opening for overhead protection would be 14.4 in. x 12.0 in. (365 mm x 304 mm).

This example would be acceptable for overhead protection.

Example No. 2 – Internal broiler size is 30 in. long x 24 in. wide (762 x 609 mm) with an opening of 22 in. x 12 in. (558 x 304 mm).

To determine minimum opening size, multiply internal length and internal width by 0.6:

Length of opening -30 in. $\times 0.6 = 18.0$ in. $(762 \text{ mm} \times 0.6 = 457 \text{ mm})$

Width of opening -24 in. $\times 0.6 = 14.4$ in. $(609 \text{ mm} \times 0.6 = 365 \text{ mm})$

Minimum allowable opening for overhead protection would be 18 in. x 14.4 in. (457 mm x 365 mm).

Because this broiler has an opening of 22 in. \times 12 in. (558 mm \times 304 mm), the 12 in. (304 mm) width is below the minimum allowable calculated dimension of 14.4 in. (365 mm) and therefore would not be acceptable for overhead protection.

Salamander Broiler Protection

The R-102 system uses three different nozzle locations for salamander broiler protection. All of the design options require a one-flow nozzle.

2014-SEP-01 REV. 11 PAGE 4-23

Salamander Broiler Protection – 1N (1-Flow) Nozzle Overhead

A salamander broiler with a maximum hazard area (internal broiler chamber) of 16 in. (406 mm) deep x 29 in. (736 mm) wide

► can be protected using a 1N nozzle. The nozzle is stamped with 1N, indicating that this is a one-flow nozzle.

The single 1N nozzle must be located directly in line with either vertical edge of the broiler opening, 6 in. (152 mm) to 12 in. (304 mm) in front of the broiler, and 0 in. to 12 in. (304 mm) above the top of the broiler. The nozzle must be aimed at the center of the broiler opening. See Figure 4-57a.




FIGURE 4-57a

Salamander Broiler Protection – 1F (1-Flow) Nozzle Overhead

A salamander broiler with a maximum hazard area (internal broiler chamber) of 15.5 in. (393 mm) deep x 31 in. (787 mm) ▶ wide can be protected using a 1F nozzle. The nozzle is stamped with 1F, indicating that this is a one-flow nozzle.

The single 1F nozzle must be located directly in line with the center of the broiler opening, 8 in. (203 mm) to 12 in. (304 mm) in front of the broiler and 12 in. (304 mm) to 18 in. (457 mm) above the top of the broiler. The nozzle must be aimed at the center of the top broiler opening when the grate is located in the middle position. The nozzle must be orientated so the nozzle tip flats are parallel with the grate left to right centerline. See Figure 4-57b.




FIGURE 4-57b

Salamander Broiler Protection – 1N (1-Flow) Nozzle Local

Note: The use of the Agent Distribution Hose should be considered when protecting a salamander broiler/range combination appliance that employs casters.

A salamander broiler with a maximum hazard area (internal broiler chamber) of 15 in. (381 mm) deep x 31 in. (787 mm) wide

- can be protected using a 1N nozzle. The nozzle is stamped with 1N, indicating that this is a one-flow nozzle.
- ► The single 1N nozzle must be affixed to the side of the cooking
- ► chamber, above the grate on either vertical edge of the broiler opening. The nozzle must be aimed at the center of the grates. See Figure 4-57c.




FIGURE 4-57c

Upright Broiler/Salamander Protection


The R-102 system uses two 1/2N Nozzles for all upright broiler protection. The nozzle is stamped 1/2N, indicating that this is a half-flow nozzle. A pair of these nozzles will equal one flow number

Two 1/2N nozzles will protect a maximum hazard area (internal broiler chamber) of 30 in. x 32.5 in. (761 mm x 825 mm). These nozzles must always be used in pairs on an upright broiler. One nozzle must be positioned above the grate and pointed at the back opposite corner of the broiler chamber. The second nozzle must be pointed down into the center of the drip pan through the open slot. See Figure 4-58.

UL EX3470 ULC EX3470

PAGE 4-24 REV. 11 2014-SEP-01

Upright Broiler/Salamander Protection (Continued)



Gas-Radiant/Electric Char-Broiler Protection

The R-102 system uses the 1N nozzle for gas-radiant/electric char-broiler protection.

► The nozzle is stamped with a 1N, indicating that this is a one-flow nozzle and must be counted as one flow number.

One 1N nozzle will protect a hazard with a maximum length of 36 in. (914 mm) and a total cooking area which does not exceed 864 in.² (55741 mm²). The nozzle tip must be located 15 in. to 40 in. (381 mm to 1016 mm) above the hazard surface. When using this nozzle for gas-radiant/electric char-broiler protection, the nozzle must be positioned anywhere along or within the perimeter of the maximum cooking area and shall be aimed at the center of the cooking surface. See Figure 4-59a.




FIGURE 4-59a

Electric Char-Broiler Protection (Optional)

The R-102 system uses the 1N nozzle for electric char-broiler protection.

The nozzle is stamped with a 1N, indicating that this is a one-flow nozzle and must be counted as one flow number.

One 1N nozzle will protect a hazard with a maximum length of 34 in. (863 mm) and a total cooking area which does not exceed 680 in.² (43870 mm²). The nozzle tip must be located 20 in. to 50 in. (508 mm to 1270 mm) above the hazard surface. When using this nozzle for electric char-broiler protection, the nozzle must be positioned anywhere along or within the perimeter of the maximum cooking area and shall be aimed at the center of the cooking surface. See Figure 4-59b.





FIGURE 4-59b

Lava Rock (Ceramic) Char-Broiler Protection

The R-102 system uses the 1N nozzle for all lava rock charbroiler protection. The nozzle is stamped with 1N, indicating that this is a one-flow nozzle and must be counted as one flow number.

One 1N nozzle will protect a hazard which has a maximum length of 24 in. (609 mm) and a total cooking area which does not exceed 312 in.² (20128 mm²). The nozzle tip must be located 18 in. to 35 in. (457 mm to 889 mm) above the hazard surface. When using this nozzle for lava rock (ceramic) charbroiler protection, the nozzle must be positioned anywhere along or within the perimeter of the maximum cooking area and angled to the center. See Figure 4-60.







FIGURE 4-60

Natural Charcoal Broiler Protection

The R-102 system uses the 1N nozzle for all natural charcoal broiler protection. The nozzle is stamped with 1N indicating that this is a one-flow nozzle and must be counted as one flow number.

One 1N nozzle will protect a hazard area which has a maximum length of 24 in. (610 mm) and a total cooking area which does not exceed 288 in.² (18580 mm²). The nozzle tip must be located 18 in. to 40 in. (457 mm to 1016 mm) above the hazard surface. When using this nozzle for natural charcoal broiler protection, the nozzle must be positioned anywhere along or within the perimeter of the maximum cooking area and aimed at the center of the cooking surface. See Figure 4-61.

The coverage of such appliances only applies when the depth of the charcoal does not exceed 4 in. (101 mm).



PAGE 4-26 REV. 11 2014-SEP-01

Alternate Ceramic/Natural Charcoal Char-broiler Protection

The R-102 system may also use the 3N nozzle for all ceramic (lava rock) and natural charcoal char-broiler protection. The

nozzle is stamped with 3N, indicating that this is a three-flow nozzle and must be counted as three flow numbers.

One 3N nozzle will protect a hazard which has a maximum length of 30 in. (762 mm) and a total cooking area which does not exceed 720 in.² (46451 mm²). The nozzle tip must be located 14 in. to 40 in. (355 mm to 1016 mm) above the hazard surface. The nozzle must be positioned anywhere along or within the perimeter of the maximum cooking area and angled to the center. See Figure 4-62.

For natural charcoal char-boiler protection, this coverage only applies when the depth of the charcoal does not exceed 4 in. (101 mm).




FIGURE 4-62

Wood Fueled Char-Broiler Protection

The R-102 system uses the 3N nozzle for mesquite char-broiler
▶ protection. The nozzle is stamped with 3N indicating that this is a three-flow nozzle and must be counted as three flow numbers.

One 3N nozzle will protect a hazard which has a maximum length of 30 in. (762 mm) and a total cooking area which does not exceed 720 in.² (46451 mm²). The nozzle tip must be located 14 in. to 40 in. (355 mm to 1016 mm) above the hazard surface. The nozzle must be positioned anywhere along or within the perimeter of the maximum cooking area and aimed at the center of the cooking surface. See Figure 4-63.

Mesquite logs and pieces, no larger than 4 in. (102 mm) in diameter, may be protected with a maximum allowable wood depth of 6 in. (152 mm).

COOKING




FIGURE 4-63

Wok Protection

The R-102 system uses two different nozzles for the protection of woks.

- A 260 nozzle will protect a wok 14 in. (355 mm) minimum diameter up to 30 in. (762 mm) maximum diameter. The wok depth must be no less than 3.75 in. (95 mm) and no greater than 8 in. (203 mm).
- The nozzle is stamped with 260 indicating that this is a two-flow nozzle and must be counted as two flow numbers. When using this nozzle, the nozzle must be positioned as shown in Figure 4-64.

NOZZLE MUST BE POSITIONED WITHIN 1 IN. (25 mm) RADIUS
OF THE CENTER OF THE WOK, POINTED VERTICALLY DOWN

260 NOZZLE

35 – 45 IN.
(889 – 1143 mm)

MINIMUM DEPTH 3.75 IN. (95 mm)
MAXIMUM DEPTH 8 IN. (203 mm)

14 IN. (355 mm) MINIMUM DIAMETER
30 IN. (762 mm) MAXIMUM DIAMETER

FIGURE 4-64

2. A 1N nozzle will protect a wok 11 in. (279 mm) minimum diameter up to 24 in. (609 mm) maximum diameter. The wok depth must be no less than 3 in. (76 mm) and no greater than 6 in. (152 mm). The nozzle is stamped with 1N indicating that this a one-flow nozzle and must be counted as one flow number. When using this nozzle, the nozzle must be positioned anywhere along or within the perimeter of the wok, aimed at the center, 30 in. to 40 in. (762 mm to 1016 mm) above the hazard surface, as shown in Figure 4-65.

NOTICE

When using this type of wok protection, only five flow numbers are allowed on a 1.5 gal (5.7 L) system, and only eleven flow numbers are allowed on a 3 gal (11.4 L) system.




FIGURE 4-65

00026

UL EX3470 ULC EX3470

PAGE 4-28 REV. 11 2014-SEP-01

Nozzle Application Chart

The following chart has been developed to assist in calculating the quantity and type of nozzle required to protect each duct, plenum, or appliance.

NOTICE

This chart is for general reference only. See complete details for each type of hazard.

	. ,				71	
١	Hazard	Maximum Hazard Dimensions	Minimum Nozzle Quantity	Nozzle Heights	Nozzle Part No.	Nozzle Stamping – Flow No.
	Duct or Transition (Single Nozzle)	Length – Unlimited Perimeter – 50 in. (1270 mm) Diameter – 16 in. (406 mm)	1		439839	1W
	Duct or Transition (Single Nozzle)	Length – Unlimited Perimeter – 100 in. (2540 mm) Diameter – 31 7/8 in. (809 mm)	1	-	439840	2W
	Duct or Transition (Dual Nozzle)	Length – Unlimited Perimeter – 150 in. (3810 mm) Diameter – 48 in. (1219 mm)	2	-	439840	2W
	Electrostatic Precipitator (At Base of Duct)	Individual Cell	1	-	439837	1/2N
	Plenum (Horizontal Protection)	Length – 10 ft (3.0 m)	1	-	439838	1N
,	Plenum (Horizontal Protection)	Length – 6 ft (1.8 m) Width – 4 ft (1.2 m)	1	-	439839	1W
	Plenum (Vertical Protection)	Length – 4 ft (1.2 m) Width – 4 ft (1.2 m)	1	-	439839	1W
	Fryer (Split or Non-Split Vat)	Maximum Size (without drip board) 14 in. (355 mm) x 15 in. (381 mm) Low Proximity	1	13 – 16 in. (330 – 406 mm)	439845	290
	Fryer (Split or Non-Split Vat)	Maximum Size (without drip board) 14 1/2 in. (368 mm) x 14 in. (355 mm) Medium Proximity	1	16 – 27 in. (406 – 685 mm)	439845	290
	Fryer (Split or Non-Split Vat)*	Maximum Size (without drip board) 15 in. (381 mm) x 14 in. (355 mm) High Proximity Medium Proximity	1 1	27 – 47 in. 20 – 27 in.	439842 439843	230 245
	Fryer (Non-Split Vat Only)	Maximum Size (without drip board) 19 1/2 in. (495 mm) x 19 in. (482 mm) High Proximity Low Proximity	1 1	21 – 34 in. 13 – 16 in.	439841 439845	3N 290
		Maximum Size (without drip board) 18 in. (457 mm) x 18 in. (457 mm) High Proximity	1	25 – 35 in. (635 – 889 mm)	439841	3N

 $^{^{\}star}$ For multiple nozzle protection of single fryers, see detailed information on Pages 4-10 and 4-11.

Nozzle Application Chart (Continued)

NOZZIE Application Char	t (Continued)				
► Hazard	Maximum Hazard Dimensions	Minimum Nozzle Quantity	Nozzle Heights	Nozzle Part No.	Nozzle Stamping – Flow No.
Fryer (Non-Split Vat Only) (Continued)	Maximum Size (without drip board) 14 1/2 in. (368 mm) x 16.5 in. (419 mm) High Proximity	1	16 – 21 in. (406 – 533 mm)	439845	290
Fryer (Non-Split Vat Only)*	Maximum Size (with drip board) 21 in. (533 mm) x 14 in. (355 mm) (Fry Pot must not exceed 15 in. x 14 in. (381 mm x 355 mm)) High Proximity	1	27 – 47 in.	439842	230
	Medium Proximity	1	(685 – 1193 mm) 20 – 27 in. (508 – 685 mm)	439843	245
	Maximum Size (with drip board) 25 3/8 in. (644 mm) x 19 1/2 in. (495 mm) (Fry pot side must not exceed 19 1/2 in. (495 mm) x 19 in. (483 mm)				
	High Proximity Low Proximity	1	21 – 34 in. (533 – 863 mm) 13 – 16 in.	439841 439845	3N 290
	Maximum Size (with drip board) 18 in. (457 mm) x 27 3/4 in. (704 mm)	,	(330 – 406 mm)	403043	230
	High Proximity Maximum Size (with drip board) 14 1/2 in. (368 mm) x 26.5 in. (673 mm)	1	25 – 35 in. (635 – 889 mm)	439841	3N
	High Proximity	1	16 – 21 in. (406 – 533 mm)	439845	290
Fryer (Split or Non-Split Vat)	Maximum Size (with drip board) 14 in. (355 mm) x 21 in. (533 mm) Low Proximity	1	13 – 16 in. (330 – 406 mm)	439845	290
Fryer (Split or Non-Split Vat)	Maximum Size (with drip board) 14 1/2 in. (368 mm) x 26 1/2 in. (673 mm) Medium Proximity	1	16 – 27 in. (406 – 685 mm)	439845	290

 $^{^{\}star}$ For multiple nozzle protection of single fryers, see detailed information on Pages 4-10 and 4-11.

UL EX3470 ULC EX3470

PAGE 4-30 REV. 11 2014-SEP-01

Nozzle Application Chart (Continued)

Nozzie Application Cha	irt (Continued)	Minimum			Nozzle
Hazard	Maximum Hazard <u>Dimensions</u>	Nozzle Quantity	Nozzle <u>Heights</u>	Nozzle Part No.	Stamping – Flow No.
Range	Longest Side (High Proximity) 32 in. (812 mm) Area – 384 in. ² (24774 mm ²)	1	30 – 40 in. (762 – 1016 mm)	439838	1N
	Longest Side (Low Proximity) 24 in. (609 mm) Area – 432 in. ² (27870 mm ²)	1	15 – 20 in. (381 – 508 mm)	439838	1N
	Longest Side 28 in. (711 mm) Area – 336 in. ² (21677 mm ²)		40 – 48 in. (1016 – 1219 mm) (With Backshelf)	439836	1F
	Longest Side 32 in. (812 mm) Area – 384 in. ² (24774 mm ²)		30 – 40 in. (762 – 1016 mm) (With Backshelf)	439844	260
	Longest Side (High Proximity) 28 in. (711 mm) Area – 672 in. ² (43354 mm ²)	1	40 – 50 in. (1016 – 1219 mm)	439843	245
	Longest Side (Medium Proximity) 32 in. (812 mm) Area – 768 in. ² (49548 mm ²)	1	30 – 40 in. (762 – 1016 mm)	439844	260
	Longest Side (Low Proximity) 36 in. (914 mm) Area – 1008 in. ² (65032 mm ²)	2	15 – 20 in. (381 – 508 mm)	439845	290
Griddle	Longest Side (High Proximity) 48 in. (1219 mm) Area – 1440 in. ² (92903 mm ²)	1	30 – 50 in. (762 – 1270 mm) (perimeter located)	439844	260
	Longest Side (High Proximity) 30 in. (762 mm) Area – 720 in. ² (46451 mm ²)	1	30 – 50 in. (762 – 1270 mm) (center located)	439845	290
	Longest Side (High Proximity) 36 in. (914 mm) Area – 1080 in. ² (69677 mm ²)	1	35 — 40 in. (889 – 1016 mm) (perimeter located)	439838/439865	1N/1NSS
	Longest Side (Medium Proximity) 48 in. (1219 mm) Area – 1440 in. ² (92903 mm ²)	1	20 – 30 in. (508 – 762 mm) (perimeter located)	439845	290
	Longest Side (Low Proximity) 26 in. (660 mm) Area – 533 in. ² (34387 mm ²)	1	15 – 20 in. (381 – 508 mm) (center located)	439839	1W

Nozzle Application Chart (Continued)

► <u>Hazard</u>	Maximum Hazard Dimensions	Minimum Nozzle Quantity	Nozzle Heights	Nozzle Part No.	Nozzle Stamping – Flow No.
Griddle (Continued)	Longest Side (Low Proximity) 36 in. (914 mm) Area – 1080 in. ² (69677 mm ²)	1	10 – 20 in. (254 – 508 mm) (perimeter located)	439840	2W
	Longest Side (Low Proximity) 48 in. (1219 mm) Area – 1440 in. ² (92903 mm ²)	1	10 – 20 in. (254 – 508 mm) (perimeter located)	439846	2120
Chain Broiler*(Overhead Protection)	Length – 34 in. (863 mm) Width – 32 in. (812 mm)	2	10 – 26 in. (254 – 660 mm)	439839/439864	1W/1WSS
Chain Broiler (Horizontal Protection)	Length – 43 in. (1092 mm) Width – 31 in. (787 mm)	2	1 – 3 in. (25 – 76 mm)	439838/439865	1N/1NSS
► Gas-Radiant/Electric Char-Broiler	Longest Side – 36 in. (914 mm) Area – 864 in. ² (55741 mm ²)	1	15 – 40 in. (381 – 1016 mm)	439838/439865	1N/1NSS
Electric Char-Broiler	Longest Side – 34 in. (863 mm) Area – 680 in. ² (43870 mm ²)	1	20 – 50 in. (508 – 1270 mm)	439838/439865	1N/1NSS
Lava-Rock Broiler	Longest Side – 24 in. (609 mm) Area – 312 in. ² (20128 mm ²)	1	18 – 35 in. (457 – 889 mm)	439838/439865	1N/1NSS
Natural Charcoal Broiler	Longest Side – 24 in. (609 mm) Area – 288 in. ² (18580 mm ²)	1	18 – 40 in. (457 – 1016 mm)	439838/439865	1N/1NSS
Lava-Rock or Natural Charcoal Char-Broiler	Longest Side – 30 in. (762 mm) Area – 720 in. ² (46451 mm ²)	1	14 – 40 in. (355 – 1016 mm)	439841	3N
Wood Fueled Char-Broiler	Longest Side – 30 in. (762 mm) Area – 720 in. ² (46451 mm ²)	1	14 – 40 in. (355 – 1016 mm)	439841	3N
Upright Broiler/ ► Salamander	Length – 32.5 in. (825 mm) Width – 30 in. (762 mm)	2	_	439837	1/2N
Salamander Broiler	Length – 29 in. (736 mm) Width – 16 in. (406 mm)	1	_	439838	1N
	Length – 31 in. (787 mm) Width – 15 in. (381 mm)	1	_	439836	1F
	Length – 31 in. (787 mm) Width – 15 in. (381 mm)	1	_	439838	1N
Wok	14 in. – 30 in. (355 – 762 mm) Diameter 3.75 – 8.0 in. (95 – 203 mm) Deep	1	35 – 45 in. (889 – 1143 mm)	439844	260
	11 in. – 24 in. (279 – 609 mm) Diameter 3.0 – 6.0 in. (76 – 152 mm) Deep		30 – 40 in. (762 – 1016 mm)	439838/439865	1N/1NSS

 $^{^{\}star}$ Minimum chain broiler exhaust opening – 12 in. x 12 in. (305 mm x 305 mm), and not less than 60% of internal broiler size.

UL EX3470 ULC EX3470

PAGE 4-32 REV. 11 2014-SEP-01

SPECIFIC APPLICATION BY MODEL

Due to the configuration, application, and/or additional features that pose protection problems using conventional protection. noted in the guidelines previously addressed, the following appliances/applications are considered hazard specific.

The following hazard specific applications have been individually tested and listed by make and model number of the equipment designated.


Dean Industries Gas Fryer, Model 2424 GTI, 120,000 BTU/ hr. Rating

This specialized gas fryer can be protected with a combination of a 290 nozzle and a 1W nozzle for low proximity (7 3/4 - 8 in. (197 - 203 mm) nozzle height only) and two 230 nozzles (Part No. 419339) for high proximity (45 in. (1143 mm) nozzle height


The maximum dimension of the fry pot is 24 in. x 24 in. (610 mm x 610 mm).

Nozzles must be positioned and aimed as shown in Figure 4-66.

Note: For low proximity protection, see Special Piping Layout in Figure 4-67.



LOW PROXIMITY (7 3/4 - 8 IN. (196 - 203 mm) NOZZLE HEIGHT)



HIGH PROXIMITY (45 IN. (1143 mm) NOZZLE HEIGHT ONLY)

FIGURE 4-66

Dean Industries Model GTI Gas Fryer Special Piping Lavout


Section A (Tank to Hood Penetration) Piping Limitations

Maximum Length: 30 ft (9.1 m) Maximum Rise: 6 ft (1.8 m)

Maximum Number of 90° Elbows: 7 Maximum Number of Tees: 0

Section B (Hood Penetration to Nozzles) Piping Limitations

- 1. Piping configuration shall be as shown with ±1/4 in. (6 mm) tolerance on dimensions.
- 2. All nozzles shall be at the same elevation.
- 3. Each pair of appliance nozzles shall be equally spaced from left-to-right centerline of fryer.




SPECIFIC APPLICATION BY MODEL (Continued)

Far West Hospitality Products Gas Fryer, Model PAR-1-20, 63000 BTU/hr Rating

This specialized gas fryer can be protected with a single, 290 nozzle.

The maximum dimension of the fry pot is 21 in. \times 21 in. (533 mm \times 533 mm).

The 290 nozzle must be located on the front-to-rear centerline and aimed at the center of the cooking surface. See Figure 4-68.



290 NOZZLE LOCATED ON FRONT-TO-REAR CENTERLINE \pm 4.5 IN. (114 mm) FROM SIDE TO SIDE CENTERLINE AND AIMED AT CENTER OF COOKING AREA.




FIGURE 4-68

Frymaster 14 KW – 208V Electric Fryer, Model MACH 14 Series

This specialized single vat electric fryer can be protected either with a single 230 nozzle located 27 in. to 47 in. (685 mm to 1193 mm) above the top surface of the fryer or with a single 245 nozzle located 20 in. to 27 in. (508 mm to 685 mm) above the top surface of the fryer.

Either nozzle must be located anywhere along or within the perimeter of the cooking surface and aimed at the midpoint. See Figure 4-69. The maximum size of the fry pot (without drip board) is 13 3/4 in. x 16 3/4 in. (349 mm x 425 mm) and the maximum size of the cooking surface (with drip board) is 13 3/4 in. x 20 7/8 in. (349 mm x 530 mm). The vat may be divided in half to make two split vats.

230 NOZZLE TIP OR 245 NOZZLE TIP ANYWHERE ALONG OR WITHIN THE PERIMETER OF THE COOKING SURFACE AND AIMED AT THE MIDPOINT.




FIGURE 4-69

UL EX3470 ULC EX3470

PAGE 4-34 REV. 11 2014-SEP-01

SPECIFIC APPLICATION BY MODEL (Continued)

Frymaster Energy Efficient RE 14 Fryer

This electric fryer can be protected with either a single 230 nozzle located 27 to 47 in. (685 mm to 1193 mm) above the top surface of the fryer or with a single 245 nozzle located 20 to 27 in. (508 mm to 685 mm) above the top surface of the fryer.

Either nozzle must be located anywhere along or within the perimeter of the cooking surface and aimed at the midpoint. See Figure 4-70. The maximum size of the fry pot (without drip board) is $14 \times 15 \, 1/2$ in. (355 mm x 393 mm) and the maximum size of the cooking surface (with drip board) is $14 \times 20 \, 7/8$ in. (355 mm x 530 mm). The vat may be divided in half to make two split vats.

230 NOZZLE TIP OR 245 NOZZLE TIP ANYWHERE ALONG OR WITHIN THE PERIMETER OF THE COOKING SURFACE AND AIMED AT THE MIDPOINT.




FIGURE 4-70

McDonald Fryer (Nozzle Heights of Less Than 20 in. (508 mm))

When the 245 nozzle is used to protect McDonald's fryers at heights less than 20 in. (508 mm) above the top of the fryer, the following appliance and distribution piping rules shall apply:

 Each McDonald's gas or electric fryer shall be protected by one 245 nozzle. The fryer vat dimensions for one full vat or two split vats shall not exceed 14 in. x 15 in. (355 mm x 381 mm) without the dripboard and 14 in. x 21 in. (355 mm x 533 mm) with the dripboard.

The heat input rating of the fryer shall not exceed 122,000 BTU/HR.

The 245 nozzle shall be located 18 in. to 20 in. (457 mm to 508 mm) above the top of the fryer vat, 2 in. to 2 1/4 in. (51 mm to 57 mm) to the right or left of the front-to-rear vat centerline, and 0 to 3 1/4 in. (0 to 82 mm) forward of the right-to-left vat centerline, and aimed at the vat center point. See Figure 4-71.




FIGURE 4-71

0023

- The distance between the start of the first branch line and the start of the last branch line shall not exceed 79 in. (2006 mm).
- The total length of all branch lines shall not exceed 162 in. (4114 mm).
- 4. The 3 gallon agent tank shall be elevated above the connections between the supply and branch lines.
- 5. The requirements of the following table shall not be exceeded:

Requirement	Supply Line	Duct Branch Line	Plenum Branch Line	Appliance Branch Line
Pipe Size	3/8 in.	3/8 in.	3/8 in.	3/8 in.
Maximum Length		67 in. (1701 mm)		42 in. (1066 mm)
Minimum Length	81 in. (2057 mm)	4 in. (101 mm)	4 in. (101 mm)	17 in. (431 mm)
Maximum 90° Elbows	5	3	1	6
Maximum Tees	0	1	1	1
Maximum Flow Numbers	11	2	1	2
Minimum Flow Numbers	5	0	0	1/2

SPECIFIC APPLICATION BY MODEL (Continued)

Henny Penny Mono Rail Center Lift System – Models 690, 691, 692

Nozzle Type: One 1N nozzle (Upper position)
One 1F nozzle (Lower position)

Nozzle Location:

1N Nozzle (Upper position): From the Tee Block, position nozzle tip 16 in. (406 mm) up from base of fryer surface and 5 in. (127 mm) in from **right** side of appliance back shroud

1F Nozzle (Lower Position): Running down from the Tee Block to the base of the fryer, position the nozzle tip 2 in. (51 mm) from back side of fry vat, and 8 in. (203 mm) in from the **right** side of appliance back shroud


Nozzle Aiming Point:

1N Nozzle: At center point of fry vat

1F Nozzle: The 1F nozzle is a flat spray nozzle and the spray must be horizontal to that of the edge of the back lip of the fry vat

System Coverage: Each fryer requires a minimum of 3 gal (11.4 L) of ANSULEX Low pH agent discharging through the two one-flow nozzles (1N and 1F)

Note: In this application, R-102 agent storage tanks must be pressurized from a dedicated R-102 double-tank nitrogen cartridge. The cartridge utilized for this hazard-specific Henny Penny fryer protection cannot be shared with tanks intended for standard R-102 protection. Standard protection will require an expellant gas cartridge installed in another actuation device such as an AUTOMAN regulated release or regulated actuator assembly.



UL EX3470 ULC EX3470

PAGE 4-36 REV. 11 2014-SEP-01

SPECIFIC APPLICATION BY MODEL (Continued)

Henny Penny Dual Lift System – Models 580, 581, 582, 590, 591, 592, 680, 682, 691

Nozzle Type: One 1N nozzle (Upper position)
One 1F nozzle (Lower position)

Nozzle Location:

1N Nozzle (Upper position): From the Tee Block, position nozzle tip 16 in. (406 mm) up from base of fryer surface and 5 in. (127 mm) in from **left** side of appliance back shroud

1F Nozzle (Lower position): Running down from the Tee Block to the base of the fryer, position the nozzle tip 2 in. (51 mm) from back side of fry vat, and 8 in. (203 mm) in from the **left** side of appliance back shroud.

Nozzle Aiming Point:

1N Nozzle: At center point of fry vat

1F Nozzle: The 1F nozzle is a flat spray nozzle and the spray must be horizontal to that of the edge of the back lip of the fry vat


System Coverage: Each fryer requires a minimum of 3 gal (11.4 L) of ANSULEX Low pH agent discharging through the two one-flow nozzles (1N and 1F)

NOTE 1: IT IS RECOMMENDED THAT THE AGENT DISTRIBUTION HOSE KIT (PART NO. 435982) BE UTILIZED DURING SYSTEM INSTALLATION.


NOTE 2: VAT DIMENSIONS – 16 IN. (406 mm) WIDTH 20 1/4 IN. (514 mm) LENGTH

MAXIMUM LID HEIGHT ABOVE VAT –

28 1/2 IN. (724 mm) DEPTH



Note: In this application, R-102 agent storage tanks must be pressurized from a dedicated R-102 double-tank nitrogen cartridge. The cartridge utilized for this hazard-specific Henny Penny fryer protection cannot be shared with tanks intended for standard R-102 protection. Standard protection will require an expellant gas cartridge installed in another actuation device such as an AUTOMAN regulated release or regulated actuator assembly.



Note: In this application, R-102 agent storage tanks must

be pressurized from a dedicated R-102 double-tank nitrogen

cartridge. The cartridge utilized for this hazard-specific Henny

Penny fryer protection cannot be shared with tanks intended for standard R-102 protection. Standard protection will require

an expellant gas cartridge installed in another actuation device

such as an AUTOMAN regulated release or regulated actuator

SPECIFIC APPLICATION BY MODEL (Continued)

Henny Penny Dual Lift System - Model PXE-100

Nozzle Type: One 1N nozzle (Upper position) One 1F nozzle (Lower position)

Nozzle Location:

1N Nozzle (Upper position): From the Tee Block, position nozzle tip 16.75 in. (425 mm) up from base of fryer surface and 1.75 in. (44 mm) in from **right** side of appliance back shroud

1F Nozzle (Lower position): Running down from the Tee Block to the base of the fryer, position the nozzle tip 2 in. (51 mm) up from the base of the fryer surface, and 2.25 in. (57 mm) in from the **right** side of appliance back shroud

Nozzle Aiming Point:

1N Nozzle: At center point of fry vat

1F Nozzle: The 1F nozzle is a flat spray nozzle and the spray must be horizontal to that of the edge of the back lip of the fry vat


System Coverage: Each fryer requires a minimum of 3 gal (11.4 L) of ANSULEX Low pH agent discharging through the two one-flow nozzles (1N and 1F)


NOTE 1: IT IS RECOMMENDED THAT THE AGENT DISTRIBUTION HOSE KIT (PART NO. 435982) BE UTILIZED DURING SYSTEM INSTALLATION.

NOTE 2: VAT DIMENSIONS -

14.93 IN. (379 mm) WIDTH 20.55 IN. (522 mm) LENGTH 17.42 IN. (442 mm) DEPTH

HEAT OUTPUT - 17kW





assembly.




FIGURE 4-74

UL EX3470 ULC EX3470

PAGE 4-38 REV. 11 2014-SEP-01

SPECIFIC APPLICATION BY MODEL (Continued)

Pitco SPINFRESH Fryer – Models MEII, MGII, SE14, SE14R, SE14X, SG144S, SG14RS, SEH50, SEH5017, SGH50, SGH5017, SSH55, SSH55R

Nozzle Quantity/Type: Two 2120 nozzles

- One Agent Distribution Hose and Restraining Cable Kit (Part No. 435982) must be utilized for each fryer (see Figure 4-78)
- The 3/8 in. Quik-Seal mechanical bulkhead fitting (Part No. 77285) must be utilized for the connections through fryer cover.
- Nozzle must be installed with the standard Metal Blow-Off Cap (Part No. 439861) or the Stainless Steel Blow-Off Cap (Part No. 439866).
- Fryer electrical power source must be connected for electrical shutdown upon system actuation through the use of the ANSUL R-102 Snap Action Switch Kit (Part Nos. 423878-423881).

THE THE

NOZZLE CROSS SECTION VIEW




FIGURE 4-76

FRYER FLUE





FIGURE 4-77


FIGURE 4-75



SPECIFIC APPLICATION BY MODEL (Continued)

BELSHAW Century Fryers – Models C100, C200, C200G, C300G, C400, C400G, C600, C600G

- · Nozzle Type: 3N nozzle
- Nozzle Spacing: 11.5 in. (292 mm) maximum from end of fryer and 25.5 in. (647 mm) maximum on centers
- · Nozzle Height: 35 in. (889 mm) above top of appliance
- · Nozzle Position: 2 in. (51 mm) in from inside edge of fry vat
- · Nozzle Aiming Point: Along the centerline of fry vat






FIGURE 4-79

BELSHAW Century Fryers

Specifications		C100	C200	C200G	C300G	C400	C400G	C600	C600G
Fryer Vat Size									
Length:	Inches	65	65	65	65	122.25	122	122.25	122
	(mm)	(1651)	(1651)	(1651)	(1651)	(3105)	(3099)	(3105)	(3099)
Width:	Inches	12	20	20	31.25	20.25	21.25	31	31.25
	(mm)	(305)	(508)	(508)	(794)	(514)	(540)	(787)	(794)
Depth:	Inches	5.25	5.25	9.75	9.75	6.25	11.25	7.12	11.00
	(mm)	(133)	(133)	(248)	(248)	(159)	(286)	(181)	(279)
BTU Rating: K		_	_	188	200	_	350	_	360
Vat Oil Capacity:	Lb	110	188	346	700	478	600	675	1250
	(kg)	(49.8)	(85.2)	(156.9)	(317.5)	(216.8)	(272.1)	(306.1)	(566.9)

UL EX3470 ULC EX3470

PAGE 4-40 REV. 11 2014-SEP-01

SPECIFIC APPLICATION BY MODEL (Continued) Dunkin Donuts Fryer Model DD400CGF

· Nozzle Type: 3N nozzle

· Nozzle Spacing: 11.5 in. (292 mm) maximum from end of


fryer and 25.5 in. (647 mm) maximum on

centers

• Nozzle Height: 35 in. (889 mm) above top of appliance

· Nozzle Position: 2 in. (51 mm) in from inside edge of fry vat

· Nozzle Aiming Point: Along the centerline of fry vat




Fryer Specifications:

· Vat Size:

Length: 122 in. (3098 mm) Width: 31.3 in. (795 mm) Depth: 11 in. (279 mm)

• BTU Rating: 360k

Vat Oil Capacity:
 1250 lb (566.9 kg)



► Krispy Kreme Fryers – Models 55M, 65 D/H, 110 D/H, 110M,

▶ 150 D/H, 220M, 270 D/H, 600 D/H, and 1000 D/H

Nozzle Type: 3N nozzle

Nozzle Spacing: 11.5 in. (292 mm) maximum from end of

fryer and on maximum 25.5 in. (647 mm)

centers

Nozzle Height: 35 in. (889 mm) above top of appliance **Nozzle Position:** 2 in. (51 mm) from inside edge of fry vat

Nozzle Aiming Point: Along centerline of fry vat

Note: Figure 4-81 shows maximum size fryer (Model 1000 D/H). Smaller size fryers (Models 150 D/H, 270 D/H, and 600 D/H) can be protected with less nozzles but nozzle spacings, height requirements, and positions, must be maintained as shown in Figure 4-81.




FIGURE 4-80

FIGURE 4-81

SPECIFIC APPLICATION BY MODEL (Continued)

Garland Electric Dual-Side Clamshell Broiler – Model CXBE12

Nozzle Quantity/Type: One 1N nozzle

Nozzle Height: 12 in. (304.8 mm) to 15 in. (381 mm) above

lower cooking surface

Nozzle Location: 1 in. (26 mm) from side of appliance at


12 in. (304.8 mm) up

1 in. (26 mm) to 3 in. (76 mm) from side of

appliance at 15 in. (381 mm) up

See Figure 4-82

Nozzle Aiming Point: Center of lower cooking surface







FIGURE 4-82


UL EX3470 ULC EX3470

PAGE 4-42 REV. 11 2014-SEP-01

SPECIFIC APPLICATION BY MODEL (Continued) DUKE Chain Broiler – Model FBB-High Proximity DUKE Chain Broiler With or Without Catalyst View:

- ▶ · Nozzle Quantity/Type: One 290 nozzle
- Nozzle Height: 15 to 20 in. (381 to 508 mm) above top of appliance
- Nozzle Location: Centered 6 1/2 in. (165 mm) back from front feed edge of appliance. Nozzle must be oriented to spray onto impedance plate.
- · Nozzle Aiming Point: Aimed at center of impedance plate





DUKE Chain Broiler With or Without Catalyst View Exhaust Deflector Size – 6.25 in. (159 mm) x 26.75 in. (679 mm):

- Nozzle Quantity/Type: Two 245 nozzles
- Nozzle Height: 8 in. to 15 in. (203 mm to 381 mm) above top of appliance.
- Nozzle Location: 6.5 in. (165 mm) from front or back edge of hazard


First nozzle positioned 17.25 in. (438 mm) from right side of broiler (facing broiler)

Second nozzle positioned 15 in. (381 mm) from first nozzle

Nozzle must be oriented to spray onto impedance plate.

· Nozzle Aiming Point: Aimed at at center of impedance plate

Note: If the deflector or flue gas diverter is rotated 180 degrees, the nozzles must also rotate to discharge into the opening.






FIGURE 4-84

FIGURE 4-83

SPECIFIC APPLICATION BY MODEL (Continued)

DUKE Electric Broiler - Model FBB - High Proximity

DUKE Electric Broiler with or without Catalyst View

Nozzle Quantity/Type: Two 1N nozzles

Nozzle Height: 18 in. (457 mm)

Nozzle Location: 6.5 in. (165 mm) from edge of appliance that

impedance plate is angled toward

First nozzle positioned 5 in. (127 mm) to left


of opening centerline

Second nozzle positioned 5 in. (127 mm) to

right of opening centerline

See Figure 4-85

Nozzle Aiming Point: Aimed at center of opening






FIGURE 4-85

DUKE Electric Broiler – Model FBB – High Proximity DUKE Electric Broiler without Catalyst View

► Nozzle Quantity/Type: One 290 nozzle


▶ Nozzle Height: 15 to 20 in. (381 to 508 mm)

Nozzle Location: 6.5 in. (165 mm) from edge of appliance that

impedance plate is angled toward

See Figure 4-86

Nozzle Aiming Point: Aimed at center of opening






FIGURE 4-86

UL EX3470 ULC EX3470

PAGE 4-44 REV. 11 2014-SEP-01

SPECIFIC APPLICATION BY MODEL (Continued)

DUKE Electric Broiler - Model FBB - Low Proximity

DUKE Electric Broiler with or without Catalyst View

Nozzle Quantity/Type: Two 245 nozzles

Nozzle Height: 8 in. (203 mm) to 15 in. (381 mm)

Nozzle Location: 6.5 in. (165 mm) from edge of appliance that


impedance plate is angled toward

First nozzle positioned 17.5 in. (444 mm) from right side of broiler (facing broiler)

Second nozzle positioned 15 in. (381 mm) from first nozzle

See Figure 4-87

Nozzle Aiming Point: Aimed at center of opening







FIGURE 4-87


Nieco Broiler Model 940, 962 or 960 With Catalytic Converter Protection

Note: Nieco broilers without catalytic converters use standard chain broiler protection options.

Certain models of the Nieco broiler (Models 940, 962, and 960) are equipped with a catalytic converter to comply with new clean air laws. Because of the converter, it is necessary to protect these broilers in a special way. The guidelines for protecting these broilers are as follows:

- The maximum internal broiling area is 29 in. x 23.5 in. (737 mm x 596 mm).
- An R-102 3-gallon system with a maximum of six flow numbers, must be used for protection of each broiler, including plenum and duct.
- Each individual broiler must be protected with a minimum of two 1N nozzles. The nozzles must be located as shown in Figure 4-88.
- The broiler must be fitted with two 1 in. (25 mm) high agent barriers on the angled surface of the broiler. If these have not been completed by the equipment supplier, they must be added in the field.






SPECIFIC APPLICATION BY MODEL (Continued)

Nieco Broiler - Model 950, 960, 980, 1424

- · Nozzle Quantity/Type: One 2W nozzle
- Nozzle Height: 20 in. (508 mm) above top of appliance. See Figure 4-89a.
- Nozzle Location: 6 1/2 in. (165 mm) back from front edge of appliance. See Figure 4-89a.
- Nozzle Aiming Point: Aimed at center of opening. See Figure 4-89a

Nieco Broiler – Model 950, 960, 980, 1424 (with Catalytic Converter)

- · Nozzle Quantity/Type: Two 2W nozzles
- Nozzle Height: 20 in. (508 mm) above top of appliance. See Figure 4-89b.
- Nozzle Location: 6 1/2 in. (165 mm) back from front edge of appliance. See Figure 4-89b.
- Nozzle Aiming Point: Aimed at center of opening. See Figure 4-89b – Side View.
- Nozzle Aiming Point: Aimed at point 3 in. (76 mm) each side of center. See Figure 4-89b – Front View.



Nieco Broiler – Model 9015 (With or Without Catalytic Converter)

- Nozzle Quantity/Type: Two 2W nozzles
- Nozzle Height: 20 in. (508 mm) above top of appliance. See Figure 4-90.
- Nozzle Location for Large Chamber: 6 1/2 in. (165 mm) back from front edge of appliance. See Figure 4-90.
- Nozzle Location for Small Chamber: Nozzle to be located 6 1/2 in. (165 mm) back from front edge of appliance and 12 in. (305 mm) over from large chamber nozzle.
- Nozzle Aiming Point for Large Chamber: Aimed at center of opening. See Figure 4-90.
- Nozzle Aiming Point for Small Chamber: Nozzle to be aimed 12 in. (305 mm) over from large chamber nozzle aiming point.




FIGURE 4-90


UL EX3470 ULC EX3470

PAGE 4-46 REV. 11 2014-SEP-01

SPECIFIC APPLICATION BY MODEL (Continued)

Nieco Broiler – Model 9025 (With or Without Catalytic Converter)

- · Nozzle Quantity/Type: Two 2W nozzles
- Nozzle Height: 20 1/2 in. (520 mm) above top of appliance.
 See Figure 4-91.
- Nozzle Location: 6 1/2 in. (165 mm) back from front edge of appliance. See Figure 4-91.
- Nozzle Aiming Point: Aimed at center of each opening. See Figure 4-91.







FIGURE 4-91

Nieco Broiler – Model MPB94 and MPB84 – High Proximity (With or Without Catalytic Converters)

- · Nozzle Quantity/Type: One 2W nozzle
- Nozzle Height: 20 in. (508 mm) above top of converter. See Figure 4-92.
- Nozzle Location: Centered 6 1/2 in. (165 mm) back from any edge of the appliance. See Figure 4-92.
- Nozzle Aiming Point: Aimed at center of opening. See Figure 4-92.






FIGURE 4-92

SPECIFIC APPLICATION BY MODEL (Continued)

Nieco Broiler – Model MPB94 – Low Proximity (With or Without Catalytic Converter)

Nozzle Quantity/Type: Two 245 nozzles

Nozzle Height: 8 in. to 15 in. (203 mm to 381 mm) measured

from top of converter

Nozzle Location: 6.5 in. (165 mm) from front or back edge of

hazard.

First nozzle positioned 7.5 in. (190 mm) to


the right from center of hazard.

Second nozzle positioned 7.5 in. (190 mm) to

the left from center of hazard.

See Figure 4-93.

Nozzle Aiming Point: Aimed at opening on respective center lines






FIGURE 4-93

Nieco Broiler – Model MPB84 – Low Proximity (With Catalytic Converter)

Nozzle Quantity/Type: Two 245 nozzles

Nozzle Height: 8 in. to 15 in. (203 mm to 381 mm) measured

from top of converter

Nozzle Location: 6.5 in. (165 mm) from front or back edge of

hazard.

First nozzle positioned 7.5 in. (190 mm) to


the right from center of hazard.

Second nozzle positioned 7.5 in. (190 mm) to

the left from center of hazard.

See Figure 4-94.

Nozzle Aiming Point: Aimed at opening on respective center lines






FIGURE 4-94

UL EX3470 ULC EX3470

PAGE 4-48 REV. 11 2014-SEP-01

SPECIFIC APPLICATION BY MODEL (Continued)

Nieco Broiler – Model MPB84 and MPB94 – High Proximity (With Perforated Cap OR with Catalytic Converter and Chimney)

Nozzle Quantity/Type: Two 1N nozzles

Nozzle Height: 18 in. (457 mm) to 20 in. (508 mm)

Nozzle Location: 6.5 in. (165 mm) from front or back edge of

hazard

First nozzle positioned 5 in. (127 mm) to left


of opening centerline

Second nozzle positioned 5 in. (127 mm) to

right of opening centerline

See Figure 4-95

Nozzle Aiming Point: Aimed at center of opening






FIGURE 4-95

Nieco Broiler – Model MPB84 and MPB94 – Low Proximity (With Perforated Cap OR with Catalytic Converter and Chimney)

Nozzle Quantity/Type: Two 245 nozzles

Nozzle Height: 8 in. (203 mm) to 15 in. (381 mm)

Nozzle Location: 6.5 (165 mm) from front or back edge of

hazard

First nozzle positioned 7.5 in. (190 mm) to the


right of hazard centerline

Second nozzle positioned 7.5 in. (190 mm) to

the left of hazard centerline

See Figure 4-96

Nozzle Aiming Point: Aimed at center of opening






FIGURE 4-96

SPECIFIC APPLICATION BY MODEL (Continued)

Nieco Broiler - Model JF94E Electric Broiler - High

Proximity (With Catalyst)

Nozzle Quantity/Type: Two 230 nozzles


Nozzle Height: 20 in. (508 mm)

Nozzle Location: 6 1/2 in. (165 mm) from front or back edge of

Nozzles positioned 15 in. (381 mm) apart

See Figure 4-97

Nozzle Aiming Point: Center of catalyst



SIDE VIEW




FIGURE 4-97

Nieco Broiler - Model JF94E Electric Broiler - Low **Proximity (With Catalyst)**

Nozzle Quantity/Type: Two 245 nozzles

Nozzle Height: 8 in. (203 mm) to 15 in. (381 mm)


Nozzle Location: 6 1/2 in. (165 mm) from front or back edge of

hazard

Nozzles positioned 15 in. (381 mm) apart

See Figure 4-98

Nozzle Aiming Point: Center of catalyst






FIGURE 4-98

UL EX3470 ULC EX3470

PAGE 4-50 REV. 11 2014-SEP-01

SPECIFIC APPLICATION BY MODEL (Continued)

 Nieco Jet Flow Automatic Chain Broilers – Models JF62, JF63, JF92, JF93, JF143 (With or Without Catalyst)

Nozzle Quantity/Type: One 245 nozzle


Nozzle Height: 20 in. (508 mm) to 25 in. (635 mm)

Nozzle Location: Centered above the catalyst to 5 in. (127 mm)

forward of catalyst front edge

See Figure 4-99a

Nozzle Aiming Point: Center of catalyst






FIGURE 4-99a

 Nieco Jet Flow Automatic Chain Broilers – Models JF64G, JF84G, JF94G – High Proximity (With or Without Catalyst)

Nozzle Quantity/Type: Two 230 nozzles

Nozzle Height: 20 in. (508 mm)


Nozzle Location: 6.5 in. (165 mm) from front or back edge of

hazard

Nozzles positioned 15 in. (381 mm) apart

See Figure 4-99b

Nozzle Aiming Point: Center of catalyst front to back; 6 in. (152 mm) in from each side of catalyst



2014-SEP-01

REV. 11

PAGE 4-50.1

SPECIFIC APPLICATION BY MODEL (Continued)

Nieco Jet Flow Automatic Chain Broilers – Models JF64G, JF84G, JF94G – Low Proximity, Nozzles Rear-Mounted Facing Forward (With or Without Catalyst)

Nozzle Quantity/Type: Two 245 nozzles

Nozzle Height: 8 in. (203 mm) to 15 in. (381 mm)

Nozzle Location: 6.5 in. (165 mm) from back edge of hazard

Nozzles positioned 15 in. (381 mm) apart

See Figure 4-99c

Nozzle Aiming Point: 4 in. (102 mm) from back edge of catalyst; 6 in. (152 mm) in from each side of

15 IN. (381 mm) SPACING CENTERED OVER CATALYST / AIMED 6 IN. AIMED 6 IN. (152 mm) FROM SIDE OF (152 mm) FROM SIDE OF CATALYST CATALYST 8 IN TO 15 IN AIMED 4 IN. (102 mm) (203 mm to 381 mm) FROM BACK NOZZLE HEIGHT OF CATALYST 6.5 IN. (165 mm) FROM EDGE OF APPLIANCE

 Nieco Jet Flow Automatic Chain Broilers – Models JF64G, JF84G, JF94G – Low Proximity, Nozzles Front-Mounted Facing Rearward (With or Without Catalyst)

Nozzle Quantity/Type: Two 245 nozzles

Nozzle Height: 8 in. (203 mm) to 15 in. (381 mm)

Nozzle Location: 6.5 in. (165 mm) from front edge of hazard

Nozzles positioned 15 in. (381 mm) apart

See Figure 4-99d

Nozzle Aiming Point: Center of catalyst front to back; 6 in. (152 mm) in from each side of

catalyst




FIGURE 4-99c

UL EX3470 ULC EX3470

PAGE 4-50.2 REV. 11 2014-SEP-01

PAGE INTENTIONALLY LEFT BLANK

SPECIFIC APPLICATION BY MODEL (Continued)

Bakers Pride Broiler – Models CH6, CH8, CH10, XX6, XX8, XX10 (With Wood Smoker Box and Chip Holders)

Nozzle Quantity/Type: Two 3N nozzles

Nozzle Height: 25 in. (635 mm) to 40 in. (1016 mm) above the

hazard surface

Nozzle Location: Each nozzle is to protect half of the cooking

area and located within 1 in. (25 mm) of the center of the respective cooking area, aimed

at the center of that hazard area

See Figure 4-100

Note: Smoker Box and Chip Holders cannot exceed logs 4 in. (101 mm) in diameter and a maximum allowable wood depth of 4 in. (101 mm).




FIGURE 4-100

Magikitch'n Gas Radiant Char-Broiler with Smoker Box
 Models FM-RMB-660, FM-RMB-648, FM-RMB-636 (With Wood Smoker Box and Chip Holders)

Nozzle Quantity/Type: Three 3N nozzles

Nozzle Height: 25 in. (635 mm) to 40 in. (1016 mm) above the

broiler surface


 $\textbf{Nozzle Location:} \ \, \textbf{All three nozzles are to be centered front to} \\$

back above the broiling surface. The middle nozzle is to be centered left to right above the broiling surface. The remaining two nozzles are to be located 9 in. (229 mm) inside the

broiler sides.

See Figure 4-101

Note: Smoker Box and Chip Holders cannot exceed logs 4 in. (101 mm) in diameter and a maximum allowable wood depth of 4 in. (101 mm).



UL EX3470 ULC EX3470

PAGE 4-52 REV. 11 2014-SEP-01


SPECIFIC APPLICATION BY MODEL (Continued)

Marshall Air - Model 2001BK Multi-Chamber Broiler

- · Nozzle Quantity/Type: Two 1W nozzles
- Nozzle Location: Front nozzle tip must be located 14 in. (355 mm) directly above the appliance, aligned with the front face and centerline of the catalytic converter. The aim point is 4 in. (101 mm) forward of the front edge of the converter on the centerline.

The rear nozzle tip is a mirror image of the front. The rear nozzle is located 14 in. (355 mm) vertically above the appliance, aligned with the "rear" face and centerline of the catalytic converter. The aim point is 4 in. (101 mm) behind the "rear" edge of the converter on the centerline. See Figure 4-102.

System Limitation: Maximum of five flows for a 3.0 gallon system: Remaining flow points available may be used to protect other hazards.



NOZZLE ALIGNED WITH FRONT OF CONVERTER




FIGURE 4-102

Marshall Air Electric Broiler - Model FR14B AutoBroil

Nozzle Quantity/Type: One 260 Nozzle

15 - 20 in. (381 - 508 mm) above the **Nozzle Height:**

top of the broiler

Nozzle Location: The nozzle must be centered above the

front edge of the broiler

Nozzle Aiming Point: Aimed at the center of the exhaust

opening of the broiler. See Figure

4-103.





FIGURE 4-103

Grease Grabber-80™ Two Stage Filtration System

The Grease Grabber-80 Two Stage Filtration System consists of two components: The primary filter (The Grease-X Tractor) and the secondary filter (The Grease Grabber-80).

The protection required for this application is the same as the standard plenum/filter protection: One 1N nozzle protecting 10 (3.0 m) linear feet of plenum length by 4 ft (1.2 m) of plenum chamber depth (width), positioned 2 in. to 4 in. (51 mm to 102 mm) from peak of secondary filter. See Figure 4-104.



NOTE: TWO NOZZLES MUST BE UTILIZED FOR V-BANK FILTER

ARRANGEMENT.

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 4-53

OVERLAPPING NOZZLE COVERAGE

Overlapping Coverage - Option 1

For each group of protected appliances under a common hood(s), the overlapping nozzles must be located from right to left so that each end nozzle is located a maximum of 6 in. (152 mm) inside the outside edge of the cooking hazard of each end appliance, and the inside overlapping nozzles must be located between the two end nozzles at a maximum spacing of 12 in. (304 mm).

Hazard Zone

The hazard zone is defined as a theoretical, flat and level, rectangular surface, that includes all of the cooking hazards of the protected appliances under a common hood(s). The purpose of the hazard zone is to provide a means of locating the appliances and the overlapping nozzles, as well as aiming the overlapping nozzles. The hazard zone measures 28 in. (711 mm) deep by the length of the cooking hazard(s). The centerline of the hazard zone must bisect the 28 in. (711 mm) depth (from front to back) and run from right-to-left for the full width of the hazard zone.

Overlapping Nozzle Appliance Protection

Overlapping Nozzle Appliance Protection is defined as protection of cooking appliances by nozzles spaced uniformly at uniform elevations under a common hood(s). Overlapping protection of appliances is continuous for the full length of the hood or divided when group(s) of protected appliances are separated by counters or appliances not requiring protection.

Full hood continuous protection is defined as overlapping nozzle appliance protection that covers the appliance line-up located under the total hood length. All appliances requiring protection are the appliances under the hood that can be an ignition source of grease in the hood, grease removal device or the duct.

Group protection is defined as overlapping nozzle appliance protection that protects individual hazard zones located under a common hood. These "groups" of appliances may be separated by appliances not requiring protection, such as steam equipment or work tables, or by dedicated appliance protection, such as salamander broilers.

See Figure 4-108 (full hood continuous protection) and Figure 4-109 (multiple group protection).

Dedicated Nozzle Appliance Protection

Appliance protection using dedicated nozzle coverage is defined as protection of cooking appliances with enclosed cooking hazards, such as upright broilers, which cannot be protected with overlapping nozzles and therefore must be protected with nozzles dedicated to the appliance.

General Design Limitations

- · Maximum depth of zone is 28 in. (711 mm).
- The 245 nozzle is the only approved nozzle for overlapping (zone) protection.
- Nozzle must be located 0 in. to 6 in. (0 mm to 152 mm) forward of zone centerline, aimed back at the zone centerline.
- Nozzles must be spaced a maximum of 6 in. (152 mm) from each end of hazard and then a maximum of 12 in. (304 mm) on center for the remaining overlapping nozzles until the complete hazard is covered.

- For appliance hazard surfaces with listed protection exceeding the standard hazard zone of 28 in. (711 mm) in depth, the hazard surface(s) must be aligned with the back edge of the hazard zone, with the front edge overhanging the front edge of the zone. See Appliance Chart, Table 4-1.
- For appliance hazard surfaces that exceed the listed protection sizes, multiple zones must be utilized. Align entire hazard surface area within the multiple zones.
- All hood, duct, individual appliance, piping, and flow limitations are as specified in the R-102 Design, Installation, Recharge and Maintenance Manual (Part No. 418087).
 - All appliance protection currently listed in the R-102 Design Manual (Part No. 418087) is also approved protection. Zone protection can be considered optional protection.

Maximum Cooking Hazard

TABLE 4-1
Overlapping Nozzle Coverage (Zone Protection)

Appliance Type

Appliance Type Illiax		waxiiiiuiii Cookiiig Hazaiu
	Fryer	34 in. (863 mm) Deep x 5.8 ft ² (0.5 m ²)
	Griddle	30 in. (762 mm) Deep x Unlimited Length
	Range	28 in. (711 mm) Deep x Unlimited Length
	Wok, Maximum	30 in. (762 mm) Diameter x 8 in. (203 mm) Deep
	Wok, Minimum	11 in. (279 mm) Diameter x 3 in. (76 mm) Deep
	Braising Pan/Tilt Skillet*	34 in. (863 mm) Deep x Unlimited Length
	Lava Rock Char-Broiler	32 in. (812 mm) Deep x Unlimited Length
	Charcoal Broiler	32 in. (813 mm) Deep x Unlimited Length (4 in. (102 mm) Maximum Fuel Depth)
	Mesquite Wood Broiler	32 in. (812 mm) Deep x Unlimited Length (12 in. (304 mm) Maximum Fuel Depth)
	Gas Radiant Char-Broiler	36 in. (914 mm) Deep x Unlimited Length

Electric Char-Broiler 34 in. (863 mm) Deep x 20 in. (508 mm)

* See Figure 4-105 for nozzle location




FIGURE 4-105

UL EX3470 ULC EX3470

PAGE 4-54 REV. 11 2014-SEP-01


OVERLAPPING NOZZLE COVERAGE (Continued)

Overlapping Appliance Nozzle and Hazard Zone Locations

- 1. All overlapping appliance nozzles must be the 245 nozzle and must be located under a common hood at the same height above the hazard zone, in a straight line from right to left and aimed at the centerline of the hazard zone. The overlapping nozzle is used for both continuous overlapping and multiple group overlapping protection.
- 2. The hazard zone must be positioned (located) so that all appliance hazard surfaces are within the zone. For appliance hazard surfaces with listed protection exceeding the standard hazard zone size of 28 in. (711 mm) in depth (see Table 1), the hazard surface(s) must be aligned with the back edge of the hazard zone, with the front edge overhanging the front of the zone.
- 3. The overlapping appliance nozzles must be located 40 in. to 45 in. (1016 mm to 1143 mm) above the top surface of the protected appliances. See Figure 4-107.

Exception No. 1: Nozzle dimensions for wok protection are measured to bottom of wok. Exception No. 2: When using overlapping appliance nozzles in areas where there is a back shelf, the nozzle cannot be positioned in the shaded area as shown in Figure 4-106.

Also, back shelf must not extend more than 11 in. (279 mm) over the hazard zone and cannot be less than 20 in. (508 mm) above the hazard zone. See Figure 4-106.



006914

4. The overlapping appliance nozzles must be located 0 in. to 6 in. (0 mm to 152 mm) forward of the centerline or aimline of the selected hazard zone. See Figure 4-107.




FIGURE 4-107

006915

OVERLAPPING NOZZLE COVERAGE (Continued)

Overlapping Appliance Nozzle and Hazard Zone Locations – Group Protection

 For each group of protected appliances under a common hood(s), the overlapping nozzles must be located from right to left so that each end nozzle is located a maximum of 6 in. (152 mm) inside the outside edge of the cooking hazard of each end appliance, and the inside overlapping nozzles must be located between the two end nozzles at a maximum spacing of 12 in. (304 mm). See Figures 4-108 and 4-109.




FIGURE 4-108





FIGURE 4-109

00172

2. When obstructions are located adjacent to appliance(s) protected by overlapping nozzles, the overlapping appliance nozzle spacing must start with the appliance(s) adjacent to the obstruction. See Figure 4-110.



3. When an appliance requires dedicated protection with a protected area intended for overlapping appliance nozzle protection, the group protection option will be required for appliances on either side of the appliances using dedicated protection. Group protection using overlapping appliance nozzles must begin with the protected appliance(s) adjacent to the dedicated appliance protected. An overlapping appliance nozzle(s) must be positioned within 6 in. (152 mm) of the edge(s) of the appliance hazard surface area(s) adjacent to the dedicated nozzle protection. See Figure 4-111.




FIGURE 4-111

00175

UL EX3470 ULC EX3470

PAGE 4-56 REV. 11 2014-SEP-01

OVERLAPPING NOZZLE COVERAGE (Continued)

Overlapping Appliance Nozzle and Hazard Zone Locations – Group Protection (Continued)

4. On protected appliances, all hazard surfaces located in a group must be within 40-45 in. (1016-1143 mm) from the nozzle(s). Once that dimension is exceeded, a new group must be started. See Figure 4-112.

Note: The supply pipe feeding nozzle groups is to be at the same elevation. Adjust height for each group only by varying lengths of nozzle drops.




FIGURE 4-112

006917

Detection Requirements For Overlapping Appliance Protection

When utilizing overlapping appliance protection, fusible link detectors must be installed on a maximum of 2 ft (0.6 m) centers, starting with detectors located in (under) the duct opening(s).

Starting from the detector under the duct opening, add detectors on 2 ft (0.6 m) maximum spacing until the complete length of the plenum area is covered, from one end to the other. The location of the last detector on each end of the plenum must not exceed 2 ft (0.6 m) from end of plenum.

Note: Standard detector coverage, as specified in "Design Section," is acceptable when utilizing dedicated nozzle coverages.

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 4-57

OVERLAPPING NOZZLE COVERAGE (Continued)

Overlapping Coverage - Option 2

For each group of protected appliances under a common hood(s), the overlapping nozzles must be located from right to left so that each end nozzle is located a maximum of 11.5 in. (292 mm) inside the outside edge of the cooking hazard of each end appliance, and the inside overlapping nozzles must be located between the two end nozzles at a maximum spacing of 25.5 in. (647 mm).

Hazard Zone

The hazard zone is defined as a theoretical, flat and level, rectangular surface, that includes all of the cooking hazards of the protected appliances under a common hood(s). The purpose of the hazard zone is to provide a means of locating the appliances and the overlapping nozzles, as well as aiming the overlapping nozzles. The hazard zone measures 28 in. (711 mm) deep by the length of the cooking hazard(s). The centerline of the hazard zone must bisect the 28 in. (711 mm) depth (from front to back) and run from right-to-left for the full width of the hazard zone.

Overlapping Nozzle Appliance Protection

Overlapping Nozzle Appliance Protection is defined as protection of cooking appliances by nozzles spaced uniformly at uniform elevations under a common hood(s). Overlapping protection of appliances is continuous for the full length of the hood or divided when group(s) of protected appliances are separated by counters or appliances not requiring protection.

Full hood continuous protection is defined as overlapping nozzle appliance protection that covers the appliance line-up located under the total hood length. All appliances requiring protection are the appliances under the hood that can be an ignition source of grease in the hood, grease removal device or the duct.

Group protection is defined as overlapping nozzle appliance protection that protects individual hazard zones located under a common hood. These "groups" of appliances may be separated by appliances not requiring protection, such as steam equipment or work tables, or by dedicated appliance protection, such as salamander broilers.

See Figure 4-116 (full hood continuous protection) and Figure 4-117 (multiple group protection).

Dedicated Nozzle Appliance Protection

Appliance protection using dedicated nozzle coverage is defined as protection of cooking appliances with enclosed cooking hazards, such as upright broilers, which cannot be protected with overlapping nozzles and therefore must be protected with nozzles dedicated to the appliance.

General Design Limitations

- If overlapping appliance protection is mixed with dedicated appliance protection on the same pipe system, THE OVERLAPPING APPLIANCE PROTECTION PIPING BEOUIREMENTS MUST BE FOLLOWED.
- Overlapping protection requires the use of 3.0 gal (11.4 L) tank(s) and a maximum of six flows per tank.
- In installations using tanks only intended for overlapping protection, a single Double Tank nitrogen expellant gas cartridge can be utilized with up to three 3.0 gal (11.4 L) tanks.
- In installations using both overlapping protection and conventional non-overlapping protection (ex. hood/duct or dedicated appliance protection), a single Double Tank nitrogen expellant gas cartridge can be utilized with up to three 3.0 gal (11.4 L) tanks, as long as none of the 3.0 gal (11.4 L) tanks exceed a total flow output of more than six flows.
- If more than six flows will be used in a conventional non-overlapping tank, it cannot share the same cartridge as tanks intended for overlapping protection. In this case, an additional Regulated Actuator Assembly with another expellant gas cartridge will be required.
- The 245 nozzle must be used for "end of zone" protection.
- The 260 nozzle must be used for zone protection.
- · Maximum depth of zone is 28 in. (711 mm).
- Refer to overlapping system piping requirements listed in Table 4-2.
- Nozzle must be located 0 in. to 12 in. (0 mm to 304 mm) forward of zone centerline, aimed back at the zone centerline.
- Nozzles must be spaced a maximum of 11.5 in. (292 mm) from each end of hazard and then a maximum of 25.5 in. (647 mm) on center for the remaining overlapping nozzles until the complete hazard is covered.
- For appliance hazard surfaces with listed protection exceeding the standard hazard zone of 28 in. (711 mm) in depth, the hazard surface(s) must be aligned with the back edge of the hazard zone, with the front edge overhanging the front edge of the zone. See Appliance Chart, Table 4-1.
- For appliance hazard surfaces that exceed the listed protection sizes, multiple zones must be utilized. Align entire hazard surface area within the multiple zones.
- All hood, duct, and individual appliance protection are as specified in the R-102 Design, Installation, Recharge and Maintenance Manual (Part No. 418087).
- All appliance protection currently listed in the R-102 Design Manual (Part No. 418087) is also approved protection. Zone protection can be considered optional protection.

UL EX3470 ULC EX3470

PAGE 4-58 REV. 11 2014-SEP-01

OVERLAPPING NOZZLE COVERAGE (Continued)

TABLE 1 Overlapping Nozzle Coverage (Zone Protection)

Appliance Type	Maximum Cooking Hazard
Fryer	34 in. (863 mm) Deep x 5.8 ft ² (0.5 m ²)
Griddle	30 in. (762 mm) Deep x Unlimited Length
Range	30 in. (762 mm) Deep x Unlimited Length
Wok Maximum	30 in (762 mm) Diameter x 8 in

(203 mm) Deep

Wok, Minimum 11 in. (279 mm) Diameter x 3 in.

(76 mm) Deep

Braising Pan/Tilt 34 in. (863 mm) Deep x Unlimited Length

Skillet*

Lava Rock 26 in. (660 mm) Deep x Unlimited Length

Char-Broiler (see Note 1)

Charcoal Broiler 30 in. (762 mm) Deep x Unlimited Length

(4 in. (101 mm) Maximum Fuel Depth)

Mesquite Wood 30 in. (762 mm) Deep x Unlimited Length

Regular (6 in. (152 mm) Maximum Fuel Deeth)

Broiler (6 in. (152 mm) Maximum Fuel Depth)
Gas Radiant 36 in. (914 mm) Deep x Unlimited Length

Char-Broiler

Electric Char-Broiler 34 in. (863 mm) Deep x Unlimited Length

Note 1: Always try to place Lava Rock Char-Broiler(s) near the center of the zone. When the Lava Rock Char-Broiler is the first or last appliance in the zone, the outside edge of the broiler must not be more than 6 in. (152 mm) outside the end nozzle.




FIGURE 4-113

006927

Overlapping Appliance Nozzle and Hazard Zone Locations

- 1. All overlapping appliance nozzles must be the 245 nozzle for "end of zone" protection and the 260 nozzle for zone protection, and must be located under a common hood at the same height above the hazard zone, in a straight line from right to left and aimed at the centerline of the hazard zone. The overlapping nozzle is used for both continuous overlapping and multiple group overlapping protection.
- 2. The hazard zone must be positioned (located) so that all appliance hazard surfaces are within the zone. For appliance hazard surfaces smaller than the standard hazard zone size, the hazard surface can be located anywhere within the standard hazard zone. For appliance hazard surfaces with listed protection exceeding the standard hazard zone size of 28 in. (711 mm) in depth (see Table 4-1), the hazard surface(s) must be aligned with the back edge of the hazard zone, with the front edge overhanging the front of the zone.
- 3. The overlapping appliance nozzles must be located 40 in. to 45 in. (1016 mm to 1143 mm) above the top surface of the protected appliances. See Figure 4-115.

Exception No. 1: Nozzle dimensions for wok protection are measured to bottom of wok. Exception No. 2: When using overlapping appliance nozzles in areas where there is a back shelf, the nozzle cannot be positioned in the shaded area as shown in Figure 4-114.

Also, back shelf must not extend more than 11 in. (279 mm) over the hazard zone and cannot be less than 18 in. (458 mm) above the hazard zone. See Figure 4-114.




FIGURE 4-114

^{*} See Figure 4-113 for nozzle location

UL EX3470 ULC EX3470 2014-SEP-01 **REV. 11 PAGE 4-59**

OVERLAPPING NOZZLE COVERAGE (Continued)

4. The overlapping appliance nozzles must be located 0 in. to 12 in. (0 mm to 304 mm) forward of the centerline or aimline of the selected hazard zone. See Figure 4-115.




FIGURE 4-115

TABLE 4-2 Overlapping System Piping Limitations

System Size	Total Flow Numbers	Max. 3/8 in. Pipe Length	Max. No. of Elbows	Max. Elevation Rise	Cartridge Size
3 Gallon (11.4 L)	6	75 ft (22.9 m)	25	10 ft (3.0 m)	LT-30-R
6 Gallon (22.7 L) Manifolded	12	75 ft (22.9 m)	25	10 ft (3.0 m)	Double Tank/ LT-A- 101-30*
9 Gallon (34.1 L)	18	75 ft (22.9 m)	25	10 ft (3.0 m)	Double Tank/ LT-A- 101-30*

50 ft (15.2 m) maximum pipe from first to last nozzle. 50 ft (15.2 m) maximum pipe after the split on a split system.

Overlapping Appliance Nozzle and Hazard Zone Locations - Group Protection

1. For each group of protected appliances under a common hood(s), the overlapping nozzles must be located from right to left so that each end nozzle is located a maximum of 11.5 in. (292 mm) inside the outside edge of the cooking hazard of each end appliance, and the inside overlapping nozzles must be located between the two end nozzles at a maximum spacing of 25.5 in. (647 mm). See Figures 4-116 and 4-117.





FIGURE 4-116



GROUP APPLIANCE PROTECTION Note: On group appliance protection, start and end of EACH zone group must be protected with a 245 nozzle.

FIGURE 4-117

001720


^{*}Use with regulated actuator only.

PAGE 4-60 REV. 11 2014-SEP-01

OVERLAPPING NOZZLE COVERAGE (Continued)

Overlapping Appliance Nozzle and Hazard Zone Locations – Group Protection (Continued)


 When obstructions are located adjacent to appliance(s) protected by overlapping nozzles, the overlapping appliance nozzle spacing must start with the appliance(s) adjacent to the obstruction. See Figure 4-118.



Note: On continuous appliance protection, start and end with 245 nozzles and 260 nozzle(s) in the middle.

FIGURE 4-118


3. When an appliance requires dedicated protection with a protected area intended for overlapping appliance nozzle protection, the group protection option will be required for appliances on either side of the appliances using dedicated protection. Group protection using overlapping appliance nozzles must begin with the protected appliance(s) adjacent to the dedicated appliance protected. An overlapping appliance nozzle(s) must be positioned within 11.5 in. (292 mm) of the edge(s) of the appliance hazard surface area(s) adjacent to the dedicated nozzle protection. See Figure 4-119.



Note: On group appliance protection, start and end of EACH zone group must be protected with a 245 nozzle.

4. On protected appliances, all hazard surfaces located in a group must be within 40-45 in. (1016-1143 mm) from the nozzle(s). Once that dimension is exceeded, a new group must be started. See Figure 4-120.

Note: The supply pipe feeding nozzle groups is to be at the same elevation. Adjust height for each group only by varying lengths of nozzle drops.



Note: On group appliance protection, start and end of EACH zone group must be protected with a 245 nozzle.

FIGURE 4-120

Detection Requirements For Overlapping Appliance Protection

When utilizing overlapping appliance protection, fusible link detectors must be installed on a maximum of 2 ft (0.6 m) centers, starting with detectors located in (under) the duct opening(s).

Starting from the detector under the duct opening, add detectors on 2 ft (0.6 m) maximum spacing until the complete length of the plenum area is covered, from one end to the other. The location of the last detector on each end of the plenum must not exceed 2 ft (0.6 m) from end of plenum.

Note: Standard detector placement can also be utilized when using overlapping protection. However, the overlapping detector option cannot be used when utilizing standard R-102 protection.

▶ Refer to Pages 4-71 – 4-73 for detector placement.

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 4-61

TANK AND CARTRIDGE REQUIREMENTS

Once the hazard analysis is completed and the total nozzle flow numbers are established, the quantity and size of agent tanks and cartridges needed to supply the nozzles with the proper volumes of agent at the proper flow rates can be determined. For cartridges used in the regulated release mechanism, flow capacities, tank quantities and sizes, and regulated release cartridge options are given in the table below.

Total	Quantity and	Regulated R	lelease
Flow	Size of	Cartridge O	ptions
Numbers*	Tank(s)	Nitrogen	Carbon Dioxide
1 – 5	(1) 1.5 Gallon	LT-20-R	101-10
6 – 11	(1) 3.0 Gallon	LT-30-R	101-20
11 – 16	(1) 1.5 Gallon	Double	101-30
	(1) 3.0 Gallon		
16 – 22	(2) 3.0 Gallon	Double	101-30**
16 – 22	(2) 3.0 Gallon (Manifold)	Double	-
22 - 33	(3) 3.0 Gallon	Double	_

When one or more regulated actuators are used, the following tank and cartridge combinations apply for each regulated actuator:

Regulated Actuator Tank(s)	Regulated Actuator Cartridge
(1) 1.5 Gallon	LT-20-R or 101-10
(1) 3.0 Gallon	LT-30-R or 101-20
(1) 1.5 Gallon and	LT-A-101-30 or 101-30** or
(1) 3.0 Gallon	double tank
(2) 3.0 Gallon	LT-A-101-30 or 101-30** or double tank
(2) 3.0 Gallon (Manifold)	LT-A-101-30 or Double
(3) 3.0 Gallon	LT-A-101-30 or Double

^{*} For exceptions to maximum flow numbers, see Distribution Piping Requirements for 1.5 gallon and 3.0 gallon systems in this Section.

For higher total flow numbers (23 to 110), multiple cartridges and regulated actuators are required as shown in the System Selection Guide in "Appendix" Section

ACTUATION AND EXPELLANT GAS LINE REQUIREMENTS


This section contains the guidelines for installing the actuation and expellant gas lines between the regulated release mechanism regulator, each regulated actuator regulator, and each agent tank. These limitations should be considered when selecting the component mounting locations.

The actuation gas line is the length of pipe and/or hose that is run from either the AUTOMAN Regulated Release Assembly or the Remote Release Assembly that directs high pressure from the cartridge in the release to actuate one or more additional Regulated Actuator Assemblies. The actuation gas line can consist of 1/4 in. Schedule 40 black iron, chrome-plated, stainless steel, or galvanized steel pipe and fittings, and/or factory supplied stainless steel braided actuation hose.

The **expellant gas line** is the length of pipe that is run from the regulator in either the AUTOMAN Regulated Release Assembly or a Regulated Actuator Assembly that directs regulated pressure to the agent storage tanks to pressurize the tank and discharge the agent. The expellant gas line shall consist of 1/4 in. Schedule 40 black iron, chrome-plated, stainless steel, or galvanized steel pipe and fittings.

Actuation Gas Line - 6 to 8* Tanks Maximum

- * 8 Tank maximum reflects the utilization of 3 tank regulated actuators.
- 1. Use only 1/4 in. Schedule 40 black iron, hot-dipped galvanized, chrome-plated, or stainless steel pipe and fittings.
- 2. The actuation gas line piping is installed from the regulated release mechanism to each regulated actuator connected within the system. The total length of the actuation gas line from the regulated release assembly to the regulated actuator assembly(ies) must not exceed 20 ft (6.0 m) when using an LT-20-R, an LT-30-R nitrogen cartridge, or a 101-10 or a 101-20 carbon dioxide cartridge. See Figure 4-121.



^{**} The 101-30 cartridge can not be used when two 3.0 gallon tanks are manifolded together.

UL EX3470 ULC EX3470

PAGE 4-62 REV. 11 2014-SEP-01

ACTUATION AND EXPELLENT GAS LINE REQUIREMENTS (Continued)

Actuation Gas Line – 6 to 8* Tanks Maximum (Continued)

- 3. If an expellant gas line is connected to the regulated release assembly along with an actuation gas line, the total combined length of the actuation and expellant gas line must not exceed 30 ft (9.1 m) when using a "double-tank" nitrogen cartridge or a LT-A-101-30 nitrogen cartridge or a 101-30 carbon dioxide cartridge. See Figure 4-122.
- A combined total of nine fittings may be used in these lines, eight 90° elbows and one tee. Two 45° elbows equal one 90° elbow.

Actuation Gas Line - 10 to 15* Tanks Maximum

- * 15 Tank maximum reflects the utilization of 3 tank regulated actuators.
- Use only 1/4 in. Schedule 40 black iron, hot-dipped galvanized, chrome-plated, or stainless steel pipe and fittings.
 Note: Stainless steel hose and fittings can also be used.
 See Component Section for detailed information.





FIGURE 4-122

- The actuation gas line piping is installed from the 101 remote mechanical release to each R-102 regulated actuator assembly. The total length of the actuation gas line from the remote mechanical release to the regulated actuator assemblies must not exceed 100 ft (30.4 m).
- A combined total of 20 elbows and 9 tees may be used in these lines. Two 45° elbows equal one 90° elbow. See Figure 4-123.
- Use only a 101-10 carbon dioxide cartridge in the 101 remote mechanical release.
- A safety vent relief valve (Part No. 15677) is required in the actuation gas line to relieve residual pressure after actuation.

Actuation Gas Line - Using 1/4 in. Stainless Steel Hose

- * 15 Tank maximum reflects the utilization of three tank regulated actuators.
- Maximum total length of hose cannot exceed 17.5 ft (5.3 m).
 Note: A combination of 1/4 in. stainless steel braided hose and 1/4 in. NPT pipe can be used as long as the total combined actuation gas line length does not exceed 17.5 ft (5.3 m). Stainless steel braided hose cannot be used for expellant gas lines. See Figure 4-123 for additional details.
- 2. Maximum of five regulated actuators allowed
- 3. Actuated with remote release (Part No. 433485) or Regulated Release Assembly (Part No. 429853)




UL EX3470 ULC EX3470 2014-SEP-01 **REV. 11 PAGE 4-63**

ACTUATION AND EXPELLENT GAS LINE REQUIREMENTS (Continued)

Expellant Gas Line

1. The expellant gas line is installed from the regulated release mechanism in double, three, and multiple-tank systems, and from the regulated actuator assembly in multiple-tank systems. The expellant gas line is the piping and/or hose between the regulator and the tank-enclosure/tank-bracket assembly. The total length of the expellant gas line from the regulated release mechanism or each regulated actuator assembly must not exceed 30 ft (9.1 m) when using a "double-tank" cartridge, an LT-A-101-30 Cartridge, or a 101-30 Cartridge. See Figures 4-124 and 4-125.






FIGURE 4-125

2. A combined total of nine fittings may be used in these lines, eight 90° elbows and one tee. Two 45° elbows equal one 90° elbow.

- 3. If two tanks are connected to the regulated release assembly in a multiple-tank system arrangement, the total combined length of the actuation and expellant gas lines must not exceed 30 ft (9.1 m) when using a "double-tank" nitrogen cartridge, an LT-A-101-30 nitrogen cartridge, or a 101-30 carbon dioxide cartridge. See Figure 4-122.
- 4. If three 3.0 gallon tanks are connected to the regulator in either a regulated release or regulated actuator assembly, only factory supplied expellant gas hose assemblies will be utilized. Refer to Distribution Piping Requirements - 9.0
- Gallon System, page 4-70 for additional design requirements.

DISTRIBUTION PIPING REQUIREMENTS

Once the nozzle placement and quantity of tanks has been determined, it is then necessary to determine the piping configurations between the tank adaptor and each discharge nozzle. This section contains the guidelines and limitations for designing the distribution piping so that the liquid agent will discharge from the nozzles at a proper flow rate. These limitations should also be referred to when selecting the mounting location for the regulated release mechanism and agent tank.

General Piping Requirements

- 1. All R-102 system piping is straight line. Therefore, the need for critical lengths and balancing is minimized.
- 2. Two 45° elbows count as one 90° elbow.
- 3. Each branch line includes the tee or elbow leading to it, and all fittings within the branch line itself.
- 4. The minimum piping length of Schedule 40, 3/8 in. pipe from the tank outlet to any nozzle protecting a range, fryer, or wok must be 6 ft (1.9 m).
- 5. Pipe lengths are measured from center of fitting to center of fitting. See Figure 4-126.




FIGURE 4-126


- 6. All distribution piping must be 3/8 in. Schedule 40 black iron, chrome-plated, or stainless steel. Do not use hot dipped galvanized pipe on the distribution piping.
- 7. All threaded connections located in and above the protected area must be sealed with pipe tape. Tape should be applied to male threads only. Make certain tape does not extend over the end of the thread, as this could cause possible blockage of the agent distribution.
- 8. Before installing blow-off caps on nozzles, apply a small amount of Dow Corning No. 111 silicone grease across the opening in the nozzle tip and also a small amount coating the exterior of the blow-off cap. This will help keep cooking grease from building up on the cap.
- 9. Tees used in the distribution piping can be used as thru tees, side outlet tees, or bull tees.

PAGE 4-64 REV. 11 2014-SEP-01

DISTRIBUTION PIPING REQUIREMENTS (Continued)

Supply and Branch Line Identification


The R-102 distribution piping network is broken down into four specific pipe runs: the Supply Line, the Duct Branch Line, the Plenum Branch Line, and the Appliance Branch Line. See Figure 4-127.



NOTE: THIS IS A CONCEPTUAL DRAWING ONLY. THIS IS NOT AN ACTUAL INSTALLATION.

SUPPLY LINE

The Supply Line is defined as the length of pipe which runs from the agent tank outlet to the last branch line (whether a duct, appliance, or plenum branch line). This includes all supply line fittings except for the tees or elbows leading to the branch lines. See Figures 4-127 and 4-128.



DISTRIBUTION PIPING REQUIREMENTS (Continued)


Supply and Branch Line Identification (Continued)

NOTICE

Branch lines cannot start ahead of a supply

DUCT BRANCH LINE

The Duct Branch Line is defined as the length of pipe which runs from the supply line to the duct nozzle(s). This includes all branch line fittings as well as the tee or elbow used to start the branch line. See Figures 4-128 and 4-129.



PLENUM BRANCH LINE

The Plenum Branch Line is defined as the length of pipe which runs from the supply line to the plenum nozzle(s). This includes all branch line fittings as well as the tee or elbow used to start the branch line. See Figures 4-128 and 4-130.




FIGURE 4-130

APPLIANCE BRANCH LINE

The Appliance Branch Line is defined as the length of pipe which runs from the supply line to the appliance nozzle(s). This includes all branch line fittings as well as the tee or elbow used to start the branch line. See Figures 4-128 and 4-131.




FIGURE 4-131

UL EX3470 ULC EX3470

PAGE 4-66 REV. 11 2014-SEP-01

DISTRIBUTION PIPING REQUIREMENTS (Continued) Distribution Piping Requirements – 1.5 Gallon System

DUCT, PLENUM, AND APPLIANCE PROTECTION

- 1. This option allows for duct protection, plenum protection, appliance protection, or any combination. However, only one duct nozzle may be used, either a 1W or a 2W, nozzle.
- 2. All distribution piping, supply and branch, must be 3/8 in. Schedule 40 black iron, chrome-plated, or stainless steel.
- 3. Each 1.5 gallon tank allows a maximum of five flow numbers.*
- 4. The pipe length between the start of the first branch line and the start of the last branch line must not exceed 8 ft (2.4 m). When the supply line is split, the combined length of both legs of the supply line (start of first branch line to start of last branch line) must not exceed 8 ft (2.4 m). See Figure 4-132.
- 5. The combined length of all branch lines must not exceed 22 ft (6.7 m). See Figure 4-133.
- 6. The requirements of the following table must not be exceeded:




FIGURE 4-132




FIGURE 4-133

000785

▶ 1.5 GALLON SYSTEM

Requirements	Supply Line	Duct Branch Line	Plenum Branch Line	Appliance Branch Line
Pipe Size	3/8 in.	3/8 in.	3/8 in.	3/8 in.
Maximum Length	40 ft	6 ft	4 ft	10 ft
	(12.1 m)	(1.8 m)	(1.2 m)	(3.0 m)
Maximum Tees	1	1	2	3
Maximum Flow Numbers	5*	2	2	3


* Exceptions:


- 1. Six flow numbers are allowed when a duct branch line is the last branch line on the piping network and no 1N nozzles are used to protect woks or griddles.
- 2. Six flow numbers are allowed when six 1N nozzles are used and none of the nozzles are used to protect woks, griddles, ranges, and salamanders. Note: Only five flow numbers are allowed if a 1N nozzle is used for wok, griddle, range, or salamander protection.
- 3. Six flow numbers are allowed when only two 3N nozzles are used.

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 4-67

DISTRIBUTION PIPING REQUIREMENTS (Continued) Distribution Piping Requirements – 3.0 Gallon System

- 1. The maximum length between the start of the first branch line and the start of the last branch line must not exceed 24 ft (7.3 m). When the supply line is split, the **combined total** of both legs of the supply line (from the start of the first branch line to the start of the last branch line) must not exceed 24 ft (7.3 m). See Figure 4-134.
- 2. The total length of all branch lines must not exceed 36 ft (10.9 m). See Figure 4-134.
- 3. Use a 3/8 in. union to connect the tank adaptor to the 3/8 in. supply line.
- 4. A maximum of two nozzles are allowed per duct branch line.
- 5. The requirements of the following table must not be exceeded:





▶ 3.0 GALLON SYSTEM

Requirements	Supply Line	Duct Branch Line	Plenum Branch Line	Appliance Branch Line
Pipe Size	3/8 in.	3/8 in.	3/8 in.	3/8 in.
Maximum Length	40 ft (12.1 m)	8 ft (2.4 m)	4 ft (1.2 m)	12 ft (3.6 m)
Maximum Rise	6 ft (1.8 m)	4 ft (1.2 m)	2 ft (0.6 m)	2 ft (0.6 m)
Maximum 90° Elbows	9	4	4	6
Maximum Tees	1	2	2	4
Maximum Flow Numbers	11*	4	2	4

Exceptions:

- 1. Twelve flow numbers are allowed in any one tank for duct and plenum protection only.
- $2. \ \, \text{Twelve flow numbers are allowed with any one tank using only two-flow appliance nozzles}.$
- 3. Twelve flow numbers are allowed with any one tank using only three-flow appliance nozzles.

Special Instructions:

- 1. Twelve flow numbers are allowed when four Dean Industries GTI Gas Fryers are protected at low proximity as shown in Figure 4-66 on Page 4-32. The discharge piping must be as shown in Figure 4-67 on Page 4-32.
- 2. For certain McDonald's applications, 11.5 flow numbers are allowed when using a combination of one 2W duct nozzle, one 1/2N electrostatic precipitator nozzle, one 1N plenum nozzle, and four two-flow appliance nozzles. Contact the Applications Engineering Department for additional information.

UL EX3470 ULC EX3470


PAGE 4-68 REV. 11 2014-SEP-01


DISTRIBUTION PIPING REQUIREMENTS (Continued)

Distribution Piping Requirements – 6.0 Gallon Manifolded System

As an option to piping two 3.0 gallon tanks separately, two 3.0 gallon tanks can be manifolded together to share a common agent distribution line. Only 3.0 gallon tanks connected to the same regulator can be manifolded. The following requirements must be met when manifolding:

- 1. All piping must be 3/8 in. Schedule 40.
- 2. See Figure 4-136 for tank connections.
- 3. The length of supply line piping between the start of the first branch line and the start of the last branch line must not exceed 24 ft (7.3 m). See Figure 4-135. When the supply line is split, the **combined total** of both legs of the supply line (from the start of the first branch line to the start of the last branch line) must not exceed 24 ft (7.3 m).
- 4. The combined length of all branch lines must not exceed 36 ft (10.9 m). See Figure 4-135.
- 5. A maximum of 22 flow numbers are allowed.
- The requirements of the following table must not be exceeded.





(BRANCH LINES IN BOLD) COMBINED LENGTH MUST NOT EXCEED 36 FT (10.9 m)

FIGURE 4-135


▶ 6.0 GALLON SYSTEM

Requirements	Supply Line	Duct Branch Line	Plenum Branch Line	Appliance Branch Line
Pipe Size	3/8 in.	3/8 in.	3/8 in.	3/8 in.
Maximum Length	32 ft (9.7 m)	8 ft (2.4 m)	4 ft (1.2 m)	12 ft (3.6 m)
Maximum Rise	6 ft (1.8 m)	4 ft (1.2 m)	2 ft (0.6 m)	2 ft (0.6 m)
Maximum 90° Elbows	8	4	4	6
Maximum Tees	2	2	2	4
Maximum Flow Numbers	22	4	2	4

DISTRIBUTION PIPING REQUIREMENTS (Continued)

Distribution Piping Requirements – 6.0 Gallon Manifolded System (Continued)

This configuration consists of two 3 gallon tanks. Both tanks are connected to a common manifold tee and are pressurized from a single double tank (Part No. 73022) nitrogen cartridge in the regulated release assembly. See Figure 4-136. **Note**: A tank mounting bracket can be utilized instead of the tank/enclosure assembly.



NOTE 1: THE PIPE CONNECTION FROM TANK CENTER TO TANK CENTER CANNOT EXCEED 8 1/2 IN. (215 mm). ALSO, OEM RELEASE/BRACKET ASSEMBLY CAN BE UTILIZED WHEN MANIFOLDING 3.0 GALLON TANK.

NOTE 2: ONLY 3 GALLON TANKS CAN BE MANIFOLDED.

NOTE 3: THE BURST DISC THAT IS PART OF THE TANK ADAPTOR/ BURST DISC ASSEMBLY MUST BE REMOVED AND MODIFIED. SEPARATE THE ALUMINUM DISC MATERIAL FROM THE PLASTIC GASKET. DISCARD THE ALUMINUM DISC MATERIAL AND REINSTALL THE PLASTIC GASKET BACK INTO THE TANK ADAPTOR/BURST DISC ASSEMBLY.

NOTE 4: THE IN-LINE BURST DISC ASSEMBLY (PART NO. 416970)
IS TO BE MOUNTED AS CLOSE TO THE TANK OUTLET AS
POSSIBLE. AFTER SYSTEM DISCHARGE, THE ASSEMBLY
MUST BE DISASSEMBLED AND A NEW BURST DISC
INSTALLED.

Distribution Piping Requirements – With Independent Pipe Runs

Independent pipe runs can also be used with the regulated release assembly and the tank/enclosure assembly or tank mounting brackets. See Figure 4-137. When manifolding is not used, each of the two 3 gallon tanks utilize the piping limitations of a single tank system.




FIGURE 4-137

Note: If an expellant gas hose is to be used for a second tank in an adjacent tank enclosure or tank bracket assembly, the second tank will need to be installed on the left side of the AUTOMAN Regulated Release, with the outlets a maximum of 8.5 in. (215 mm) from center to center, similar to the manifolded system in Figure 4-136. Otherwise, the second tank will require 1/4 in. NPT pipe instead of expellant gas hose.

UL EX3470 ULC EX3470


PAGE 4-70 REV. 11 2014-SEP-01

DISTRIBUTION PIPING REQUIREMENTS (Continued)

Distribution Piping Requirements - 9.0 Gallon System

This optional configuration consists only of three 3-gallon tanks, all pressurized from a single double-tank nitrogen cartridge with expellant gas hoses connected as shown in Figure 4-138. Tanks No. 1 and No. 2 must be connected directly to the regulator with separate expellant gas hoses and Tank No. 3 must be connected to Tank No. 2 with a third expellant gas hose as shown in Figure 4-136. Each tank must be connected to an independent distribution piping network as shown in Figure 4-138. Distribution piping requirements for each network must be as follows:

- The maximum length between the start of the first branch line and the start of the last branch line must not exceed 24 ft (7.3 m). When the supply line is split, the **combined total** of both legs of the supply line (from the start of the first branch line to the start of the last branch line) must not exceed 24 ft (7.3 m). See Figure 4-134.
- 2. The total length of all branch lines must not exceed 36 ft (10.9 m). See Figure 4-138.
- 3. Use a 3/8 in. union to connect the tank adaptor to the 3/8 in. supply line.
- 4. A maximum of two nozzles are allowed per duct branch line.
- When using this 9.0 gallon system configuration, no manifolding of distribution piping is allowed.
- 6. When an AUTOMAN Regulated Release is utilized in this configuration, additional regulator actuators cannot be used.
- 7. Only 3-gallon tanks can be utilized in this configuration.
- 8. The requirements of the following table must not be exceeded for each 3-gallon tank:



NOTE: WHEN THREE 3.0 GALLON TANKS ARE CONNECTED TO ONE AUTOMAN REGULATED RELEASE ASSEMBLY, NO ADDITIONAL REGULATED ACTUATOR(S) ASSEMBLIES CAN BE USED.

ACTUATOR ASSEMBLY

۸ I:

ONLY)

FIGURE 4-138

▶ 9.0 GALLON SYSTEM

Requirements	Supply Line	Duct Branch Line	Plenum Branch Line	Appliance Branch Line
Pipe Size	3/8 in.	3/8 in.	3/8 in.	3/8 in.
Maximum Length	40 ft (12.1 m)	8 ft (2.4 m)	4 ft (1.2 m)	12 ft (3.6 m)
Maximum Rise	6 ft (1.8 m)	4 ft (1.2 m)	2 ft (0.6 m)	2 ft (0.6 m)
Maximum 90° Elbows	9	4	4	6
Maximum Tees	1	2	2	4
Maximum Flow Numbers	11*	4	2	4

*Exceptions:

- 1. Twelve flow numbers are allowed in any one tank for duct and plenum protection ONLY.
- 2. Twelve flow numbers are allowed with any one tank using only two-flow appliance nozzles.
- 3. Twelve flow numbers are allowed with any one tank using only three-flow appliance nozzles.

Special Instructions:

- 1. When four Dean Industries GTI Gas Fryers are protected at low proximity as shown in Figure 4-66 on Page 4-32, the discharge piping must be as shown in Figure 4-67 on Page 4-32.
- 2. For certain McDonald's applications, 11.5 flow numbers are allowed when using a combination of one 2W duct nozzle, one 1/2N electrostatic precipitator nozzle, one 1N plenum nozzle, and four two-flow appliance nozzles. Contact the Applications Engineering Department for additional information.

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 4-71

DETECTION SYSTEM REQUIREMENTS

Once the fire suppression system design has been determined, a detection system design must be completed. This section contains guidelines and limitations for detection system installation.

Detector Identification

The two types of detectors are distinguished from each other by their location in the detection system.

- 1. The Terminal Detector is the last in a series of detectors, or the only detector used in a single-detector system. This detector is thus named because it is at the point at which the wire rope ends, or "terminates."
- 2. A Series Detector is any detector located in-line between the regulated release mechanism and the terminal detector.

Detector/Pulley Elbow/Conduit Offset Design Limitations

 Conduit runs, pulley elbows, and number of detectors per system must be within the approved system guidelines. The following requirements must not be exceeded:

	Maximum Number of Detectors per System	Maximum Number of Elbows per System	Maximum Length of 1/2 in. Conduit per System
Scissors Style Detector (Without Offset Conduit	15	20	150 ft (45.7 m)
Scissors Style Detector (With Offset Conduit	15	16	150 ft (45.7 m)

2. If the hazard requires more than 15 detectors, up to five 101 Remote Releases (Part No. 433485) can be used for system actuation. Each 101 remote release allows the use of a maximum of 15 "scissor" style detectors (14 series and 1 terminal) for a total of 75 detectors if needed.

Detector Placement Requirements

EXHAUST DUCTS

Each exhaust duct must have at least one detector installed in the duct entrance, located in the airstream of the cooking vapors, or at a maximum of 20 ft (6.0 m) into the duct opening. See Figure 4-139




FIGURE 4-139

000271

NOTICE

When gas appliances are used and the flue gases from the burner are exhausted into the duct, the detector must be kept out of the air stream of these exhaust gases. These gases can be very hot and could actuate the system unnecessarily.


Duct openings that are long and narrow or large enough to require multiple duct nozzles may require additional detectors.

ELECTROSTATIC PRECIPITATOR

If an electrostatic precipitator is located at or near the base of the exhaust duct, it is necessary to locate a detector below the precipitator, at the base of the duct, and also locate one in the duct, just above the precipitator. See Figure 4-140.

When installing the detector bracket and system conduit, make certain they do not interfere with the operation of the precipitator.

Note: On secondary filtration units utilizing multiple filter stages/
▶ media. contact Technical Services for instructions.



UL EX3470 ULC EX3470

PAGE 4-72 REV. 11 2014-SEP-01

DETECTION SYSTEM REQUIREMENTS (Continued)

Detector Placement Requirements (Continued)

COOKING APPLIANCES

If the cooking appliance is located under an exhaust duct where a detector has been mounted, it is normally not necessary to utilize another detector for that cooking appliance, provided the detector is not more than 12 in. (304 mm) into the duct and the appliance has no larger cooking surface than 48 in. x 48 in. (1219 mm x 1219 mm). See Figure 4-141.

Note: If two appliances are located under a duct opening where a detector has been mounted and both appliances together do not exceed a cooking surface of 48 in. x 48 in. (1219 mm x 1219 mm) and the detector is located above both the protected appliances, it is not necessary to utilize an additional detector provided the duct detector is not more than 12 in. (304 mm) into the duct opening.




FIGURE 4-141

0002

Each cooking appliance with a continuous cooking surface not exceeding 48 in. x 48 in. (1219 x 1219 mm) can be protected by a minimum of **one** detector. Cooking appliances with a continuous cooking surface exceeding 48 in. x 48 in. (1219 x 1219 mm) must be protected by at least **one detector per 48 in. x 48 in.** (1219 x 1219 mm) cooking area. Detectors used for cooking appliances must be located above the protected appliance toward the exhaust duct side of the appliance. The detector should be located in the air stream of the appliance to enhance system response time.

Note: For overlapping detector coverage, see Page 4-60 for design requirements.

Detection Line Requirements

CONDUIT

Rigid conduit or 1/2 inch EMT thin-wall conduit may be used. Standard steel conduit fittings (compression type are recommended) must be employed to properly install the detection system. All conduit or pipe must be firmly supported. When using pipe, make certain that all ends are carefully reamed, deburred and blown clear of chips and scale before assembly.

NOTICE

The conduit offset can be used at the top or bottom of the regulated release to change direction of the conduit. The conduit offset cannot be used with pulley tees. All other changes in direction must be made by using ANSUL approved pulley elbows (Part No. 423254 or 415670). See Figure 4-142.




FIGURE 4-142

00027

Fusible Link Selection

When possible, temperature readings should be taken at each detector location to determine correct fusible link temperature rating. Temperature can be recorded using either a maximum registering thermometer (Part No. 15240) temperature tape or any other accurate thermometer.




FIGURE 4-143

Select correct UL Listed fusible link(s) for installation in detector(s) according to the temperature condition. Two styles are available. See Figure 4-143. See Component Section for detailed temperature ratings.

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 4-73

DETECTION SYSTEM REQUIREMENTS (Continued)

Electric Thermal Detector

When electric thermal detection is used, the detection circuit must be supervised in accordance with NFPA 17A, Standard for Wet Chemical Extinguishing Systems. Electric thermal detectors must be used in conjunction with either the AUTOPULSE 542R Control Panel (Part No. 433607) or the AUTOPULSE Z-10 Control Panel (Part No. 430525), and the 24VDC Regulated Release Assembly.

Note: Consider the rate of temperature increase in the location chosen for the detector when using electric thermal detection. A transient rush of warm air up to 40 °F (4 °C) per minute may expand the shell, but not enough to trigger the AUTOPULSE control panel. Temperature increases over 40 °F (4 °C) per minute however, may initiate an alarm condition in the control panel.

After determining the maximum ambient temperature at the thermal detector location, select the correct thermal detector according to the temperature condition chart in the "System Components" section.

MANUAL PULL STATION REQUIREMENTS

A remote manual pull station allows the R-102 system to be manually operated at some point distant from the regulated release assembly. The pull station should be installed at a height of 42-48 in. (1067-1219 mm), in accordance with the requirements of the American Disabilities Act (ADA) and the Authority having Jurisdiction. and located in the path of egress. The pull station is the only source of manual actuation of the regulated release assembly.

The total length of the cable used for each manual pull station within a system must not exceed 150 ft (45.7 m).


The maximum number of pulley elbows that may be used per pull station is 20.

One pulley tee is allowed per cable system.

The maximum length of cable from the AUTOMAN to a pull station is 150 ft (45.7 m) with a maximum of 20 pulley elbows used per side of the tee. As the tee is located farther from the AUTOMAN, the 150 ft (45.7 m) maximum must be observed but as pulley elbows are placed between the AUTOMAN and the tee, they must be deducted from the available pulley elbows (20) allowed on each side.


Example: If 10 pulley elbows are placed between the AUTOMAN and the pulley tee, the maximum available pulley elbows left for use on each side of the tee is 10 per side. See Figure 4-144 for three different examples. (**Note:** Both must be gas valves or both must be pull stations. Mixing is not allowed.)

TEE CLOSE TO AUTOMAN (EXAMPLE)




149 FT (45.4 m) AND 20 PULLEY ELBOWS MAXIMUM PER EACH SIDE OF TEE

TEE CLOSE TO GAS VALVES OR MANUAL PULL (EXAMPLE)



149 FT (45.4 m) AND 20 PULLEY ELBOWS BETWEEN AUTOMAN AND TEE

TEE HALFWAY BETWEEN AUTOMAN AND GAS VALVES OR MANUAL PULL (EXAMPLE)



► Manual Pull Station - Part No. 435960 or 434618

Parts that may be used for installation of a metal stamped remote manual pull station are:

Description	Part No.
► Remote Manual Pull Station Assembly*	435960
► Remote Manual Pull Station Assembly	434618
Pulley Elbow	423250
Pulley Elbow	415670
Pulley Tee	427929
*Assembly includes parts listed below:	
1/16 in. Stainless Steel Cable 50 ft (15.2 m)	15821
Oval Press-To-Crimp Sleeves	4596
Glass Break Rod (1)	4834

UL EX3470 ULC EX3470

PAGE 4-74 REV. 11 2014-SEP-01

MECHANICAL GAS VALVE REQUIREMENTS

An ANSUL or ANSUL approved mechanical gas shut-off valve system can be attached to the R-102 system. The system works both mechanically and pneumatically by use of an air cylinder located inside the regulated release assembly. Upon actuation of the fire suppression system, a pneumatically-operated air cylinder assembly will mechanically close the gas shut-off valve.

The total length of the cable for each mechanical gas valve must not exceed 150 ft (45.7 m). The maximum number of pulley elbows that may be used is 20 for each valve.

One pulley tee is allowed per cable system.

The maximum length of cable from the AUTOMAN to a gas valve is 150 ft (45.7 m) with a maximum of 20 pulley elbows used per side of the tee. As the tee is located farther from the AUTOMAN, the 150 ft (45.7 m) maximum must be observed but as pulley elbows are placed between the AUTOMAN and the tee, they must be deducted from the available pulley elbows (20) allowed on each side.

Example: If 10 pulley elbows are placed between the AUTOMAN and the pulley tee, the maximum available pulley elbows left for use on each side of the tee is 10 per side. See Figure 4-144 for three different examples.

Parts that may be used for installation of a Mechanical Gas Shut-off Valve are:

Description	Part No.
Gas Valve/Actuator 3/4 in. Assembly (ANSUL)*	55598
Gas Valve/Actuator 1 in. Assembly (ANSUL)*	55601
Gas Valve/Actuator 1 1/4 in. Assembly (ANSUL)*	55604
Gas Valve/Actuator 1 1/2 in. Assembly (ANSUL)*	55607
Gas Valve/Actuator 2 in. Assembly (ANSUL)*	55610
Gas Valve/Actuator 2 1/2 in. Assembly (ASCO)*	25937
Gas Valve/Actuator 3 in. Assembly (ASCO)*	25938
Pulley Elbow	423250
Pulley Elbow	415670
Pulley Tee	427929
1/16 in. Stainless Steel Cable	15821 or
50 ft (15.2 m) or 500 ft (152.4 m) roll	79653
Oval Press-To-Crimp Sleeve	4596
Stop Sleeve (2)	26317
*Assembly includes parts listed below:	
Air Cylinder Assembly	15733
Air Cylinder	15521
Tubing Assembly	15529
Copper Tubing, 1/8 in.	15525
Male Elbow	15523
Male Connector	15522
Machine Screw (2)	15421
Hex Nut (2)	15527
Lockwasher (2)	4141
Visual Inspection Seal (2)	197

All valves above are UL listed and approved. They may be mounted in any position. Pipe threads are type NPT. Ambient operating temperature range of all valves is 32 °F to 120 °F (0 °C to 49 °C). The valves are not weatherproof and must be located indoors in areas approved by the "authority having jurisdiction."

ELECTRICAL GAS VALVE REQUIREMENTS

A UL Listed electrically-operated gas shut-off valve can be attached to the R-102 system to provide an electrical means of shutting off the gas line at a predetermined point. If an electric gas shut-off valve is used in the system it must be attached with both an electric (snap-action) switch and a manual reset relay. For more information on the types of electric (snap-action) switches, refer to the Electrical Switch, Field Installation section. The manual reset relay is reviewed in this section.

All electrical connections should be performed by a **QUALIFIED ELECTRICIAN** and in accordance with authority having jurisdiction.

The following is a brief explanation of how the R-102 system operates with an Electric Gas Shut-off Valve attached:

With the regulated release cocked in the ready condition, the normally closed contacts in the snap-action switch allow current to flow to the manual reset relay. With the relay coil energized, normally open contacts in the reset relay close, allowing the solenoid in the gas valve to be energized.

Once the R-102 system is activated, the normally closed contacts in the snap-action switch will open, de-energizing the reset relay. This will, in turn, open the contacts in the relay which will cause the gas valve to become de-energized and close.

The system must be re-armed and the "push to reset" button on the reset relay must be operated to reopen the gas valve.

It is important to note that a power failure or an electrical power interruption will cause the gas valve to close even though the system was not fired.

In either case, whether in a fired condition or when a power failure has occurred, the manual reset relay and electric gas shut-off valve must be reset to resume a normal operating condition. For resetting, refer to the "Recharge and Resetting Procedures" section in this manual.

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 4-75

ELECTRICAL GAS VALVE REQUIREMENTS (Continued)

Approvals

ANSUL gas valves listed in this section are UL listed and approved for 110 VAC. If more information is required, refer to the Gas and Oil Equipment List of Underwriters Laboratories, Inc. under "Electrically Operated Valves Guide No. 440 A5" or consult Tyco Fire Protection Products, Marinette, Wisconsin 54143-2542.

If other gas valves are used, they shall be "UL listed electrically-operated safety valves for natural or LP gas as required, of appropriate pressure and temperature rating, 110 VAC/60 Hz." The information on temperature and type of gas that the valves are suitable for may be found in the Gas and Oil Equipment List of Underwriters Laboratories, Inc. under "Electrically Operated Valves Guide No. 440 A5."

The electrically operated gas valve must be of the type that needs to be energized to remain open.

Note: For electrical wiring diagrams, see "Installation Instructions" Section, Pages 5-40 through 5-42.

Parts that may be used for installation of a 110 VAC Gas Shutoff Valve are:

Description	Part No.
Electric Solenoid Valve, 3/4 in. NPT*	13707
Electric Solenoid Valve, 1 in. NPT*	13708
► Electric Solenoid Valve, 1 1/4 in. NPT*	550360
Electric Solenoid Valve, 1 1/2 in. NPT*	13709
Electric Solenoid Valve, 2 in. NPT*	13710
► Electric Solenoid Valve, 2 1/2 in. NPT*	550363
Electric Solenoid Valve, 3 in. NPT*	17643
► Manual Reset Relay (110 VAC)	426151

^{*}Valves are normally closed when de-energized.

ALARM INITIATING SWITCH REQUIREMENTS

The Alarm Initiating Switch can be field mounted within the AUTOMAN release. The switch must be used to close a supervised alarm circuit to the building main fire alarm panel when the AUTOMAN release actuates. This action will signal the fire alarm panel that there was a system actuation in the kitchen area. The switch kit contains all necessary mounting components along with a mounting instruction sheet. See Page 5-39 for wiring information.

The switch is rated 50 mA, 28VDC.

Part No. Description

428311 Alarm Initiating Switch Kit

ELECTRICAL SWITCH REQUIREMENTS

Note: Electrical connections shall not be made in the AUTOMAN.

The electric (snap-action) switches for the R-102 system are specially designed to fit the regulated release assembly. The switches are intended for use with electric gas valves, alarms, contactors, lights, contractor supplied electric power shut-off devices, and other electrical devices that are designed to shut off or turn on when the fire suppression system is actuated. (See Figures 5-122 through 5-124 in Installation Section for reference).

Contractors shall supply "UL listed, enclosed industrial control equipment or magnetic switch having a rating matching that of the cooking appliance, coil 110 VAC/60 Hz or 24 VAC/60 Hz."

All electrical connections should be performed by a **QUALIFIED ELECTRICIAN** and in accordance with authority having jurisdiction.

Electric (Snap-Action) Switches that may be field installed are:

Part No.	Description
423878	One Switch Kit
423879	Two Switch Kit
423880	Three Switch Kit
423881	Four Switch Kit
406770	Two Cwitch Kit (no wire I

► 436770 Two Switch Kit (no wire leads)

Each switch has a set of single-pole, double throw contacts rated at 21 amp, 1 HP, 125, 250, 277 VAC or 2 HP, 250, 277 VAC.

Note: A relay must be supplied by others if the equipment load exceeds the rated capacity of the switch.

Electrical wiring and equipment shall be installed in accordance with NFPA 70 (National Electrical Code) or the requirements of the authority having jurisdiction.

If a fire alarm system is provided, the fire extinguishing system shall be connected to the alarm system in accordance with the requirements of NFPA 72, National Fire Alarm Code, so that the actuation of the extinguishing system will sound the fire alarm as well as provide the extinguishing function of the system.

If supervision of the electrical detection, electrical actuation or electrical power supply circuit is provided, it shall give prompt audible or visual indication of trouble and shall be distinctive from alarms or indicators indicating operation or hazardous conditions as specified in NFPA 17A.

R-102 Restaurant Fire Suppression Manual

SECTION 4 – SYSTEM DESIGN

UL EX3470 ULC EX3470

PAGE 4-76 REV. 11 2014-SEP-01

NOTES:

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 5-1

INSTALLATION INSTRUCTIONS

1.

The installation information listed in this section deals with the limitations and parameters of this pre-engineered system. Those individuals responsible for the installation of the R-102 system must be trained and hold a current ANSUL certificate in an R-102 training program.

Before attempting any installation, the entire system design must have been determined including: Nozzle Placement, Tank Quantity, Actuation and Expellant Gas Piping, Distribution Piping, and Detection System Requirements and an installation sketch should be completed.

► INSTALLING RELEASE ASSEMBLY COMPONENTS

For successful system performance, the regulated release assembly, regulated actuator assembly(ies), and tank-enclosure(s) or tank-bracket assembly(ies) used must be located in areas where the air temperature will not fall below 32 °F (0 °C) or exceed 130 °F (54 °C). The R-102 system is limited to interior applications only. Also, the components must be arranged to conform to the actuation and expellant gas line, and the distribution piping guidelines noted in "System Design."

CAUTION

Use only an AUTOMAN Regulated Release assembly or OEM Release/Bracket Assembly. The regulator in this assembly is specifically designed to allow a regulated flow of expellant gas into the agent tank(s). Absence of this regulator could cause the tank(s) to rupture or create an improper system discharge.

Mount the regulated release assembly, OEM Release Assembly, and each regulated actuator assembly required by completing the following steps: See Figures 5-1, 5-2, and 5-3.

- a. Select a rigid surface for mounting the enclosure. The mounting locations must allow the regulated release assembly and the regulated actuator assembly(ies) to be within the limitation of the actuation and expellant gas line lengths and must be able to support the weight of the assembly(ies). When the OEM Release Assembly is mounted inside a cabinet, clearances shall be provided for unrestricted movement of the release assembly components within the closed cabinet.
- Detach cover from the enclosure. Remove agent tank from enclosure and the expellant gas line hose from the tank/adaptor assembly.
- c. Secure enclosure box to selected mounting location using the four mounting holes. Use appropriate type of fasteners depending on the mounting surface.
- d. When mounting a 6 gallon manifolded system (or a 6 gallon individual piped system) it is critical that each mounting box is located as shown in Figure 5-3. There must be a 5/16 in. (7.9 mm) space between each box. Less than 5/16 in. (7.9 mm) will cause interference with the covers, and more than 5/16 in. (7.9 mm) will cause a gap between the two hose grommets which will expose the hose to possible tampering or damage.


Remove the 7/8 in. (22 mm) knockout on the left side of the AUTOMAN release box and remove the 1 in. (25 mm) knockout on the right side of the tank-enclosure box. Install grommets in each (use ANSUL hose/grommet package (Part No. 418511)). Remove 1/4 in. plug from back side of R-102 regulator and install fixed end of secondary expellant gas hose (included in hose/grommet package in 1/4 in. regulator outlet and wrench tighten.

If not already done, mount both boxes to a rigid surface using appropriate fasteners.

Fill tanks per instructions listed in Steps 3 and 4 on Page 5-3.

Next, route hose through grommets and wrench tighten into 1/4 in. inlet of the adaptor on the tank in the tank/ enclosure assembly. Also install hose to tank adaptor in regulated release and wrench tighten. See Figure 4-135 in "System Design" for details of hose routing.

REGULATED RELEASE ASSEMBLY/REGULATED ACTUATOR ASSEMBLY/DOUBLE TANK ENCLOSURE



SECTION 5 - INSTALLATION INSTRUCTIONS

UL EX3470 ULC EX3470

PAGE 5-2 **REV. 11** 2014-SEP-01

MOUNTING THE COMPONENTS (Continued)

OEM RELEASE/BRACKET ASSEMBLY




FIGURE 5-2

MOUNTING HOLE DIMENSIONS





FIGURE 5-3

CAUTION

- Do not install cartridge at this time. Failure to comply may
- result in accidental system actuation.
 - 2. Mount each tank-enclosure or tank-bracket assembly by completing the following steps:
 - a. Select a rigid, vertical surface for mounting the enclosure or bracket. (Keep in mind that the 3 gallon tank is taller than the bracket. (See Figure 5-4) Allow sufficient space for convenient piping and removal).
 - b. Remove tank from enclosure or bracket, and secure enclosure or bracket to the mounting location using the four mounting holes. Use appropriate type of fasteners depending on the mounting surface.

3 GALLON TANK BRACKET



SINGLE TANK ENCLOSURE/REMOTE RELEASE





FIGURE 5-4

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 5-3

MOUNTING THE COMPONENTS (Continued)

- 3. Fill each agent tank by completing the following steps:
 - a. Remove tank adaptor/tube assembly from tank fill opening. Visually inspect tank adaptor to determine bursting disc is in place and that silver side is away from tank. See Figure 5-5.



b.

⚠ CAUTION

Safety glasses should be worn during transfer operations of ANSULEX Low pH Liquid Fire Suppressant. Avoid contact with skin or eyes. In case of contact, flush immediately with water for 15 minutes. If irritation persists, contact a physician. Do not take internally. If taken internally do not induce vomiting. Dilute with water or milk and contact a physician immediately.

Place plastic funnel in fill opening and fill tank with 1.5 (5.8 L) or 3.0 (11.6 L) gallons of only ANSULEX Low pH Liquid Fire Suppressant. See Figure 5-6 for detailed filling tolerances. **Note:** Use a funnel with a screen to stop any foreign material from entering the tank. See Figure 5-6.

CAUTION

During filling, the agent temperature should be 60 °F to 80 °F (16 °C to 27 °C). **DO NOT FILL WITH COLD AGENT. DO NOT OVERFILL.** Overfilling may result in agent entering gas hoses and regulator potentially causing system malfunction.

2 1/4 IN. ± 1/8 IN. (57 mm ± 3 mm) FROM THE TOP OF THE COLLAR FOR THE 3.0 GALLON TANK OR 1 3/4 IN. ± 1/8 IN. (45 mm ± 3 mm) FROM THE TOP OF THE COLLAR FOR THE 1.5 GALLON TANK

STAINLESS STEEL TANKS

FIGURE 5-6

- Reinstall adaptor/tube assembly to tank by tightening until metal to metal contact is achieved between bottom of adaptor and tank collar.
- 4. Place each tank into its enclosure or bracket.

UL EX3470 ULC EX3470

PAGE 5-4 REV. 11 2014-SEP-01

INSTALLING THE DISTRIBUTION PIPING

Before the following procedures can be completed, the piping design must already be determined; and the actuation and expellant gas lines from the regulated release, each regulated actuator, and each tank-enclosure or tank-bracket assembly should already be installed.

These installation instructions are identical for single, double, and multiple-tank systems except for the quantity of tanks and hazard areas to be covered.

General Piping Requirements

1. Use Schedule 40 black iron, chrome-plated, or stainless steel pipe and fittings.

NOTICE

Do not use hot-dipped galvanized iron pipe or fittings in the agent distribution piping.

- Before assembling the pipe and fittings, make certain all ends are carefully reamed and blown clear of chips and scale. Inside of pipe and fittings must be free of oil and dirt.
- 3. The distribution piping and fitting connections, located in or above the hood or the protected area, must be sealed with pipe tape. When applying pipe tape, start at the second male thread and wrap the tape (two turns maximum) clockwise around the threads, away from the pipe opening.

NOTICE

Do not allow tape to overlap the pipe opening as the pipe and nozzles could become plugged.

Thread sealant or compound must not be used as it could plug the nozzles.

4. Distribution piping may be run independently or two agent tanks may be manifolded together and run to the predetermined hazard area. Only agent tanks expelled from the same cartridge may be manifolded.

NOTICE

Closely follow the piping requirements for each size system, as detailed in the "System Design" section, when installing distribution piping.

Branchline tees can be used to create more than one branch and can be installed as a thru tee, side outlet tee or bull tee.

Pipe Hanger Recommended Guidelines

1. Space hangers as follows:

Maximum Recommended
Pipe Size Distance Between Hangers

3/8 in. 5 ft (1.5 m)

2. Hangers should be placed between elbows when the distance is greater than 2 ft (0.6 m).

Piping Installation

- Starting at the tank, pipe directly from the union located on the tank adaptor. A reducing fitting may be necessary to conform to the distribution piping.
- Based on the piping sketch developed in the "System Design" section of this manual, install the supply line and position the tees at points where branch lines must be installed. See Figure 5-7.
- 3. Run all branch lines to the hazard area and connect each nozzle. (Make certain all piping is securely bracketed.)




FIGURE 5-7

0003

4. Make certain all threaded connections are properly tightened. Threaded connections located in the protected area(s) and above the hood must be sealed with Teflon pipe tape, as a minimum. Apply pipe tape to male threads only. Make certain tape does not extend over the end of the thread, as this could cause possible blockage of the agent distribution.

Pipe tape minimizes friction between bearing surfaces of the threads when threading pipe to fittings. The resulting heat may expand the pipe threads before the joint is properly made. When the pipe threads cool and contract in the fitting, the joint may become loosened causing cooking grease to migrate into the distribution piping, and/or leakage at the fitting during a pressure test or agent discharge.

Note: When required to provide pressure testing of pipe or a system discharge test, it is recommended that all pipe connections utilize Teflon pipe tape.

Install the correct nozzle(s) for each hazard area as previously designed. Some nozzles are required to be properly oriented before they are positioned for aiming.

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 5-5

INSTALLING THE DISTRIBUTION PIPING (Continued)


Piping Installation (Continued)

- 6. Aim the nozzles to a pre-determined aim point in accordance with the instructions in the "System Design" section. Using the Nozzle Aiming Device will aid in the aiming process. The device clamps to the nozzle and emits a small laser light that reflects on the surface where it is aiming. If the nozzle is used with a Swivel Adapter, the nozzle with the Aiming Device can be rotated to the exact aiming point and then tightened to hold that angle.
- 7. Before installing blow-off caps on nozzles, apply a small amount of Dow Corning No. 111 silicone grease across the opening in the nozzle tip. Also apply a small amount to coat the exterior of the blow-off cap. DO NOT FORCE SILICONE GREASE INTO NOZZLE TIP OPENING OR FILL CAP WITH GREASE.

NOTICE

When using old style metal blow-off cap with spring clips, make certain the spring clip rotates freely on the metal cap and coat the outside of the cap, including the clip, with Dow Corning No. 111 silicone grease.

 Make certain a blow-off cap is in place over each nozzle tip. These blow-off caps are designed to keep grease from building-up on the nozzle orifice and inhibiting the agent flow. See Figure 5-8.








FIGURE 5-8

INSTALLING THE AGENT DISTRIBUTION HOSE (FOR CASTERED/MOVEABLE EQUIPMENT)

Agent Distribution Hose can be used in the supply line or appliance branch line to allow a castered cooking appliance with castered supports with nozzles attached directly to the appliance, to be moved out of its normal operating position for service or cleaning.

CAUTION

The following instructions must be followed in their entirety. Failure to do so may result in the R-102 Fire Suppression System not functioning properly due to incorrect installation.

CRITICAL INSTALLATION REQUIREMENTS

- Design and installation must be performed by qualified personnel.
- The Agent Distribution Hose shall not be concealed within or run through any wall, floor, or partition, and shall not have any direct exposure to excessive heat or radiant flame from the cooking appliances.
- 3. Strong cleaning solutions or chemical substances must not come in contact with the Agent Distribution Hose. These may include acids, solvents, fluxes with zinc chloride, or other chlorinated chemicals. In case of contact, rinse down the Agent Distribution Hose with water and dry thoroughly.
- Contact with foreign objects, sharp edges, wiring, or substances must be avoided.
- 5. Bending and flexing of Agent Distribution Hose on moveable appliances (i.e. those factory equipped with casters) should be limited to pulling and pushing the appliances in or out for cleaning or maintenance. The hose shall never be installed or bent tighter than a 3 in. (76 mm) radius (6 in. (152 mm) diameter) loop.
- The Agent Distribution Hose must not be kinked, twisted, or have sharp bends when installed or when equipment is pulled away from the wall.
- 7. Make sure that all fittings are tightened properly.
- 8. Adequate means must be provided to limit the movement of castered appliances. A 36 in. (914 mm) long Restraining Cable supplied with the agent distribution hose is required to be used for all castered appliances using the Agent Distribution Hose. (Refer to Restraining Cable Installation Instructions.)
- 9. The Restraining Cable requires periodic maintenance to ensure proper operation.
- 10. The Restraining Cable must be attached to the wall and appliance anytime the distribution hose is connected to the appliance.
- 11. Do not over-extend the Agent Distribution Hose when moving equipment (for cleaning, maintenance, etc.).

AGENT DISTRIBUTION HOSE INSTALLATION INSTRUCTIONS

Before proceeding, CAREFULLY read all instructions, including all CRITICAL INSTALLATION REQUIREMENTS.

General Requirements

- The Agent Distribution Hose (which is part of the Discharge Hose and Restraining Cable Kit), is 0.5 in. (13 mm) diameter x 60 in. (1524 mm) long and is provided with two male NPT swivels for ease of installation.
- Maximum of six Agent Distribution Hoses can be used in each agent distribution piping network.
- 3. Agent Distribution Hose can only be used for castered appliances or appliances setting on castered supports.

UL EX3470 ULC EX3470

PAGE 5-6 REV. 11 2014-SEP-01

AGENT DISTRIBUTION HOSE INSTALLATION INSTRUCTIONS (Continued)

General Requirements (Continued)

- Maximum of two Agent Distribution Hoses are allowed in the supply line. However, the Agent Distribution Hose can only be used at the castered appliance.
- 5. Maximum of two Agent Distribution Hoses are allowed in the branch line. An acceptable installation scenario would be providing separate protection of two (side-by-side) appliances, each with its own Agent Distribution Hose and tether, supplied from the same appliance branch.
- 6. The Agent Distribution Hose is to only be used in the distribution piping of a single 1 1/2 or 3 gal (5.7 or 11.4 L) tank or two manifolded 3 gal (11.4 L) R-102 extinguishing systems or larger systems using combinations thereof. However, the Agent Distribution Hose is never to be used to manifold two 3 gal (11.4 L) tanks.

Installation Requirements

- 1. Agent Distribution Hose must be connected to 3/8 in. NPT black iron, chrome-plated, or stainless steel fittings. The connection from hose to fitting requires a 1/2 in. x 3/8 in. reducing coupling (Part No. 436228). All Agent Distribution Hose connections must be sealed with pipe tape. When applying pipe tape, start at the second male thread on the swivel ends of the hose. Wrap the tape (two turns maximum) clockwise around the threads, away from the hose end fitting opening.
- All connections of distribution piping to Agent Distribution Hose for castered appliances, with distribution nozzles installed/affixed to the appliance, must be located behind the cooking equipment in an area protected from obstructions and possible wear or damage.
- 3. 3/8 in. schedule 40 pipe will need to be run from the hose connection to the distribution nozzle(s) installed/affixed to the appliance. Pipe must be installed and adequately secured at a height at or below the cooking surface of the appliance. (See Figure 5-14.)
- 4. All existing distribution pipe and fitting limitations must be observed and followed. Each flex distribution hose used is to be considered as an equivalent length of 3/8 in. pipe when calculating the acceptable length of allowable distribution pipe. Each hose is 5 ft (1.5 m) long.
- All hose-to-pipe connection fittings are to be oriented in a vertical down position.
- 6. The hose connections must be positioned below an elevation where the hose could be exposed to the radiant or convected heat generated by normal cooking operations (such as the horizontal plane of appliance's cooking surface), or to heat from appliance exhaust. As a minimum height, the hose connection shall be no lower than 30 in. (762 mm) from the floor. The distribution piping shall be supported and secured per local plumbing practices.
- Hose ends are to be offset 6 to 8 in. (152 to 203 mm) center to center of fittings (See Figure 5-9) to maximize hose life expectancy and facilitate appliance movement. With the

appliance in its normal operating position, check the hose bend to make certain the bend is not less than a 3 in. (76 mm) bend radius (6 in. (152 mm) diameter).

OVERHEAD VIEW




FIGURE 5-9

Restraining Cable Installation

Important: A Restraining Cable shall always be permanently attached to the appliance and wall directly behind the appliance when the Agent Distribution Hose is installed. Removal of this cable shall only occur when the Agent Distribution Hose is not installed to the appliance.

See Figure 5-10 for mounting the Restraining Cable to the wall. See Figure 5-11 for mounting the Restraining Cable to the back of an appliance.

RESTRAINING CABLE - WALL-MOUNTED OPTION





FIGURE 5-10

RESTRAINING CABLE - APPLIANCE-MOUNTED OPTION



UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 5-7

AGENT DISTRIBUTION HOSE INSTALLATION INSTRUCTIONS (Continued)

Restraining Cable Installation (Continued)

RESTRAINING CABLE - HENNY PENNY-MOUNTED OPTION




FIGURE 5-12

- The Restraining Cable must be connected from the appliance to the wall or some other structurally sound object capable of restraining the castered appliance from being able to be pulled or pushed out to a point that will result in strain or stress to the Agent Distribution Hose.
- The Restraining Cable should be installed in line with the Agent Distribution Hose.
- 3. For sheet metal covered walls, the Restraining Cable Assembly includes four 3/4 in. x #8 self tapping sheet metal screws, and a Restraining Cable Bracket. Securely attach the Restraining Cable Bracket to the sheet metal covered wall using the 3/4 in. x #8 self tapping metal screws provided.
- For mounting to wall studs, the Restraining Cable Assembly includes one screw eye lag bolt, 5/16 in. x 2.5 in. (64 mm) long.
- 5. Locate a structural area (frame) on the rear side of the equipment that is in line with the wall attachment. **Note:** It may be necessary to contact the appliance manufacturer for a suitable location. Drill a 5/16 in. (7.9 mm) diameter hole. Use caution when drilling hole, so that internal components are not damaged.
- 6. The Restraining Cable Assembly also includes a 5/16 in. threaded eye-bolt, 5/16 in. hex head nut, 5/16 in nylon lock nut, and two 5/16 in. flat washers. Thread the included hex nut onto the eye-bolt. Slide one washer onto the eye-bolt threads next to the nut. Then, slide the eye-bolt through the drilled hole and place a washer and nylon locknut onto the eye-bolt on the inside frame of the equipment. Tighten securely.
- 7. Attach one of the snap hooks (included in the Restraining Cable package) on the end of the Restraining Cable to the wall bracket and the other snap hook to the eye-bolt (See Figure 5-13). After snap-hooking the assembly, seal the Restraining Cable Loops to the wall bracketry and appliance connection hardware with Lead Wire Seal (Part No. 197).

Note: For the Henny Penny Pressure Fryers that utilize the ANSUL Henny Penny Fryer Nozzle Kit, Part No. 434455, the 5/16 in. philips screw supplied in the Henny Penny Fryer Nozzle Kit, the 5/16 in. eye nut, and 5/16 in. washer included in the Restraining Cable Assembly Kit, must be used. (See Figure 5-12).




FIGURE 5-13

Final Installation Guidelines and Checkout Procedures

After the Agent Distribution Hose and the Restraining Cable is properly installed, carefully push the appliance back to its normal operating position. Check that the hose does not have sharp bends, and is not kinked, twisted, or caught on anything behind the appliance.

- Verify the Restraining Cable limits the travel of the appliance and prevents the application of any pull force or bending stress on the Agent Distribution Hose or hose-topipe connections.
- 2. Make certain there are no sharp bends and kinks in the hose when pulling out the cooking equipment.
- 3. The Agent Distribution Hose should always be in a vertical natural loop, never having any bends greater than a 3 in. (76 mm) radius (6 in. (152 mm) diameter), hose twists, or sharp bends. (See Figure 5-14.) If any of these conditions exist, the hose and/or hose connections will require installation modifications.

UL EX3470 ULC EX3470


PAGE 5-8 REV. 11 2014-SEP-01

AGENT DISTRIBUTION HOSE INSTALLATION INSTRUCTIONS (Continued)

Final Installation Guidelines and Checkout Procedures (Continued)

SIDE VIEW

ACCEPTABLE HOSE ORIENTATION



UNACCEPTABLE HOSE ORIENTATION







FIGURE 5-14

0078

4. Return the appliance to its normal operating position in accordance with NFPA 96. Means shall be provided to verify that the appliance returns to its original designed positioning. Failure to do so may result in undue stress and fatigue of the hose and hose connections.

INSTALLING THE ACTUATION AND EXPELLANT GAS LINE

Before installing any actuation or expellant gas line, the design must be determined; and the regulated release assembly, each regulated actuator assembly and each tank-bracket assembly should be securely mounted.

General Piping Requirements

- 1. Use only 1/4 in. Schedule 40 black iron, hot-dipped galvanized, chrome-plated, or stainless steel pipe and fittings.
- Before assembling the pipe and fittings, make certain all ends are carefully reamed and blown clear of chips and scale. Inside of pipe and fittings must be free of oil and dirt.
- 3. The piping and fitting connections must be sealed with pipe tape. When applying pipe tape, start at the second male thread and wrap the tape (two turns maximum) clockwise around the threads, away from the pipe opening.

NOTICE

Do not allow tape to overlap the pipe opening, as this could cause possible blockage of the gas pressure.

Thread sealant or compound must not be used.

 When connecting actuation or expellant gas line piping, install a 1/4 in. union near the tank inlet for easy disassembly later.

Note: Expellant gas line cannot use stainless steel braided hose.

Actuation Gas Line

Install actuation gas line from the regulated release mechanism high pressure side outlet (side opposite regulated outlet) through the appropriate knockout in the enclosure by completing the following steps:

- 1. Remove the 1/8 in. plug from high pressure side outlet. Install the appropriate fitting for additional equipment attachment as required. A 1/4 x 1/8 in. reducing fitting is required to connect the 1/4 in. actuation line. See Figure 5-15.
- Run piping or hose up through the regulated release assembly enclosure knockout to the inlet on top of each regulated actuator assembly used within the system.

UL EX3470 ULC EX3470

2014-SEP-01 REV. 11 PAGE 5-9

INSTALLING THE ACTUATION AND EXPELLANT GAS LINE (Continued)

Actuation Gas Line (Continued)


 The total combined length of the actuation gas line from the regulated release assembly to all regulated actuator assemblies must not exceed 20 ft (6 m) when using an LT-20-R nitrogen cartridge, an LT-30-R nitrogen cartridge, a 101-10 CO₂ cartridge, or a 101-20 CO₂ cartridge. See Figure 5-16.


Note: When using stainless steel actuation line, a maximum of 17.5 ft (5.3 m) of hose may be used.

- 4. If an expellant gas line is connected to the regulated release assembly along with an actuation gas line, the total combined length of the actuation and expellant gas line must not exceed 30 ft (9.1 m). See Figure 5-17.
- A combined total of nine fittings may be used in these lines, eight 90° elbows and one tee. Two 45° elbows equal one 90° elbow.


Typical Arrangements for a One Device Connection to Cartridge Receiver










Typical Arrangements for a Two Device Connection to Cartridge Receiver










Typical Arrangements for a Three Device Connection to Cartridge Receiver







Typical Arrangements for Regulator Connections



SINGLE TANK

DOUBLE AND MULTIPLE TANKS

NOTE: WHEN PIPE IS USED, ALL PIPE AND FITTINGS SHALL BE SCHEDULE 40 (STANDARD WEIGHT) BLACK IRON, HOT-TIPPED GALVANIZED, CHROME-PLATED, OR STAINLESS STEEL.

UL EX3470 ULC EX3470

PAGE 5-10 REV. 11 2014-SEP-01

INSTALLING THE ACTUATION AND EXPELLANT GAS LINE (Continued)

Actuation Gas Line (Continued)





FIGURE 5-16



UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 5-11

INSTALLING THE ACTUATION AND EXPELLENT GAS LINE (Continued)

Expellant Gas Line From The Regulated Release Assembly

Install expellant gas line from the regulated release assembly regulator in the enclosure by completing the following steps:


- 1. The regulated release assembly is shipped with a factory-installed regulator. The regulator has two 1/4 in. outlets, one at the back and one at the bottom. The bottom outlet connects the expellant gas hose to the agent tank which is mounted inside the enclosure. The back outlet is sealed with a 1/4 in. plug.
- 2. Connect expellant gas hose to the agent tank mounted inside the enclosure.

TWO TANK, THREE TANK, AND MULTIPLE TANK SYSTEMS:

If the expellant gas piping is required because an additional tank-enclosure or tank-bracket assembly is being installed, the plug installed in the back outlet must be removed. (See Figure 5-6 for proper connections to the regulator.)

Pipe the 1/4 in. expellant gas line from the regulator back outlet through one of the knockouts provided in the enclosure.

The total length of the expellant gas line from the regulated release assembly **must not** exceed 30 ft (9.1 m) when using a "double-tank" nitrogen cartridge or a 101-30 $\rm CO_2$ cartridge. See Figure 5-18.



4. If an actuation gas line is connected to the regulated release assembly along with an expellant gas line, the total combined length of the gas lines **must not** exceed 30 ft (9.1 m) when using a "double-tank" nitrogen cartridge or a 101-30 CO₂ cartridge. See Figure 5-17.

 A combined total of nine fittings may be used in these lines, eight 90° elbows and one tee. Two 45° elbows equal one 90° elbow.

Expellant Gas Line From The Regulated Actuator Assembly

Install expellant gas piping from the regulated actuator assembly regulator through the appropriate knockout in the enclosure by completing the following steps:

- 1. The regulated actuator is shipped with a factory-installed regulator. The regulator has two 1/4 in. outlets 135° from each other. One outlet is sealed by a 1/4 in. plug and the other contains the expellant gas hose for the agent tank which will be mounted within the enclosure. Connect expellant gas hose to the agent tank that is mounted inside the enclosure.
- Remove the 1/4 in. pipe plug from the regulator side outlet and pipe the 1/4 in. expellant gas line from the regulator through the knockout provided in the enclosure to a tank-enclosure or tank-bracket assembly. A maximum of one tank-enclosure or tank-bracket assembly is allowed per regulated actuator assembly.

The maximum length of the expellant gas line from the regulated actuator to the tank-bracket assembly must not exceed 30 ft (9.1 m). See Figure 5-19.

 A total of nine fittings may be used in these lines, eight 90° elbows and one tee. Two 45° elbows equal one 90° elbow.




FIGURE 5-19

UL EX3470 ULC EX3470

PAGE 5-12 REV. 11 2014-SEP-01

INSTALLING THE ACTUATION AND EXPELLENT GAS LINE (Continued)

Actuation Gas Line From Remote Release(s) to Regulated Actuators

Install actuation gas piping from the remote release(s) to the regulated actuators by completing the following:

 Pipe the 1/4 in. actuation gas line from the 1/4 in. outlet in the remote release receiver, through the knockout provided in the top of the release enclosure, to each regulated actuator assembly.

The maximum length of the actuation gas line from the remote release to all regulated actuators **must not** exceed 100 ft (30.4). See Figure 5-20.

- A maximum of nine tees and twenty elbows are allowed in the actuation piping. Two 45° elbows equal one 90° elbow. See Figure 5-20.
- 3. A safety relief valve (Part No. 15677) must be installed in the actuation piping. See Figure 5-20.

Actuation Gas Line - 15* Tanks Maximum - Using 1/4 in. Stainless Steel Hose

Note: Not for use with expellent gas line.

- 1. Maximum hose length cannot exceed 17.5 ft (5.3 m). See Figure 5-21.
- 2. Maximum of five regulated actuators allowed.
- Actuated with Remote Release (Part No. 433485) or Regulated Release Assembly (Part No. 429853).





FIGURE 5-20

00030



NOTE: WHEN MULTIPLE RELEASE ASSEMBLIES ARE UTILIZED, A 1/4 IN. CHECK VALVE (PART NO. 25627) WILL BE REQUIRED AFTER EACH REGULATED RELEASE.

UL EX3470 ULC EX3470 PAGE 5-13

2014-SEP-01 **REV. 11**

INSTALLING THE DETECTION SYSTEM

Before the following procedures can be completed, the detection design must already be completed. These installation instructions are identical for single, double, and multiple-tank systems except for the number of hazard areas to be covered.

NOTICE

Inform customer that fusible links should not be exposed to ammonia-based chemical cleaners or steam.

NOTICE

No attempt is to be made to disassemble, repair, or clean a Model SL or Model A-PC fusible link. The complete assembly must be replaced if there is any sign of potential malfunction.

- 1. Based on the requirements listed in the "System Design" section, mount the detectors in their predetermined loca-
- 2. Run 1/2 in. conduit from the regulated release mechanism trip hammer assembly knockout hole to locations selected for mounting the detectors.

Note: Before assembling the conduit and fittings, make certain all ends are carefully reamed and blown clear of chips and scale. Inside of pipe and fittings must be free of oil and dirt.

When changing the direction of conduit, use only ANSUL pulley elbows, except, at the top of the regulated release, it is acceptable to use the Conduit Offset Assembly.

Note: If stainless steel scissor linkage is used in the system while using conduit offset assembly, the following limitations must be observed:

- · Maximum number of elbows 16
- · Maximum number of detectors 15
- Maximum length of 1/2 in. EMT Conduit 150 ft (45.7 m)

Part No. 435546 and 435547 are the "scissor" style series and terminal detector assemblies. These detector assemblies use a detector linkage assembly which does not require the wire rope to be threaded through the linkage assembly while it is being fed through the detection system.

"Scissor" Style Linkage Installation

1. Secure the conduit to the detector bracket using the two 1/2 in. steel compression fittings on the series detector bracket or the single 1/2 in. steel compression fitting on the terminal detector bracket. See Figure 5-22.




FIGURE 5-22

NOTICE

Do not use zinc die cast compression connectors on the detection conduit lines as these will not withstand the normally high temperatures experienced in the plenum area.

2. For a terminal detector located in a duct or header opening, secure both sides of the detector bracket with conduit, as shown in Figure 5-23.




FIGURE 5-23

ULC EX3470 UL EX3470

PAGE 5-14 **REV. 11** 2014-SEP-01

INSTALLING THE DETECTION SYSTEM (Continued)

"Scissor" Style Linkage Installation (Continued)

3. Starting at the release assembly, feed the wire rope through the hole in the release mechanism locking clamp, allowing the excess wire rope to hang down. (Do not tighten set screws in locking clamp at this time.) See Figure 5-24.




FIGURE 5-24

4. From the release assembly, run the stainless steel wire rope through the conduit, pulley elbows and detector brackets to the terminal detector.

NOTICE

If wire rope requires splicing, make certain splice is at least 12 in. (305 mm) away from any pulley elbow or conduit adaptor to avoid interference.

5. Feed the wire rope through the terminal detector bracket as shown in Figure 5-25 or as shown in Figure 5-26 if the terminal detector is mounted within a duct or header opening, and install the stop sleeve approximately 2 to 3 in. (51 to 76 mm) from the end of the wire rope. See Figure 5-27. Use the National Telephone Supply Company Nicopress Sleeve Tool (Stock No. 51-C-887) or equal to properly crimp the stop sleeve.




FIGURE 5-25




FIGURE 5-26




FIGURE 5-27


6. To give a constant tension on the wire rope during installation of the detector linkage, hang a vice grip or other weighted device on the excess stainless steel wire rope, leaving an adequate length of spare wire rope between the locking clamp and the weighted device.

NOTICE

When attaching the weighted device to the excess wire rope, allow approximately 3 in. (76 mm) of wire rope for each detector linkage for proper installation.

Example: If the system has six detectors, there should be approximately 18 in. (457 mm) of excess wire rope between the locking clamp and the weighted device, which will be utilized when the linkage is put in place.

7. Install detector scissor assembly as shown in Figure 5-28. Note that the AUTOMAN release or remote release assembly is located on the left side of the detector bracket. Slightly crimp the two assembly "boot-hooks" over the cable with pliers so the cable is captured under each hook but the whole assembly can move from side to side. Center the assembly in the detector bracket.




UL EX3470 ULC EX3470

2014-SEP-01 REV. 11 PAGE 5-15

INSTALLING THE DETECTION SYSTEM (Continued)

"Scissor" Style Linkage Installation (Continued)

8. Hook the fusible link on the AUTOMAN release or remote release assembly side of the hook assembly, then pull the fusible link to the opposite side and complete the hookup as shown in Figures 5-29 and 5-30. The top of the hook assembly must be inside the bracket stiffeners. The hook assembly with the ANSUL fusible link in place must be located toward the terminal detector side of the bracket.



▶ 10. Insert cocking lever (Part No. 441042 or Part No. 441041) on left side of the release mechanism, with the movable flange resting securely against the corner of the cartridge receiver and spring housing, and with the notched lever portion engaging the cocking pin on **both** sides of the release mechanism. See Figure 5-32.




FIGURE 5-32

▶ 11. Using long handle cocking lever (Part No. 441041) or wrench on short handle cocking lever (Part No. 441042), pull down to raise cocking pin until the trip lever indented surface moves underneath the pin and locks the pin in the




FIGURE 5-33




FIGURE 5-30

9. Install the linkage and the correct ANSUL approved fusible link in the remainder of the detector brackets. Make certain all detector linkages are positioned against either the front or back upper lip of the formed detector bracket. See Figure 5-31.




FIGURE 5-31

UL EX3470 ULC EX3470

PAGE 5-16 REV. 11 2014-SEP-01

INSTALLING THE DETECTION SYSTEM (Continued)

"Scissor" Style Linkage Installation (Continued)

12. Remove cocking lever and fully insert Lock Pin (Part No. 438031) through the hole in the trip lever on the left side of the release. (The release mechanism cannot be actuated, nor can enclosure cover be replaced until the lock pin is removed.) See Figure 5-34.




FIGURE 5-34

13. Make certain tension lever is in the "UP" position. See Figure 5-35.




FIGURE 5-35

14. Verify each detector linkage assembly, with correct fusible link, is in the detector bracket, located fully toward the terminal detector side.

NOTICE

Due to the close adjustment between the trip hammer and cable lever assemblies, use only the particular fusible link(s) selected for installation in each detector, including terminal detector, to ensure correct adjustment when performing Steps 15 and 16.

- 15. Raise trip hammer 3/8 in. to 1/2 in. (9.5 to 12.7 mm), pull all slack out of wire rope, and tighten set screws on locking
- 16. Lower tension lever to "DOWN" position and inspect the base of the wire rope locking clamp to make certain that there is a minimum of 1/4 in. (6.4 mm) and a maximum of 3/8 in. (9.5 mm) clearance between the base of the trip hammer locking clamp assembly and the cable lever assembly. See Figure 5-36. (If clearance is not between 1/4 in. (6.4 mm) or 3/8 in. (9.5 mm), raise tension lever, loosen set screws on locking clamp and repeat Steps 15 and 16.)

CAUTION

Make certain the hook assembly with the ANSUL fusible link in place is located toward the terminal detector side of each bracket. Failure to do so may restrict travel of detection line, causing system to malfunction.




FIGURE 5-36

CAUTION

Do not install cartridge at this time as an accidental actuation could cause system discharge.

- 17. Test detection system in accordance with the Testing and Placing in Service Section, Page 6-3 – 6-4, of this manual.
- 18. When testing has been completed, cut off excess wire rope in the regulated release assembly, leaving approximately 2 in. (51 mm) of wire rope below the locking clamp.

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 5-17

INSTALLING REMOTE MANUAL PULL STATION

GENERAL INSTALLATION REQUIREMENTS

To install a remote manual pull station complete the following steps:

 Make certain that regulated release assembly enclosure cover is detached and lock pin is properly inserted within the regulated release mechanism.

NOTICE

Failure to follow these instructions may lead to system actuation.

- 2. Verify that cartridge has been removed from regulated release assembly and that the regulated release assembly is in the cocked position.
- If regulated release assembly does not have lock pin inserted or cartridge removed, refer to the "Semi-Annual Maintenance," Page 8-1, in "Maintenance Examination" section, and complete Steps 2 and 3 before completing the following installation steps.
 - 3. Select a convenient location in the path of egress for mounting the pull station(s) to the wall. The pull station should be installed at a height of 42 in. to 48 in. (1067 mm to 1219 mm) in accordance with the authority having jurisdiction and the American Disabilities Act (ADA) requirements.

A maximum of two manual pull stations can be connected to each AUTOMAN release.

INSTALLATION FOR REMOTE MANUAL PULL STATION UTILIZING EMT CONDUIT ONLY

- The total length of the wire rope used for each manual pull station within a system must not exceed 150 ft (45.7 m).
 - The maximum number of pulley elbows that may be used per each manual pull station is 20.
- If junction box(es) is used, fasten a 4 in. (102 mm) junction box to wall or in wall where pull station is to be mounted, with mounting screws positioned so that when pull station cover is positioned in place, the printing will appear right side up and readable.
- Install and secure 1/2 in. conduit, pulley tee (if required), and pulley elbows from each pull station junction box to regulated release assembly as necessary. See Figure 5-37.
 See Figures 5-38 thru 5-40 for optional methods of installing wire rope when utilizing a pulley tee.




FIGURE 5-37

REMOTE MANUAL PULL STATION DUAL APPLICATION – OPTION 1 (ONE WIRE ROPE CONNECTED TO CABLE LEVER ASSEMBLY)




FIGURE 5-38

009464

REMOTE MANUAL PULL STATION DUAL APPLICATION - OPTION 2 (TWO WIRE ROPES CONNECTED TO CABLE LEVER ASSEMBLY)




FIGURE 5-39

UL EX3470 ULC EX3470

PAGE 5-18 REV. 11 2014-SEP-01

INSTALLING REMOTE MANUAL PULL STATION (Continued)

INSTALLATION FOR REMOTE MANUAL PULL STATION UTILIZING EMT CONDUIT ONLY (Continued)

REMOTE MANUAL PULL STATION APPLICATION - OPTION 3





FIGURE 5-40



TWO WIRE ROPES CONNECTED BETWEEN A PULLEY ELBOW AND A PULLEY TEE

FIGURE 5-41

4. Feed wire rope from the AUTOMAN release through conduit and pulley elbows and pulley tee, if provided, to the pull station junction box. Follow the instructions for assembling the pull station and block assembly and attaching the wire rope to the pull station pull knob (see Figures 5-70 through 5-85).

NOTICE

Make certain that wire rope rides on top and in center of pulley sheave. If the 50 ft (15.2 m) wire rope has been spliced to accommodate a longer run, do not allow the spliced ends to be within 6 in. (153 mm) of any pulley elbow or conduit adaptor.

- Fasten pull station assembly to each junction box (if junction box is used).
- Slide oval crimp sleeve onto wire rope. Loop wire rope through cable lever guide holes and back through the oval crimp sleeve. See Figure 5-37.
- Pull slack out of each wire rope and crimp sleeve. (Use the National Telephone Supply Company Nicopress Sleeve Tool Stock No. 51-C-887 or equal to properly crimp stop sleeve.) See Figure 5-37.

Note: When utilizing flexible conduit for remote manual pull station or mechanical gas valve installation, refer to "Installation of Remote Manual Pull Station or Mechanical Gas Valve Utilizing Flexible Conduit" instructions on pages 5-22 through 5-34.

INSTALLING MECHANICAL GAS VALVE

NOTICE

Mechanical gas valves are designed for indoor installation only.

To install each Mechanical Gas Shut-off Valve complete the following steps. (All gas valve installation and testing shall be made in accordance with the authority having jurisdiction.)

Note: Mechanical gas valve air cylinder(s) can be installed in regulated release assemblies and also regulated actuator assemblies. Installation in either is the same.

 Make certain that regulated release assembly enclosure cover is detached and lock pin is properly inserted in the regulated release mechanism.

NOTICE

Failure to follow these instructions may lead to system actuation.

- Verify that cartridge has been removed from regulated release assembly and that the regulated release mechanism is in the cocked position.
- If regulated release mechanism does not have lock pin inserted or cartridge removed, refer to the "Semi-Annual Maintenance," Page 8-1, in "Maintenance Examination" section, and complete Steps 2 and 3 before completing the following installation steps.

2014-SEP-01 REV. 11 PAGE 5-19

INSTALLING MECHANICAL GAS VALVE (Continued)

3. Remove plug from cartridge receiver. See Figure 5-42.




FIGURE 5-42

000

4. Locate air cylinder and bracket assembly over the two 7/32 in. (5.6 mm) holes on right side of the enclosure. Assemble with screws, lockwashers, and nuts. Wrench tighten. See Figure 5-43. Air cylinder(s) can also be mounted in the inverted position, allowing for direct exit out the knockout(s) in the bottom of the enclosure. See Figure 5-44.

FOR MOUNTING ONE MECHANICAL GAS VALVE




FIGURE 5-43

00034





FIGURE 5-44

000341

Note: Two air cylinders are necessary only if the old style pulley tee (Part No. 15342) is utilized. If new style pulley tee (Part No. 427929) is utilized, only one air cylinder is required. Individual wire ropes can be run from each gas valve to a single air cylinder. See Figure 5-45.

5. To install second mechanical gas valve shut-off system, locate second air cylinder and bracket assembly adjacent to first assembly and over the two remaining 7/32 in. (6 mm) holes provided on right side of the enclosure. Assemble second cylinder with screws, lockwashers, and nuts as required. Wrench tighten. See Figure 5-45.

SYSTEMS USING PULLEY TEE (PART NO. 15342)



SYSTEMS USING PULLEY TEE (PART NO. 427929)

NOTE: NO ELBOWS ARE ALLOWED BETWEEN




FIGURE 5-45

UL EX3470 ULC EX3470

PAGE 5-20 REV. 11 2014-SEP-01

INSTALLING MECHANICAL GAS VALVE (Continued)

 Install the necessary 1/8 in. copper tubing and fittings for each air cylinder to the accessories piping arrangement on the regulated release mechanism. See Figures 5-43 and 5-45.

NOTICE


Do not kink 1/8 in. copper tubing or form a bend too close to a fitting. Secure each fitting without over tightening. Over tightening could result in pressure leakage or line separation at actuation.


To reduce the risk of explosion due to leaking gas, make certain that the gas line is turned off before connecting the gas valve. Failure to comply may result in serious personal injury or death. Gas valve installation shall be performed by qualified individuals in accordance with local jurisdiction requirements.

Install mechanical gas valve to its selected location in gas line so that it ensures safe shut-off to all predetermined appliances being protected upon actuation of the system. Mechanical gas valves may be mounted in any convenient horizontal or vertical position. See Figure 5-46.


- Use new pipe, properly reamed and cleaned of metal chips.
- b. Make certain gas flow is in the same direction as arrow shown on gas valve. To avoid cracking the gas valve casting, do not overtighten pipe connections. If pipe tape, paste, spray, or similar lubricant is used, extra care should be taken to avoid overtightening. Apply lubricant to male threads only.
- c. Wrench tighten pipe to gas valve. DO NOT USE GAS VALVE AS A LEVER WHEN INSTALLING OR VALVE DAMAGE MAY OCCUR. See Figure 5-46.
- d. If strainer is utilized, attach strainer ahead of gas valve.
- e. If necessary, install drip leg in gas line in accordance with the authority having jurisdiction.
- f. The total length of wire rope allowed for each valve must not exceed 150 ft (45.7 m).
- g. The maximum number of pulley elbows allowed for each gas valve is 20.


ANSUL MECHANICAL GAS VALVES





ASCO MECHANICAL GAS VALVES





UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 5-21

INSTALLING MECHANICAL GAS VALVE (Continued)

- Install 1/2 in. conduit, and pulley elbow(s) from the mechanical gas valve to regulated release assembly enclosure as necessary.
- Beginning at the regulated release assembly, thread the end of the wire rope through hole provided in air cylinder rod. See Figure 5-43.
- Feed end of wire rope through conduit and each pulley elbow.
 - Make certain that wire rope rides on top and in center of pulley sheave. If the 50 ft (15.2 m) wire rope has been spliced to accommodate a longer run, do not allow the spliced ends to be within 12 in. (305 mm) of any pulley elbow or conduit adaptor.
- 11. Remove side cover on gas valve and thread end of wire rope through hole in cocking lever. Slide stop sleeve (Part No. 26317) on to wire rope and crimp. (Use the National Telephone Supply Company Nicopress Sleeve Tool Stock No. 51-C-887 or equal to properly crimp stop sleeve.) Make certain crimp is on top of trigger, with wire rope curled under lever. See Figure 5-47.





FIGURE 5-47

- 12. With the end of wire rope already threaded through hole in air cylinder rod, slide stop sleeve (Part No. 26317) onto wire rope and leave loose. Do not crimp stop sleeve at this time. See Figure 5-43.
- Cock mechanical gas valve as shown in Figure 5-48.
 Note: A valve cocking tool is available. Order Part No. 416018.

ANSUL MECHANICAL GAS VALVE



ASCO MECHANICAL GAS VALVE




FIGURE 5-48


- 14. Raise air cylinder rod "UP" to its maximum extended position. See Figure 5-43.
- 15. Manually pull wire rope to remove excess slack.

NOTICE

DO NOT ACTUATE THE MECHANICAL GAS VALVE. Each Mechanical Gas Valve System must have gas valve cocked and air cylinder rod extended "UP" to its maximum extension before completing next step.

- Slide stop sleeve against air cylinder rod, make certain all slack is removed from wire, and crimp stop sleeve. See Figure 5-43.
- 17. Cut off any excess wire rope approximately 3/4 in. (19 mm) from end of stop sleeve.
- 18. Note: If utilizing a pulley tee to operate either a single mechanical gas valve from two AUTOMAN releases or two mechanical gas valves from one air cylinder in an AUTOMAN release, see Figures 5-49 and 5-50 for installation instructions. Maximum length of wire rope to each AUTOMAN release must not exceed 150 ft (45.7 m) and maximum number of elbows must not exceed 20.

TWO AIR CYLINDERS - ONE MECHANICAL GAS VALVE




UL EX3470 ULC EX3470

PAGE 5-22 REV. 11 2014-SEP-01

INSTALLING MECHANICAL GAS VALVE (Continued)

ONE AIR CYLINDER - TWO MECHANICAL GAS VALVES



NOTICE

When connecting two mechanical gas valves to one air cylinder, make certain both gas valves properly operate (close) when the air cylinder rod is in the down (operated) position.

INSTALLATION OF REMOTE MANUAL PULL STATION OR MECHANICAL GAS VALVE UTILIZING FLEXIBLE CONDUIT

Flexible conduit allows for quicker installations and the convenience of being able to route the cable over, under and around obstacles.

Flexible conduit can be used as a substitute for standard EMT conduit or can be used with EMT conduit.

NOTICE

Flexible conduit can be used only with NEW Remote Pull Station (Part No. 434618) and mechanical gas valve installations. Flexible conduit is intended for indoor use ONLY.

These instructions address the components and installation of both the pull station (Part No. 434618) and the flexible conduit.

Design Requirements

- · Flexible conduit cannot be utilized in detection systems.
- Flexible conduit inserts (Part No. 434347) can ONLY be used with the flexible conduit system.
- The maximum distance from an AUTOMAN release to a pull station is 140 ft (42.6 m) with a maximum of 360° (for example, 3-90° and 2-45° bends, 2-90° and 4-45° bends, etc.) bends in the flexible conduit, one pulley tee (refer to pages 5-31 through 5-33 for detailed splicing instructions), two splices, and 15 pulley elbows.

Note: When installing flexible conduit, make sure to feed wire rope through conduit directly from the spool. DO NOT pre-cut wire rope. Feeding pre-cut rope through flexible conduit will cause excessive kinks in the rope, making it difficult to install.

- The maximum distance from an AUTOMAN release to a mechanical gas valve is 75 ft (22.8 m) with a maximum of 4-90° bends in the flexible conduit and 4 pulley elbows.
- Any portion of the flexible conduit system can be substituted with EMT conduit provided the proper connections are used to join the two types of conduit.
- All bends in the flexible conduit system must have a minimum bend diameter of 6 in. (153 mm).
- When the flexible conduit is used to make 90° bends between an AUTOMAN release and a mechanical gas valve, the bends must start at the gas valve. No pulley elbows can be used between the bends. If more than 360° of bends are needed, then pulley elbows can be used.
- When the flexible conduit is used to make 90° bends between an AUTOMAN release and a pull station, the bends must start at the AUTOMAN release. No pulley elbows can be used between the bends. If more than 360° of bends are needed, then pulley elbows can be used.
- When not utilizing a conduit offset 2-45° bends in the flexible conduit are allowed between the strain relief fitting on top of the AUTOMAN release, and the location where the flexible conduit is supported.
- When installing flexible conduit, conduit should be secured at intervals not to exceed 5 ft (1.5 m) and before and after each bend. Flexible conduit CANNOT slide in the clamp(s) used for mounting. Make certain mounting clamp(s) do not pinch the conduit. The following style clamp ('P' clip) (Part No. 436150)
- is a suitable type for use on flexible conduit. See Figure 5-51.




FIGURE 5-51

TABLE 1

		Mechanical	
<u> </u>	Manual Pull	Gas Valve	Detection
90° Cable Bends	4	4	N/A
Bend Diameter - in. (mm)	6 (153)	6 (153)	N/A
Mechanical Corner Pulley	15	4	N/A
Conduit Secured Max. ft (m) 5 (1.5)	5 (1.5)	N/A
Conduit Max. Length ft (m)	140 (42.6)	75 (22.8)	N/A
Conduit Offset / 2-45° Bend (Only between strain relief fitting and support location		0	N/A
Pulley Tees	1	0	N/A
Splices	2	0	N/A

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 5-23

INSTALLATION OF REMOTE MANUAL PULL STATION OR MECHANICAL GAS VALVE UTILIZING FLEXIBLE CONDUIT (Continued)

Installation Instructions

Note: Do not add any type of lubricants inside or on the flexible conduit. Make certain stainless steel wire rope is clean and debris-free.

The flexible conduit should be routed along the same path that EMT conduit would normally be run. Stainless steel wire rope should be routed through the flexible conduit as it is in EMT conduit.

DO NOT cut the wire rope to length before feeding it into the flexible conduit. The wire rope should be fed directly from its spool through the flexible conduit. This method will help avoid possible kinking of the wire rope which can make it difficult to feed.

⚠ CAUTION


Flexible conduit must not be located within 6 in. (153 mm) of the hood or in areas exceeding 130 °F (54 °C). Also, do not route flexible conduit in areas where conduit can be crushed, pinched, or broken.

Flexible conduit can be used to connect an AUTOMAN release to a remote pull station or mechanical gas valves.

Before starting the system installation, take a few minutes to plan the layout of the system. This will minimize the amount of components needed to complete the installation. Once the path of the flexible conduit has been determined, verify that the layout does not exceed the design requirements.

Connecting the Flexible Conduit to the AUTOMAN Release, Electrical Junction Box, or MECHANICAL Gas Valve

 Layout the flexible conduit and secure it in place. Note: If inner liner is crimped, turn a drywall screw into the end to open it. See Figure 5-52.



IGUIL 3-3

Starting at the AUTOMAN release, connect the conduit connector using the supplied nut. Use only ANSUL conduit fittings (Part No. 55813). See Figure 5-53.




FIGURE 5-53

Unscrew the nut from the EMT conduit connector and remove the compression ring. Discard ring. See Figure 5-54.




FIGURE 5-54

 Thread the stainless steel wire rope through the EMT conduit connector and flexible conduit insert. Make certain thread in flexible conduit insert is facing out toward end of connector. See Figure 5-55.




FIGURE 5-55

UL EX3470 ULC EX3470

PAGE 5-24 REV. 11 2014-SEP-01

INSTALLATION OF REMOTE MANUAL PULL STATION OR MECHANICAL GAS VALVE UTILIZING FLEXIBLE CONDUIT (Continued)

Connecting the Flexible Conduit to the AUTOMAN Release, Electrical Junction Box, or Mechanical Gas Valve (Continued)

Tighten the nut to the connector body, locking the flexible conduit insert in place. See Figure 5-56.




FIGURE 5-56

Loosen the nut on the strain relief and thread the wire rope through a strain relief. See Figure 5-57.




FIGURE 5-57

7. Tighten the body of the strain relief to the conduit connector. See Figure 5-58.




FIGURE 5-58

8. Thread the wire rope through the flexible conduit. See Figure 5-59. (If a splice is required in the flexible conduit, proceed to "Splicing Installation Instructions."




FIGURE 5-59

9. Slide the flexible conduit into the strain relief until it is approximately 1/16 in. (1.6 mm) from the bottom of the flexible conduit insert. See Figure 5-60.




FIGURE 5-60

10. Tighten the strain relief nut onto the strain relief. See Figure 5-61.




FIGURE 5-61

UL EX3470 **ULC EX3470** 2014-SEP-01 REV. 11 PAGE 5-25

INSTALLATION OF REMOTE MANUAL PULL STATION OR MECHANICAL GAS VALVE UTILIZING FLEXIBLE CONDUIT (Continued)

Connecting Flexible Conduit to Pulley Elbows, Pulley Tees, or Union Fittings

1. Unscrew the nut from pulley elbow, pulley tee, or EMT conduit connector and remove the compression ring. Discard ring. See Figure 5-62.




FIGURE 5-62

2. Thread the stainless steel wire rope through the EMT conduit connector and flexible conduit insert. Make certain thread in flexible conduit insert is facing out toward end of connector. See Figure 5-63.




FIGURE 5-63

3. Tighten the nut to the connector conduit body, locking the flexible conduit insert in place. See Figure 5-64.




FIGURE 5-64

4. Loosen the nut on the strain relief and thread the wire rope through the strain relief. See Figure 5-65.




FIGURE 5-65

5. Tighten the body of the strain relief to the conduit connector. See Figure 5-66.




FIGURE 5-66

6. Push the wire rope into the flexible conduit. See Figure 5-67.




FIGURE 5-67

UL EX3470 ULC EX3470

PAGE 5-26 REV. 11 2014-SEP-01

INSTALLATION OF REMOTE MANUAL PULL STATION OR MECHANICAL GAS VALVE UTILIZING FLEXIBLE CONDUIT (Continued)

Connecting Flexible Conduit to Pulley Elbows, Pulley Tees, or Union Fittings (Continued)

 Slide the flexible conduit into the strain relief until it is approximately 1/16 in. (1.6 mm) from the bottom of the flexible conduit insert. See Figure 5-68.




FIGURE 5-68

8. Tighten the strain relief nut onto the strain relief. See Figure 5-69.




FIGURE 5-69

9. Complete the same procedures on the other end of the conduit fitting as described in Steps 1 through Step 8 above.

Assembling the Block

Note: For installations that do not require the tee block, refer to page 5-34 for instructions.

 The flexible conduit and wire rope should be connected to the electrical box as described in "Connecting the Flexible Conduit to the AUTOMAN Release, Electrical Box, or Mechanical Gas Valve." See Figure 5-70.

Note: For 1 1/2 in. (38 mm) deep electrical box, the bearing should be installed in the block's shallow box location.

For 2 1/8 in. (54 mm) deep electrical box, the bearing should be installed in the block's deep box location.




FIGURE 5-70

2. Thread the wire rope through the small end of the block into the bearing area to be used. See Figure 5-71.




FIGURE 5-71

3. Pull slack, make a loop and insert the rope through the larger opening in the bearing area. See Figure 5-72.




FIGURE 5-72

UL EX3470 ULC EX3470

2014-SEP-01 REV. 11 PAGE 5-27

INSTALLATION OF REMOTE MANUAL PULL STATION OR MECHANICAL GAS VALVE UTILIZING FLEXIBLE CONDUIT (Continued)

Assembling the Block (Continued)

Pull wire rope out of the large end of the block. See Figure 5-73.



FIGURE 5-73

5. Place the bearing against the wire rope. Make certain wire rope is in the bearing groove. See Figure 5-74.




FIGURE 5-74

OKL 3-

6. Align the bearing against the wire rope so that the bearing center and the hole in the block line up. See Figure 5-75.




FIGURE 5-75

7. Insert the supplied bolt into the bearing and tighten securely. Take care not to strip the thread. See Figure 5-76.




FIGURE 5-76

Connecting the Block and the Faceplate

1. The block can be inserted into the faceplate at 90° intervals. See Figure 5-77.




FIGURE 5-77

2. Thread the wire rope through the faceplate. Insert the block by depressing the tabs and pushing the block into the faceplate until it snaps in place. See Figure 5-78.




FIGURE 5-78

UL EX3470 ULC EX3470

PAGE 5-28 REV. 11 2014-SEP-01

INSTALLATION OF REMOTE MANUAL PULL STATION OR MECHANICAL GAS VALVE UTILIZING FLEXIBLE CONDUIT (Continued)

Connecting the Block and the Faceplate (Continued)

3. Place the faceplate over the top of the electrical box and insert the two screws to secure the faceplate. See Figure 5-79.



FIGURE 5-79

4. Thread the wire rope through the pull knob. See Figure 5-80.



FIGURE 5-80

0080

5. Thread the wire rope through stop sleeve and leave approximately 1/4-3/8 in. (6.4-9.5 mm) extended past sleeve. Crimp stop sleeve twice using Crimping tool, National Telephone Supply Co. Nicopress Sleeve Tool (Stock No. 51-C-887). Verify stop sleeve is secure on wire rope. See Figure 5-81.




FIGURE 5-81

6. Insert the break rod into the two holes toward the top of the

pull knob. See Figure 5-82.



FIGURE 5-82

7. Pull the excess slack back to the AUTOMAN release. This will pull the pull knob assembly in place. See Figure 5-83.



FIGURE 5-83

 Hold the pull knob assembly against the faceplate. Rotate the pull knob assembly counterclockwise until the break rod and pull knob snap in place. See Figure 5-84.

Note: Take care in snapping in the ends of the break rod into the pull station side shields while rotating the entire assembly.



FIGURE 5-84

2014-SEP-01 REV. 11 PAGE 5-29

INSTALLATION OF REMOTE MANUAL PULL STATION OR MECHANICAL GAS VALVE UTILIZING FLEXIBLE CONDUIT (Continued)

Connecting the Block and the Faceplate (Continued)

Snap the pull tab onto the pull knob so it is legible. See Figure 5-85.




FIGURE 5-85

- 10. Refer to R-102 or PIRANHA installation manual to complete system installation.
- 11. Test Remote Manual Pull Station and Mechanical Gas Valves in accordance with the "Testing and Placing in Service – Testing Manual Pull Station and Testing Mechanical Gas Valves" section of this manual.

Installing Flexible Conduit Through a Conduit Offset

1. Starting at the AUTOMAN release, connect the conduit connector using the supplied nut. Use only ANSUL conduit fittings (Part No. 55813). See Figure 5-86.




FIGURE 5-86

 2. Install Conduit Offset (Part No. 435961) into conduit connector and tighten nut. See Figure 5-87.




FIGURE 5-87

3. Install compression union to opposite end of conduit offset. Tighten securely. See Figure 5-88.



FIGURE 5-88

UL EX3470 ULC EX3470

PAGE 5-30 REV. 11 2014-SEP-01

INSTALLATION OF REMOTE MANUAL PULL STATION OR MECHANICAL GAS VALVE UTILIZING FLEXIBLE CONDUIT (Continued)

Installing Flexible Conduit Through a Conduit Offset (Continued)

 Install the conduit required to get above the ceiling. See Figure 5-89.



FIGURE 5-89

Install compression union to top of conduit riser. See Figure 5-90.



FIGURE 5-90

Remove union nut and ring. Discard ring. Do not reinstall nut at this time. See Figure 5-91.



FIGURE 5-91

7. Remove strain relief nut and install strain relief body into compression union. See Figure 5-92.



FIGURE 5-92

Install union nut over strain relief body and tighten nut. See Figure 5-93.



FIGURE 5-93

9. Install strain relief nut onto strain relief body. Do not tighten nut at this time. See Figure 5-94.




FIGURE 5-94

2014-SEP-01 **REV. 11** PAGE 5-31

INSTALLATION OF REMOTE MANUAL PULL STATION OR MECHANICAL GAS VALVE UTILIZING FLEXIBLE CONDUIT (Continued)

Installing Flexible Conduit Through a Conduit Offset (Continued)

10. Push flexible conduit completely through conduit offset. Flexible conduit should stop flush or +/- 1/2 in. (13 mm) from bottom conduit fitting in AUTOMAN release. See Figure 5-95.



FIGURE 5-95

11. Tighten nut on strain relief on top of conduit riser. See Figure 5-96.




FIGURE 5-96

12. Complete the remainder of the flexible conduit and wire rope installation to the pull station or the gas valve.

Flexible Conduit Splicing (Allowed on Pull Station Installations Only)

Note: Wire rope cannot be spliced together, only the flexible conduit.

Flexible conduit can be spliced together using EMT compression fitting union (Part No. 79827).

1. Remove rings from both ends of compression union. See Figure 5-97.




FIGURE 5-97

2. Install strain relief nut, strain relief, compression union nut, flexible conduit insert and compression union over the flexible conduit with wire rope installed. See Figure 5-98.



FIGURE 5-98

3. Tighten compression union nut onto union body, locking flexible conduit insert in place. See Figure 5-99.




FIGURE 5-99

UL EX3470 ULC EX3470

PAGE 5-32 REV. 11 2014-SEP-01

INSTALLATION OF REMOTE MANUAL PULL STATION OR MECHANICAL GAS VALVE UTILIZING FLEXIBLE CONDUIT (Continued)

Flexible Conduit Splicing (Allowed on Pull Station Installations Only) (Continued)

Install strain relief body into compression union and tighten.
 See Figure 5-100.



FIGURE 5-100

 Push flexible conduit into strain relief until it is approximately 1/16 in. (1.6 mm) from the bottom of the flexible conduit insert, then tighten strain relief nut onto strain relief body. See Figure 5-101.



FIGURE 5-101

0080

Starting on the opposite end of the compression union, remove the nut. See Figure 5-102.



FIGURE 5-102

 Install strain relief nut, strain relief, and compression union nut on remaining section of flexible conduit and install flexible conduit insert on wire rope. See Figure 5-103.




FIGURE 5-103

8. Push wire rope completely through remaining section of flexible conduit. See Figure 5-104.




FIGURE 5-104

9. Tighten compression union nut onto union body, securing flexible conduit insert in place. See Figure 5-105.



INSTALLATION OF REMOTE MANUAL PULL STATION OR MECHANICAL GAS VALVE UTILIZING FLEXIBLE CONDUIT (Continued)

Flexible Conduit Splicing (Allowed on Pull Station Installations Only) (Continued)

10. Tighten strain relief into compression union. See Figure 5-106.



FIGURE 5-106

11. Push flexible conduit into strain relief until it is approximately 1/16 in. (1.6 mm) from the bottom of the flexible conduit insert, then tighten strain relief nut onto strain relief body. See Figure 5-107.



FIGURE 5-107

12. Complete the remainder of the flexible conduit and wire rope installation to the pull station or the gas valve.

Component Removal Instructions

REMOVAL OF BLOCK

Using thumbs on the clips on each side of the block, press firmly in the direction of the center of the block, at the same time pressing in a slightly downward direction. As the clips on the side of the block release from the pull station cover, the block will release and be free to be removed from the backside of the cover. See Figure 5-108.



FIGURE 5-108

REMOVAL OF PULL KNOB

Insert a small screwdriver into slot at bottom of pull knob. Push slightly on the screwdriver and turn pull knob clockwise, then pull knob can be removed without breaking the glass rod. See Figure 5-109.




FIGURE 5-109

REMOVAL OF PULL CAP

Using a small screwdriver or other blunt object, push on the backside of the pull cap. This will free the cap from the pull knob. See Figure 5-110.



FIGURE 5-110

UL EX3470 ULC EX3470

PAGE 5-34 REV. 11 2014-SEP-01

INSTALLATION OF REMOTE MANUAL PULL STATION OR MECHANICAL GAS VALVE UTILIZING FLEXIBLE CONDUIT (Continued)

Pull Station Installation without Pulley Block Assembly

Note 1: When using this installation option, the distance from the back of the faceplate and the connection to the 1/2 in. EMT conduit compression fitting must not exceed 6 in. (152 mm).

Note 2: To provide for a straight run of wire rope from the pull station, an octagonal junction box with a center knockout in the back of the junction box will be needed. See Figure 5-111. If a pre-fabricated box or enclosure is to be used, it must allow the pull station face plate to be firmly attached to the box or enclosure, with a hole or knockout suitable for a 1/2 in. EMT threaded conduit compression connector to be installed directly in line with the center of the pull station pull knob.




FIGURE 5-111

- 1. Attach a 1/2 in. EMT conduit compression fitting (Part No. 55813) to the back center knock out of the junction box. If something other than a junction box is to be utilized, a method of securing the flexible conduit or EMT conduit directly in line with the center of the pull station pull knob must be used. This will ensure that in the event of manual operation the wire rope, exiting the back of the pull station faceplate, will be pulled straight out without binding or resulting in undue additional pull force due to friction loss.
- Remove the block assembly from the pull station face plate.
 Thread the wire rope from either flexible conduit or 1/2 in.
 EMT conduit attached to the back of the junction box or fabricated enclosure through the back side of the pull station faceplate and through the pull knob.
- 3. Thread the wire rope through the stop sleeve (Part No. 26317) and leave approximately 1/4 in. to 3/8 in. (6.4 mm to 9.5 mm) extending past the sleeve.
- Crimp the stop sleeve twice using the crimping tool National Telephone Supply Co. Nicopress Sleeve Toll (Stock No, 51-C-887). Verify the sleeve is secure on the wire rope.

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 5-35

INSTALLING ELECTRICAL GAS VALVES

NOTICE

Electric gas valves are designed for indoor installation only.

The following instructions and schematics illustrate methods of procedures for installing 110 VAC Electric Gas Shut-off Valves.

 Make certain that regulated release assembly enclosure cover is detached and lock pin is properly inserted within the regulated release mechanism.

NOTICE

Failure to follow these instructions may lead to system actuation.


- Verify that cartridge has been removed from regulated release assembly and that the regulated release mechanism is in the cocked position.
- If regulated release mechanism does not have lock pin inserted or cartridge removed, refer to the "Semi-Annual Maintenance," Page 8-1, in "Maintenance Examination" section, and complete Steps 2 and 3 before completing the following installation steps.

3. A WARNING

To reduce the risk of explosion due to leaking gas, make certain that the gas line is turned off before connecting the gas valve. Failure to comply may result in serious personal injury or death. Gas valve installation shall be performed by qualified individuals in accordance with local jurisdiction requirements.

Install each electric gas valve to its selected location in gas line so that it ensures safe shut-off to all predetermined appliances being protected upon actuation of the system. Refer to manufacturer's instructions (if provided). See Figure 5-112.

- a. Use new pipe properly reamed and clean of metal chips.
- Install valve so that the actuator is above the horizontal pipe line with no more than a five degree (5°) lean either way.
- Make certain gas flow is in the same direction as arrow shown on gas valve.
- d. If strainer is utilized, attach strainer ahead of gas valve.
- e. If necessary, install drip leg in gas line in accordance with authority having jurisdiction.
- 4. Install and secure 1/2 in. conduit from each electric gas valve to manual reset relay enclosure.
- 5. Tag and connect electrical wiring to each electric gas valve. Then, feed wire through conduit to manual reset relay. Tape or place a wire nut on any unused wire leads in accordance with authority hoving invindiction. Pefer to Figure 5.122
- with authority having jurisdiction. Refer to Figures 5-122 —
- ▶ 5-125 at the end of this section for typical wiring diagrams.






FIGURE 5-112

⚠ WARNING

6.

Before working on any electrical wiring, make certain main power has been disconnected. Failure to disconnect main power may cause serious personal injury or death if contact is made with energized wires

NOTICE

All electrical wiring/connections shall be performed by qualified individuals in accordance with local jurisdiction requirements.

Connect electrical wiring to manual reset relay along with any contactor, or contractor supplied devices needed. Refer to manufacturer's instructions and proper figure listed for assistance.

- 7. Tape or place a wire nut on any unused wire leads in accordance with authority having jurisdiction.
- Install and secure 1/2 in. conduit from the regulated release assembly enclosure to manual reset relay enclosure.
 If snap-action switches have not been attached, go to
 - "Electric Switch" section and install them at this time by completing Steps 3 through 8.
- Tag and connect electrical wiring to each electric (snap-action) switch. Then, feed wire through conduit to manual reset relay.
- Connect wiring from each electric (snap-action) switch to manual reset relay terminals. Refer to manufacturer's instructions (if provided) and proper figure for assistance.
- 11. Tape or place a wire nut on any unused wire leads in accordance with authority having jurisdiction.
- 12. Properly return electrical power to the system.

UL EX3470 ULC EX3470

PAGE 5-36 REV. 11 2014-SEP-01

INSTALLING ELECTRICAL SWITCHES

The procedure for field installing an electric (snap-action) switch is as follows:

⚠ CAUTION

Unused wire leads will become "hot" when the system is operated. Failure to adequately cover exposed wire end(s) will cause electric shock if touched.

⚠ CAUTION

Before working on any electrical wiring, make certain main power has been disconnected. Failure to disconnect main power could cause personal injury or death if contact is made with energized wires.

NOTICE

Except for the Alarm Initiating Switch, all electrical wiring connections are to be made outside the AUTOMAN release enclosure in suitable enclosures in accordance with local jurisdiction requirements.

 Make certain that regulated release assembly enclosure cover is detached with lock pin properly inserted within the regulated release mechanism.

NOTICE

Failure to follow these instructions may lead to system actuation.

- 2. Verify that cartridge has been removed from regulated release assembly and that the regulated release mechanism is in the cocked position. If regulated release mechanism does not have lock pin inserted or cartridge
- mechanism does not have lock pin inserted or cartridge removed, refer to "Semi-Annual Maintenance," Page 8-1, in "Maintenance Examination" section, and complete Steps 2 and 3 before completing the following installation steps.
- If regulated release mechanism has a factory installed solenoid, it will also have two factory installed switches.




FIGURE 5-113

Install one or two of the electrical (snap-action) switches into the switch cover for the upper tab of the switch mounting bracket. See Figure 5-114.

Note: When applicable, always place the low voltage alarm initiating switch(es) on the upper tab of the switch mounting bracket. Never place low voltage alarm initiating switch(es) on the lower tab of the switch mounting bracket.




FIGURE 5-114

4. Slide switch cover onto the upper tab of the switch mounting bracket, ensuring that the tab slides into the channels on the back side of the switch cover, until the screw holes line up. See Figure 5-115.




FIGURE 5-115

UL EX3470 ULC EX3470

2014-SEP-01 REV. 11 PAGE 5-37

► INSTALLING ELECTRICAL SWITCHES (Continued)

5. Install two switch mounting screws and nuts, ensuring that the screws pass through the holes in the cover, though the mounting holes in each of the switches, and through the holes in the mounting bracket tab. See Figure 5-116. Tighten screws securely.


Note: To meet UL requirements, the screws and nuts must be installed. The switch cover is not intended to secure the switches to the bracket.



FIGURE 5-116

Wire the upper switch(es) according to the switch wiring diagram provided with each release mechanism. See Figure 5-117.

SWITCH WIRING DIAGRAM SHOWN IN COCKED POSITION



NOTE:
EXCEPT FOR ALARM INITIATING SWITCH, NO WIRE CONNECTIONS ARE TO BE MADE INSIDE
THIS CONTROL HEAD/RELEASING DEVICE. SWITCHES MUST BE SECURED WITH SCREWS
TO MEET UL REQUIREMENTS.

21 A 125, 250 • 1 HP 125 VAC OR 2 HP 250 VAC

FIGURE 5-117

00914

7. If necessary, install one or two of the snap-action switches into the switch cover for the lower tab of the switch mounting bracket. These switches will be oriented opposite of the upper switch(es) so that the levers will appear on the top side of the switch when mounted to the lower tab of the switch mounting bracket.

Note: Never place low voltage alarm initiating switch(es) on the lower tab of the switch mounting bracket.

 Slide switch cover onto the lower tab of the switch mounting bracket, ensuring that the tab slides into the channels on the back side of the switch cover, until the screw holes line up. See Figure 5-118.




FIGURE 5-118

Install two switch mounting screws and nuts, ensuring that the screws pass through the holes in the cover, though the mounting holes in each of the switches, and through the holes in the mounting bracket tab. Tighten screws securely.

Note: To meet UL requirements, the screws and nuts must be installed. The switch cover is not intended to secure the switches to the bracket.

 Wire the lower switches according to the switch wiring diagram provided with each release mechanism. See Figure 5-117.

Note: All wiring to be performed by a certified individual(s).

- 11. Restore power to release assembly.
- Before proceeding with Step 13, test electric (snap-action) switches:
 - a. Remove lock pin. With the AUTOMAN release in the cocked or ready position, press the lever of each switch up. If the switch is working properly there should be an audible click. See Figure 5-119.



FIGURE 5-119

 With the AUTOMAN release in the fired position, press the lever of each switch up, there should be no audible click.

When installing multiple switches, make certain all switches transfer when the release operates. If they do not, readjust their position.

UL EX3470 ULC EX3470

PAGE 5-38 REV. 11 2014-SEP-01

INSTALLING ELECTRICAL SWITCHES (Continued)

- c. If an audible click is heard in the fired position adjust-
- ments can be made by removing the snap action switch and bending the lever slightly.
 - d. After adjustments repeat steps a and b. Then, recock AUTOMAN release and install lock pin.

NOTICE

All electrical wiring/connections shall be performed by qualified individuals in accordance with local jurisdiction requirements

▶13. The switch may now be connected to compatible components that are predetermined to shut off or turn on. Refer to component manufacturer's instructions for proper wiring connections to compatible components.

NOTICE

Except for the Alarm Initiating Switch, all electrical wiring connections are to be made outside the AUTOMAN release enclosure in suitable enclosures in accordance with local jurisdiction requirements.

▶14. Tape or place a wire nut on any unused wire leads in accordance with authority having jurisdiction.

NOTICE

Do not connect power source to any relay, contactor, or contractor supplied devices until all other electrical connections are made. Refer to proper section or manufacturer supplied instructions for recommended installation procedures for these devices.

▶15. Turn off power source and connect power line to any relay, contactor, or contractor supplied devices where used.

UL EX3470 ULC EX3470

2014-SEP-01 REV. 11 PAGE 5-39

INSTALLING ALARM INITIATING SWITCH

The Alarm Initiating Switch Kit (Part No. 428311) consists of:

- Alarm Initiating Switch Assembly Rated 50 mA 28VDC (or 0.1A, 125VAC)
 - · Switch Cover
- · Mounting Screw with Nut (4)
- · Self-Tapping Screws (2)
- · Trip Lever Pin
- · Hex Nut for Trip Lever Pin
- · Instruction Sheet

The Alarm Initiating Switch is installed in the AUTOMAN Release on the upper tab of the switch mounting bracket.

- 1. Install round trip lever pin with hex nut provided.
- Install the alarm initiating switch into the switch cover for the upper tab of the switch mounting bracket. To install the alarm initiating switch in the switch cover, slide the switch into the large opening of the switch cover, oriented with the switch lever on the bottom side of the switch. See Figure 5-120.




FIGURE 5-120 009137

NOTICE

The alarm initiating switch must always be installed on the upper tab of the switch mounting bracket.


Slide switch cover onto the upper tab of the switch mounting bracket, ensuring that the tab slides into the channels on the back side of the switch cover, until the screw holes line up. 4. Install two switch mounting screws and nuts, ensuring that the screws pass through the holes in the cover, though the mounting holes in each of the switches, and through the holes in the mounting bracket tab. Tighten screws securely.

Note: To meet UL requirements the screws and nuts must be installed. The switch cover is not intended to secure the switches to the bracket.


See NFPA 72, "National Fire Alarm Code," Initiating Devices section, for the correct method of wiring connection to the fire alarm panel.

NOTICE

All connections to fire alarm control panels must be made by trained and qualified personnel in accordance with fire alarm control panel manufacturer's recommendations.







CORRECT - SEPARATE INCOMING AND OUTGOING CONDUCTORS

FIGURE 5-121

Note: With the exception of the Alarm Initiating Switch, all electrical connections must be made in an approved electrical box which also meets NEC article 314.40 (D) Grounding Provisions.

SECTION 5 - INSTALLATION INSTRUCTIONS


UL EX3470 ULC EX3470

PAGE 5-40 REV. 11 2014-SEP-01

ELECTRICAL SWITCH REQUIREMENTS


Electric (110 VAC/60 Hz) Gas Shut-off Valve

INSTALLATION OVERVIEW



WIRING SCHEMATIC

WIRING SCHEMATIC - RELAY PART NO. 426151



NOTE:


- 1. _____ DENOTES FIELD INSTALLATION.
- 2. ____ DENOTES FACTORY INSTALLATION.
- 3. CONTRACTORS: "UL LISTED ENCLOSED INDUSTRIAL CONTROL EQUIPMENT OR MAGNETIC SWITCH HAVING A RATING MATCHING THAT OF THE COOKING APPLIANCE COIL, 110V/60HZ."
- 4. DO NOT USE BLACK WIRE ON SNAP-ACTION SWITCH IN NORMAL INSTALLATION. BLACK WIRE TO BE USED ONLY FOR EXTRANEOUS ALARM, LIGHT CIRCUITS, ETC.

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 5-41

ELECTRICAL SWITCH REQUIREMENTS (Continued)

Electric (110 VAC/60 Hz) Application with Customer Supplied Contactor and Heating Element Load

INSTALLATION OVERVIEW



WIRING SCHEMATIC

WIRING SCHEMATIC - RELAY PART NO. 426151 UPPER SWITCH LOWER SWITCH - BLACK **BROWN** RED BROWN BLACK ANSUL SNAP-ACTION SWITCH (SWITCH CONTACTS SHOWN WITH AUTOMAN RELEASE IN THE COCKED POSITION) TO TO RESET POWER INDICATOR $^{\circ}$ GND ! ェ RFD CREW 5 **RELAY COIL** L2 NEUTRAL 110 VAC/60HZ L1 HOT CONTACTOR (CUSTOMER SUPPLIED) POWER ON-OFF SWITCH (CUSTOMER SUPPLIED) MANUAL RESET RELAY (PART NO. 426151) **ELECTRIC RATING** TO POWER SUPPLY TO HEATING 1/3 HP, 10 Amp, 120 VAC 1/2 HP, 10 Amp, 240 VAC 220V/440V **ELEMENT LOAD** 13 Amp, 28 VDC NOTE:

1. _____ DENOTES FIELD INSTALLATION.

^{2.} ____ DENOTES FACTORY INSTALLATION.

^{3.} GAS VALVES: "UL LISTED ELECTRICALLY-OPERATED SAFETY VALVE FOR NATURAL, OR LP GAS AS NEEDED OF APPROPRIATE PRESSURE AND TEMPERATURE RATING, 110V/60 HZ" OR ANSUL GAS VALVES, PART NUMBERS 13707, 13708, 13709, 13710, AND 17643.

^{4.} DO NOT USE BLACK WIRE ON SNAP-ACTION SWITCH IN NORMAL INSTALLATION. BLACK WIRE TO BE USED ONLY FOR EXTRANEOUS ALARM, LIGHT CIRCUITS, ETC.

SECTION 5 - INSTALLATION INSTRUCTIONS


UL EX3470 ULC EX3470

PAGE 5-42 REV. 11 2014-SEP-01


ELECTRICAL SWITCH REQUIREMENTS (Continued)

Electric (110 VAC/60 Hz) Application with Customer Supplied Contactor and Heating Element Load, and Power Supply Switch

INSTALLATION OVERVIEW



WIRING SCHEMATIC



NOTE:

- 1. _____ DENOTES FIELD INSTALLATION.
- 2. ____ DENOTES FACTORY INSTALLATION.
- 3. CONTRACTORS: "UL LISTED ENCLOSED INDUSTRIAL CONTROL EQUIPMENT OR MAGNETIC SWITCH HAVING A RATING MATCHING THAT OF THE COOKING APPLIANCE COIL, 110V/60HZ."
- DO NOT USE BLACK WIRE ON SNAP-ACTION SWITCH IN NORMAL INSTALLATION. BLACK WIRE TO BE USED ONLY FOR EXTRANEOUS ALARM, LIGHT CIRCUITS, ETC.

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 5-43

WIRING 24VDC REGULATED RELEASE ASSEMBLY

CAUTION

Do not install cartridge or remove tank assembly unless release is cocked and ring pin is in place. Failure to comply may result in accidental system actuation.

If the following occurs during installation, the solenoid for the releasing assembly may be damaged, rendering the system inoperable.

- If the release is electrically tripped (fired) with the ring pin inserted such that the release mechanism is pinned in the cocked position.
- The lever arm of the mounted switch is bent such that the switch does not operate when the release roll pin is bottomed out in the fired position.
- 3. Trying to recock the release mechanism while power is applied to the release through the alarm contacts.

For complete recharging, inspection, and maintenance instructions, refer to applicable fire suppression system manual.


⚠ WARNING

Take extreme care when wiring release assembly. Failure to comply may cause an electrical shock, resulting in possible serious injury or death.

Refer to the following notes and wiring diagram for instruction on wiring the 24VDC regulated release assembly.

Notes:

- 1. To be connected to a nominal 24VDC releasing circuit.
 Input power: 750 mA at 24VDC nominal (1.02 at 30VDC maximum).
- 2. Polarization: Observe polarity when connected to a release circuit; Terminal 4 positive, Terminal 8 negative.
- 3. All interconnecting wiring number 14 18 AWG.
- S₁ and S₂ contact ratings: 20A, 125/250 VAC 2 HP, 250 VAC 1 HP, 125 VAC.
- 5. SOL₁ coil resistance: 28 OHMS +/- 10% at 77 °F (25 °C).
- Install the in-line supervisory device SD_x across terminals No. 4 and No. 5. Refer to the releasing panel installation instructions for supervisory device requirements. If an in-line supervisory device is not required, install jumper J₂ across terminals No. 4 and No. 5.
- ▶ 7. S₃ contact ratings: 24VDC, 240mA maximum.



- * AUXILIARY ALARMING DEVICES, SEE S_{1} RATINGS
- ** FUEL SHUT-OFF VALVE, BLOWER MOTOR, DOOR CLOSER, ETC., SEE S_1 RATINGS.

FIGURE 5-125

SECTION 5 – INSTALLATION INSTRUCTIONS

UL EX3470 ULC EX3470

PAGE 5-44 REV. 11 2014-SEP-01

NOTES:

ANSUL certificate in an R-102 training program.

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 6-1

After the system has been completely installed, and **BEFORE INSTALLING THE CARTRIDGE**, the system must be tested at the regulated release assembly. The testing information listed in this section deals with the limitations and parameters of this pre-engineered system. Those individuals responsible for the testing of the R-102 system must be trained and hold a current

Note: AUTOMAN Release must be in the cocked position before testing manual pull station. Make certain to remove lock pin before performing pull station testing.

TESTING MANUAL PULL STATION

To test each remote manual pull station, complete the following steps:

- With the expellant gas cartridge removed, remove lock pin from regulated release assembly cable lever.
 - On pull station, remove break rod from the pull station by inserting a small screwdriver into slot at bottom of pull knob to facilitate turning the pull knob. Push slightly on the screwdriver and turn pull knob clockwise, then the pull knob can be removed without breaking the glass rod.

NOTICE

Take care in removing the break rod from the pull station side shields while rotating the break rod/pull knob assembly.

- 3. Pull ring handle on pull station. If the regulated release assembly is tripped easily, the remote manual pull station is properly installed. If the regulated release assembly does not trip, remove pulley tee (if provided) and each pulley elbow cover to make certain wire rope is resting on the pulley sheave. If this does not correct the problem, there is too much slack in the line and it must be retightened.
- Recock regulated release assembly using cocking lever (Part No. 441042 or 441041) and reinstall lock pin (Part No.
- 438031).
 - On pull station, insert the break rod into the two holes toward the top of the pull knob. Rotate the pull knob counterclockwise.

NOTICE

Take care in snapping in the ends of the break rod into the pull station side shields while rotating the entire assembly.

NOTICE

If no other devices are being attached, proceed to Page 6-3, Step No. 1, and test the detection system.

TESTING MECHANICAL GAS VALVES

To test each mechanical gas shut-off valve complete the following steps:

1. A WARNING

To reduce the risk of explosion due to leaking gas, before the gas line is turned on, make certain to extinguish any open flames and turn off all burners and any electrical or mechanical devices that are capable of igniting gas.

- Failure to comply may result in serious personal injury or
 death.
 - Turn gas line on.

2. Manually push each air cylinder rod to full "DOWN" position. The gas valve should close. If mechanical gas valve does not trip, remove each pulley elbow cover to make certain wire rope is resting on each pulley elbow sheave. If this does not correct the problem there may be too much slack in the line and it should be retightened.

- Test for gas leaks by painting connections with a soap solution. Bubbles indicate a gas leak. Tighten connections where leaks appear and repeat test again to make certain no other gas leaks exist.
- If no gas leak is found, pull air cylinder rod to full "UP" position.
- 5. Recock mechanical gas valve.
- Check burners for gaseous odor. IF GASEOUS ODOR EXISTS, MANUALLY PUSH THE AIR CYLINDER ROD TO THE FULL "DOWN" POSITION IMMEDIATELY. This will cause the mechanical gas valve to shut the gas line off.

Open any doors and/or windows to clear the area of gaseous fumes, then correct the gas leak before proceeding any further.

- If no gaseous odor exists, pilot light may be ignited at this time.
- Reinstall side covers to gas valve housing. Make certain roll pin is positioned within both sides of the valve housing slot. Connect visual inspection seals (Part No. 197) on ANSUL type valves. See Figure 6-1 (next page).
- 9. Make certain the regulated release mechanism is cockedwith lock pin in place.

NOTICE

If no other devices are being attached, proceed to Page 6-3, Step No. 1, and test the detection system.

SECTION 6 - TESTING AND PLACING IN SERVICE

UL EX3470 ULC EX3470

PAGE 6-2 REV. 11 2014-SEP-01

TESTING MECHANICAL GAS VALVES (Continued)




FIGURE 6-1

000359

TESTING ELECTRICAL GAS VALVES

To test each Electric Gas Shut-off Valve complete the following steps:

To reduce the risk of explosion due to leaking gas, before the gas line is turned on, make certain to extinguish any open flames and turn off all burners and any electrical or mechanical devices that are capable of igniting gas. Failure to comply may result in serious personal injury or

 Failure to comply may result in serious personal injury of death.

Turn gas line on.

- 2. Make certain electric (snap-action) switch is properly wired.
- Make certain all other devices connected to the manual reset relay are properly wired. Refer to typical wiring diagrams in Figures 5-122, 5-123, 5-124, and 5-125 in "Installation Instructions" section.
- Test for gas leaks by painting connections with a soap solution. Bubbles indicate a gas leak. Tighten connections where leaks appear. Repeat test again to make certain no other gas leaks exist.
- If no gas leaks are found, turn power source on and depress the reset button on the manual reset relay (RED LIGHT ON) to energize (OPEN) electric gas valve.
- ▶ 6. Remove lock pin from regulated release mechanism.

CAUTION

Do not install cartridge at this time or system may be actuated.

 Manually actuate the system by operating the remote pull station. (It may be necessary to remove the glass break rod prior to operating pull station.) Manual reset relay (RED LIGHT OUT) will de-energize (CLOSE) the electric gas valve, thus shutting off the gas line. If this does not happen, turn power source off. Then re-examine all wiring connections for proper hookup. Refer to Figures 5-122, 5-123, 5-124, and 5-125 in "Installation Instructions" section for typical wiring diagrams.

- If test is successful, recock regulated release mechanism using cocking lever (Part No. 441042 or 441041) and rein-
- stall lock pin (Part No. 438301). Depress reset button on manual reset relay (RED LIGHT ON).
 - Check burners for gaseous odor. IF GASEOUS ODOR EXISTS, TURN OFF POWER SOURCE IMMEDIATELY. This will cause the electric gas valve to shut the gas line off.

Open any doors and/or windows to clear the area of gaseous fumes, then correct the gas leak before proceeding any further.

If no gaseous odor exists, pilot light may be ignited at this time.

NOTICE

If no other devices are being attached, proceed to Page 6-3, Step No. 1, and test the detection system.

TESTING ELECTRIC SWITCH

The procedure for testing a field installed electric (snap-action) switch is as follows:

NOTICE

If an electrical gas shut-off valve is attached to system, perform proper test procedure for the gas valve first, before completing the following steps.

- Turn power source on and if installed, depress reset button on manual reset relay (RED LIGHT ON). All electrical devices should be operating at this time.
- ▶ 2. Remove lock pin.

CAUTION

Do not install cartridge at this time or system may be actuated.

3. Manually actuate the system by operating the remote pull station. It may be necessary to remove the glass break rod prior to operating pull station. (If installed, the manual reset relay will de-energize the electric gas valve, thus shutting off the gas line.) All electrically-operated devices predetermined to shut off or turn on should do so. If this does not occur, turn power source off and make sure all wiring is properly connected and retest. Refer to Figures 5-122, 5-123, 5-124, and 5-125 in "Installation Instructions" section for typical wiring diagrams.

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 6-3

TESTING ELECTRIC SWITCH (Continued)

- If test is successful, recock regulated release mechanism using cocking lever (Part No. 441042 or 441041) and rein-
- stall lock pin (Part No. 438031). If a manual reset relay is installed, depress the reset button (RED LIGHT ON). It will also be necessary to re-light any pilot lights on the cooking appliances.

NOTICE

If no other devices are being attached, proceed to Page 6-3, Step No. 1, and test the detection system.

TESTING DETECTION SYSTEM

- 1. Test detection system by completing the following steps:
 - Raise the regulated release mechanism tension lever to the "UP" position.
- Remove the fusible link from the terminal detector and install a test link (Part No. 24916). See Figure 6-2.




FIGURE 6-2

c. Locate detector linkage and center in each bracket.

For "clip on" style linkage, locate linkage in bracket slightly toward termination end of detection run.

For "scissor" style linkage, locate linkage in bracket all the way toward termination end of detection run.

- d. Lower regulated release mechanism tension lever to "DOWN" position and remove lock pin.
- e. Using a wire cutter, cut the test link at the terminal detector to simulate automatic actuation.
- f. If system actuates successfully, go to Step 4.
- If the regulated release mechanism does not actuate, check the following components and remedy any disorder as follows:
 - a. Check the detector linkage for correct positioning.
 - b. Check the wire rope for knotting or jamming.
 - c. Check pulley elbows to see that wire rope is free and centered in pulley sheaves. If any evidence of pulley elbow deformation is found, replace the pulley elbow.
- d. Make certain that lock pin is removed.
 - e. Make certain that regulated release mechanism is cocked.
 - f. Make certain that tension lever is in "DOWN" position.

- 3. Re-test the system by completing the following steps:
- a. Make certain regulated release is cocked and lock pin is inserted.
 - Raise the regulated release mechanism tension lever to the "UP" position.
- c. Install a new test link (Part No. 24916) on the terminal detector.
 - d. Lower the regulated release mechanism tension lever to the "DOWN" position.
 - e. Check for 1/4 in. (6.4 mm) minimum 3/8 in. (9.5 mm) maximum clearance between the trip hammer assembly and the cable lever assembly.
- f. Remove the lock pin.
 - g. Using a wire cutter, cut the test link at the terminal detector to simulate automatic actuation.
 - 4. Upon successful actuation of the system, complete the following steps:
 - Raise tension lever to "UP" position and install a properly-rated fusible link in the terminal detector.
 - b. Cock regulated release mechanism using cocking lever (Part No. 441042 or 441041) and insert lock pin (Part No. 438031).
 - c. Lower tension lever to "DOWN" position.
 - d. For scissor-style linkage, locate linkage in bracket all the way toward termination end of detection run.
 - e. Make certain the 1/4 in. (6.4 mm) minimum to 3/8 in. (9.5 mm) maximum clearance was maintained between the base of the trip hammer assembly and the cable lever assembly.

NOTICE

Reset any electrical equipment that may have been affected by the system actuation.

- Remove shipping cap and weigh each cartridge. Replace if weight is 1/2 ounce (14.2 g), or more, below weight stamped on cartridge.
- g. Install cartridge into the regulated release mechanism receiver and each regulated actuator receiver. Hand tighten firmly.
- h. Remove the lock pin.

SECTION 6 - TESTING AND PLACING IN SERVICE

UL EX3470 ULC EX3470

PAGE 6-4 REV. 11 2014-SEP-01

TESTING DETECTION SYSTEM (Continued)

i. Install cover on regulated release assembly and each regulated actuator assembly and secure with appropriate fasteners or visual inspection seal. Insert seal (Part No. 197) in each upper and lower cover hole, if applicable. If system is installed in an OEM enclosure, attach enclosure cover and secure with appropriate hardware or procedure.

CAUTION

Before installing cover, make certain detection tension lever is secured in the "DOWN" position to enable automatic detection and operation of the AUTOMAN Regulated Release.

j. Record installation date on tag attached to unit and/or in a permanent file.

UL EX3470 **ULC EX3470**

2014-SEP-01 **REV. 11** PAGE 7-1

The recharge information listed in this section deals with the limitations and parameters of this pre-engineered system. Those individuals responsible for the recharge of the R-102 system must be trained and hold a current ANSUL certificate in an R-102 training program.

For continued fire protection, the R-102 restaurant fire suppression system must be recharged immediately after use. Recharge procedures for single, double, and multiple-tank systems are as follows.

CLEANUP PROCEDURES

Although there is no unusual cleanup procedure of ANSULEX or ANSULEX Low pH agents, due to the alkaline nature of these agents, they should be cleaned from kitchen surfaces within 24 hours after system discharge. The reaction from the wet chemical agent on cooking grease or oil produces a foamy bi-product that can be wiped up with a cloth or sponge. The following procedures should be followed:

⚠ CAUTION

Before attempting any cleanup, make certain that all fuel sources to the equipment to be cleaned have been shut off. Make certain that the exhaust hood and all appliance electrical controls have been de-energized to avoid any chance of electrical shock resulting from the cleaning process or from electrically conductive alkaline liquid agent and/or its residue.

Make certain all surfaces to be cleaned have cooled down to room temperature.

Do not use water to clean any appliances that contain hot grease or cooking oils. Doing so may result in violent steaming and/or spattering causing personal injury.

- 1. The agent is non-toxic; however, food product and cooking grease/oil that has come in contact with the agent will no longer be suitable for human consumption and should be discarded.
- 2. Sponge up as much of the agent as possible using sponges or clean rags. Dispose of these sponges or rags in a local sanitary land fill site in accordance to local authorities.

Wear rubber gloves during cleanup as sensitive skin may become irritated. If the ANSULEX agent or its residue comes in contact with skin or eyes, flush thoroughly with clean water.

- 3. Using hot, soapy water and either a clean cloth or sponge, wipe away all foamy residue and thoroughly scrub all surfaces that have come in contact with the agent.
- 4. After thoroughly cleaning all affected surfaces, adequately rinse and allow to completely dry before re-energizing the equipment.

RECHARGE

NOTICE

Determine the cause of system discharge and correct immediately before performing system recharge.

- 1. Remove the enclosure cover from the AUTOMAN regulated release assembly and each regulated actuator assembly.
- 2. From tank in regulated release enclosure: Disconnect the expellant gas hose from each tank adaptor assembly.
 - From tank in mounting bracket or mounting enclosure: Disconnect expellant gas piping union at each tank adaptor inlet line(s).
- 3. Disconnect distribution piping union at each tank adaptor outlet line(s).
- 4. From tank in enclosure: Remove tank.
 - From tank in bracket assembly: Loosen wingnut, disengage bracket band, and remove each tank.
- 5. Remove each tank adaptor/tube assembly and complete the following:
 - a. Remove o-ring and inspect for damage.
 - b. Clean and coat o-ring with a good grade of extreme temperature grease and reinstall into adaptor groove. See Figure 7-1.
 - c. Remove 1/4 in. vent plug.
- d. Clean and inspect for free movement and corrosion. If necessary, replace Vent Plug (Part No. 74247).
 - e. Reinstall vent plug into adaptor body.



FIGURE 7-1

SECTION 7 – RECHARGE AND RESETTING PROCEDURES

UL EX3470 ULC EX3470

PAGE 7-2 REV. 11 2014-SEP-01

RECHARGE (Continued)

6

CAUTION

Do not flush pipe with only water or other non-approved material, as this could cause internal corrosion, leading to possible improper discharge.

Piping system must be flushed to remove any wet chemical residue. To prepare the system for flushing:

- a. Pour the complete contents of one 32-oz. bottle of ANSUL Flushing Concentrate (Part No. 79656) into an empty R-102 agent tank. One complete bottle is used for either size tank, the 1.5 gallon or the 3 gallon.
- b. Fill the tank approximately half full with warm, clean water. Agitate the tank for a few seconds and then add more warm water to bring the fill level to within approximately 1 in. (25 mm) from the bottom of the fill opening.
- c. Install adaptor/tube assembly and tighten.
- To perform the flushing procedure, either secure heavy-duty plastic bags to each nozzle (See Figure 7-2) or remove each nozzle tip and strainer and attach plastic tubing. See Figure 7-3.

If using plastic bags, secure bags and proceed to Step 9. If using plastic tubing, proceed to Step 8.




FIGURE 7-2




FIGURE 7-3

If using the plastic tubing option, utilize 1/2 in. (13 mm) OD plastic tubing with wall thickness not to exceed 0.062 in. (1.5 mm), and make certain it can withstand the pressures of at least 90 psi (6.2 bar) expelled during the flushing and blowdown procedures.


Also required is a container with some means of securing tubing to it such as a five-gallon plastic pail and cover that snaps onto the pail.

To prepare the plastic tubing:

- a. Cut as many tubing lengths as required, making them long enough to reach the container from each nozzle outlet.
- b. Using the nozzle tip end, slide a length of 1/2 in. (13 mm) plastic tubing over the rib on the nozzle tip and secure with a 1/2 in. (13 mm) adjustable hose clamp. See Figure
 7-4.
 - c. In the pail cover, drill the number of holes required, large enough to insert 1/2 in. NPT fittings, with one additional hole that can be used for venting.
 - d. Secure 1/2 in. compression fitting/threaded adaptors to the pail cover, using 1/2 in. conduit nuts. See Figure 7-4.


UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 7-3

RECHARGE (Continued)




- e. Attach the tubing ends to the compression fittings. Tubing inserts will be required. See Figure 7-4.
- Install nozzle/tubing ends to nozzle bodies in discharge piping.
- g. Make certain each length of tubing is fastened to the pail cover with the cover snapped securely to the pail.
- 9. Complete the following steps in the flushing procedure:
 - a. Connect discharge piping and expellant gas line to agent tank adaptor.
- b. Cock AUTOMAN Release Mechanism and insert lock pin. Refer to Components Section of this manual for detailed part numbers.
 - c. Install LT-30-R Cartridge; hand tighten.
- d. Remove lock pin.
 - e. If regulated actuators are included in the system, also install LT-30-R cartridges in them.
 - f. Actuate system via pull station.
 - g. Wash out all system nozzles and strainers in warm soapy water, rinse and return all nozzles and strainers to their appropriate locations in the discharge piping.
- h. Verify that all nozzle types are correct. Utilizing the nozzle aiming device, ensure that all nozzles are correctly aimed at the appropriate location on the appliance.
 - i. Apply a small amount of Dow Corning No. 111 silicone grease across the opening of the nozzle tip. Install blowoff caps onto nozzles.
 - j. Remove empty tank.

- 10. Fill each tank with 1.5 gal (5.8 L) or 3.0 gal (11.6 L) of ANSULEX Low pH Liquid Fire Suppressant. See Figure
- 7-5. Note: Use a funnel with a screen to stop any foreign material from entering the tank. See Page 5-3, Figure 5-6,
- for additional detailed filling instructions.



RED PAINTED STEEL TANK



CAUTION

During filling, the agent temperature should be 60 °F to 80 °F (16 °C to 27 °C). **DO NOT FILL WITH COLD AGENT. DO NOT OVERFILL.** Overfilling may result in agent entering gas hose and regulator potentially causing system malfunction. See Page 5-3.

- 11. Replace bursting disc (Part No. 416974) in adaptor assembly. Make certain silver side of disc is away from tank.
- 12. Replace adaptor/tube assembly and tighten into place. Return and secure each tank in regulated release assembly and mounting bracket/enclosure. Reconnect expellant gas and distribution piping and/or as required.
- 13. Raise tension lever to "UP" position.
- 14. Cock regulated release mechanism using cocking lever (Part No. 441042 or 441041) and install lock pin (Part No.
- 438031).

SECTION 7 – RECHARGE AND RESETTING PROCEDURES

UL EX3470 ULC EX3470

PAGE 7-4 REV. 11 2014-SEP-01

RECHARGE (Continued)

 Remove empty cartridge from regulated release assembly and each regulated actuator assembly as required.

CAUTION

Do not install replacement cartridge at this time or system may be actuated.

Install properly-rated fusible links in all detectors except the terminal detector.

NOTICE

If actuation was caused by a fire situation, all fusible links must be replaced.

- ▶ 17. Install test link (Part No. 24916) in terminal detector.
 - 18. Lower tension lever to "DOWN" position.
- ▶ 19. Remove the lock pin.
 - 20. Using wire cutter, cut the test link at the terminal detector to simulate automatic actuation.

NOTICE

If regulated release mechanism does not actuate, refer to Steps 2 and 3 of the "Testing Detection System" portion of the "Testing and Placing In Service" section, Page 6-3, of this manual.

- After successful actuation, raise the tension lever to "UP" position
- 22. Install properly-rated, ANSUL approved, fusible link in terminal detector.
- ▶ 23. Cock the regulated release mechanism and install lock pin
 ▶ (Part No. 438031).
 - Locate detector linkage and correctly position in each bracket.
- 25. Lower tension lever to "DOWN" position.
- 26. Inspect the base of the wire rope clamping device to make certain there is a minimum of 1/4 in. (6.4 mm) to a maximum of 3/8 in. (9.5 mm) clearance between the base of the trip hammer assembly and the cable lever assembly.

NOTICE

If clearance is not 1/4 in. (6.4 mm) minimum to a maximum of 3/8 in. (9.5 mm), raise tension lever to "UP" position, raise trip hammer 3/8-1/2 in. (9.6-12.7 mm), tighten set screws, and repeat Steps 25 and 26.

- ▶ 27. Remove lock pin.
- 28. Manually test the regulated release mechanism by operating the remote manual pull station.
- 29. Recock the regulated release mechanism and insert the lock pin.
- 30. Reset all devices which were affected by the system actuation. Refer to the following "Resetting" section.

RESETTING

Resetting Remote Manual Pull Station

Metal Stamped Style (Part No. 4835 and 54011)

Reset each remote manual pull station by completing the following steps:

- If necessary, remove set screw that is retaining the break glass rod.
- If necessary, carefully remove any remaining broken glass from station.
- Press and position ring handle in proper location against cover and slide the replacement glass break rod (Part No. 4834) through stud and handle.
- 4. Tighten set screw into stud.
- 5. If no other resetting is required, refer to "Replacement Cartridge," Page 7-5, and complete steps 1 through 5.

Molded Composite Style with Side Shields (Part No. 434618 and 435960)

- If necessary, carefully remove any remaining broken glass from station.
- Insert the break rod into the two holes toward the top of the pull knob.
- 3. Pull the excess slack back into the AUTOMAN Release. This will pull the pull knob assembly in place.

NOTICE

Take care in snapping in the ends of the break rod into the pull station side shields while rotating the entire assembly.

- 4. Hold the pull knob assembly against the faceplate. Rotate the pull knob assembly counterclockwise until the break rod and pull knob snap in place.
- 5. Snap the PULL tab onto the pull knob so it is legible.
- 6. If no other resetting is required, refer to "Replacement Cartridge," Page 7-5, and complete steps 1 through 5.

SECTION 7 - RECHARGE AND RESETTING PROCEDURES

UL EX3470 ULC EX3470 PAGE 7-5

2014-SEP-01 **REV. 11**

RESETTING (Continued)

Resetting Mechanical Gas Shut-Off Valve

Reset each mechanical gas shut-off valve by completing the following steps:

WARNING

To reduce the risk of explosion due to leaking gas, before the gas line is turned on, make certain to extinguish any open flames and turn off all burners and any electrical or mechanical

- devices that are capable of igniting gas. Failure to comply may
- result in serious personal injury or death.
 - 1. Remove side cover from gas valve housing.
 - 2. Extend air cylinder rod to full "UP" position. Air cylinder is located inside the regulated release assembly enclosure.
 - 3. Recock gas valve by pulling valve stem up so pin in stem engages in cocking lever.
 - 4. Check burners for gaseous odor. IF GASEOUS ODOR EXISTS, MANUALLY PUSH THE AIR CYLINDER ROD TO THE FULL "DOWN" POSITION IMMEDIATELY. This will cause the mechanical gas valve to shut the gas line off.
 - Open any doors and/or windows to clear the area of gaseous fumes, then correct the gas leak before proceeding any further.
 - 5. If no gaseous odor exists, pilot light may be ignited at this time.
 - 6. Reinstall side cover to gas valve housing. On ANSUL type valve, make certain roll pin is positioned within both sides of the valve housing slot and secure visual inspection seal (Part No. 197).
 - 7. If no other resetting is required, refer to "Cartridge Replacement" and complete steps 1 through 5.

Resetting Electrical (Snap-Action) Switch

Reset the electrical (snap-action) switch by completing the following steps:

- 1. Make certain the power source is on.
- 2. Electric (snap-action) switch is reset automatically when the regulated release mechanism is recocked.
- 3. If no other resetting is required, refer to "Cartridge Replacement" and complete steps 1 through 5.

Resetting Electrical Gas Shut-Off Valve

Reset each electric gas shut-off valve by completing the following steps:

WARNING

To reduce the risk of explosion due to leaking gas, before the gas line is turned on, make certain to extinguish any open flames and turn off all burners and any electrical or mechanical

- ▶ devices that are capable of igniting gas. Failure to comply may
- ▶ result in serious personal injury or death.
 - 1. Make certain the power source is on.
 - 2. Depress reset button on manual reset relay (red light on). Gas valve will resume its normal operating (open) position.
 - 3. Check burners for gaseous odor. IF GASEOUS ODOR EXISTS, TURN OFF POWER SOURCE IMMEDIATELY. This will cause the electric gas valve to shut the gas line off.

Open any doors and/or windows to clear the area of gaseous fumes, then correct the gas leak before proceeding any further.

- 4. If no gaseous odor exists, pilot light may be ignited at this time.
- 5. If no other resetting is required, refer to "Replacement Cartridge" and complete steps 1 through 5.

SECTION 7 – RECHARGE AND RESETTING PROCEDURES

UL EX3470 ULC EX3470

PAGE 7-6 REV. 11 2014-SEP-01

RESETTING (Continued)

Resetting Pressure Switch

Reset the pressure switch by completing the following:

- Depress the reset button(s) on the pressure switch cover.
 The pressure switch assembly(ies) is located on the right side of the regulated release enclosure. An audible click will be heard to verify the pressure switch has resumed its normal (non-actuated) condition.
- 2. If no other resetting is required, refer to "Replacement Cartridge" and complete steps 1 through 5.

REPLACEMENT CARTRIDGE

To complete the recharge and resetting procedures:

- 1. Remove shipping cap and weigh replacement cartridge. Replace if weight is 1/2 ounce (14.2 g), or more, below weight stamped on cartridge.
- 2. Make certain regulated release mechanism is cocked and lock pin is installed. Then, install replacement cartridge into the regulated release assembly and each regulated actuator receiver and hand tighten.
- ▶ 3. Remove lock pin.
 - Snap cover on regulated release and each regulated actuator assembly, insert visual seal (Part No. 197) in upper and lower cover hole and secure.

CAUTION

Before installing cover, make certain detection tension lever is secured in the "DOWN" position to enable automatic detection and operation of the AUTOMAN Regulated Release.

Record recharge date on tag attached to unit and/or in a permanent file.

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 8-1

The maintenance information listed in this section deals with the limitations and parameters of this pre-engineered system. Those individuals responsible for the maintenance of the R-102 system must be trained and hold a current ANSUL certificate in an R-102 training program.

Maintenance is required semi-annually. At the 12 year interval, along with the normal maintenance exam, the tank(s) must be hydro-tested and the regulator(s) must be flow tested.

Prior to performing the required maintenance steps, verify that the R-102 system protection is designed and installed correctly for the existing appliance and ventilation system configuration. If not, make corrections as required.

SEMI-ANNUAL MAINTENANCE EXAMINATION

Semi-annual maintenance procedures for single, double, and multiple-tank systems are as follows.

NOTICE

Under certain circumstances hood and duct cleaning operations may render the fire suppression system ineffective due to a coating of cleaning chemical left on the detection equipment or mishandling of the system by cleaning service personnel. Therefore, it is strongly recommended that the R-102 system be completely inspected and serviced by an authorized ANSUL distributor immediately following any such cleaning operations.

- Remove the enclosure cover from the AUTOMAN regulated release assembly and each regulated actuator assembly.
- 2. Insert the lock bar (Part No. 14985) or lock pin (Part No. 438031) on the cocked regulated release mechanism. See
 Figure 8-1 or Figure 8-2.




FIGURE 8-1




FIGURE 8-2

- Remove cartridge from regulated release assembly and each regulated actuator assembly, install safety shipping cap, and set aside in a safe location.
- 4. Check to make certain the actuation line used to connect the regulated actuator assembly(s) to the AUTOMAN regulated release assembly is connected to the high pressure side (right side) of the cartridge receiver in the AUTOMAN and that it is intact, with all fittings securely tightened. This includes any 1/8 in. copper tubing and fittings used to connect to the air cylinder for the ANSUL mechanical gas valve.

CAUTION

If the actuation line leaks pressure, the regulated actuator assembly(s) may not operate. A severe leak can render the entire system inoperable.

- 5. To check for leaks in the actuation line, a hand held or electric vacuum pump may be used:
 - Disconnect the actuation line from the AUTOMAN regulated release cartridge receiver and connect the pump to the line.
 - The pump should pull a vacuum to 20 inches of mercury, as shown on the gauge. Leaks should not exceed 5 inches of mercury loss within a 30 second time frame.
 - If the gauge indicates a leak in the line, examine for loose connections or damage. Repair or replace as needed.
 - d. If leakage is not due to piping, disassemble the pneumatic actuator assembly(s) in the regulated actuator(s) and inspect the actuator and the o-ring in the actuator. Repair or replace as needed.

Note: Vacuum pumps can be obtained from automotive parts/supply stores.

SECTION 8 – MAINTENANCE EXAMINATION

UL EX3470 ULC EX3470

PAGE 8-2 REV. 11 2014-SEP-01

SEMI-ANNUAL MAINTENANCE EXAMINATION (Continued)

Alternate Test Method:

The actuation line can also be pressurized with either CO_2 or N_2 from a cartridge or with dry air, CO_2 , or N_2 from a larger cylinder.

- a. Cock the AUTOMAN regulated release assembly and carefully insert lock bar (Part No. 14985) or lock pin (Part No. 438031). See Figure 8-9 or Figure 8-10.
- b. Make certain expellant gas line hose and/or pipe from the regulator in the AUTOMAN regulated release is disconnected from agent storage tanks.
- c. Connect Regulator Test Kit (Part No. 56972) to one of the expellant gas line hoses and securely cap the remaining hose or pipe. See Figure 8-12.
- Verify that no cartridges are installed in the AUTOMAN or the regulated actuator assembly(s).
- e. To verify operation of the regulated actuator assembly(s), Pressure Adaptor (Part No. 427560) can be used to connect to a pressurized CO₂ or N₂ cylinder, instead of using a CO₂ or N₂ cartridge.


Note: The pressure adaptor assembly comes with a 1/4 in. NPT pipe plug that is required to be installed in the side of the adaptor.

- f. Install a suitable 1/4 inch air pressure quick connect fitting (supplied by others) to the bottom of the adaptor.
- g. Install and hand tighten the adaptor to the cartridge receiver and securely attach the corresponding connector from the gas cylinder hose assembly.
- h. With the valve on the regulator test kit closed, remove the lock bar or lock pin and operate the remote cable operated pull station to operate the regulated release.
- Open the pressure cylinder valve to verify that the regulated actuator assembly(s) has operated properly and the air cylinder has unlatched the ANSUL mechanical gas valve, if used.
- j. Once regulated actuator and gas valve operation is verified, close the valve on the pressurized cylinder, if used, and open the valve on the regulator test kit to relieve any residual pressure.

Note: Although only required at 12 year intervals, the regulator in the AUTOMAN regulated release can also be verified. See Maintenance steps on page 8-6.

- k. Re-cock the AUTOMAN regulated release and remove the spent cartridge or pressure adaptor from the cartridge receiver.
- I. If there were leaks in the actuation line or in the 1/8 inch copper gas tubing for the air cylinder(s), re-tighten the fittings or replace damaged components.
- m. If the cartridge puncture pin in the regulated actuator(s) did not fully extend, dismantle the actuator and inspect components of the actuator assembly.

- Once the pneumatic actuator is disassembled, remove the actuator piston assembly and check the interior walls of the actuator body for signs of damage or corrosion.
- Check the o-ring for elasticity or cuts. Replace, if necessary. Clean and coat o-ring with a good grade of extreme temperature silicone grease and reinstall.
- Re-assemble the actuator assembly(s), and reconnect all actuation and all expellant piping or hose.
- 6. Remove gasket from cartridge receiver in regulated release mechanism and each regulated actuator. Check gasket for elasticity or cuts and replace Gasket (Part No. 181) if necessary. Clean and coat gasket lightly with a good grade of extreme temperature grease. Reinstall gasket into cartridge receiver(s).
- 7. From tank in regulated release assembly: Disconnect the expellant gas hose from each tank adaptor assembly.
 - From tank in bracket/enclosure assembly: Disconnect the expellant gas piping union at each tank adaptor inlet line.
- Disconnect distribution piping union at each tank adaptor outlet line.
- 9. From tank in enclosure: Remove tank. Keep in upright position to avoid spilling the agent.
 - From tank in bracket assembly: Loosen wingnut, disengage bracket band, and remove each tank. Keep tank in upright position to avoid spilling the agent.
- Remove tank adaptor/tube assembly from each tank. See Figure 8-3.



11. Make certain that each tank is filled with 1.5 (5.8 L) or 3.0 (11.6 L) gallons of only ANSULEX Low pH Liquid Fire Suppressant. Fill level to be ONLY to the level indicated in the "Installation" section. See Page 5-3, Figure 5-6, for detailed filling tolerances.

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 8-3

SEMI-ANNUAL MAINTENANCE EXAMINATION (Continued) Alternate Test Method: (Continued)

- 12. Examine threads on each tank adaptor and tank collar for nicks, burrs, or cross-threading. Clean and coat o-ring with a good grade of extreme temperature grease. See Figure 8-4. Remove 1/4 in. vent plug and clean and inspect for free movement and corrosion (if necessary, replace Vent
- Plug (Part No. 74247)). Reinstall vent plug. Make certain bursting disc is in place and silver side is away from tank. Clean seating surface and return adaptor/tube assembly to each tank. Tighten securely.




FIGURE 8-4

- Place fully charged tanks in enclosures and/or brackets and secure.
- 14. Carefully assemble and wrench tighten all expellant gas and agent distribution piping.
- 15. Remove blow-off caps from nozzles. Inspect each blow-off cap and replace if deteriorated. On older style metal blow-
- off caps with spring clips, make certain spring clip rotates freely on cap. On newer metal blow-off caps, make certain
- integral o-ring is intact and undamaged. If there are signs of
- deterioration, replace cap(s).

NOTICE

Rubber blow-off caps that have been installed in the system for one year or more must be replaced.

16. Verify that all nozzle types are correct. Check all nozzles to ensure that they are free of cooking grease build-up and have a thin coating of clean silicone grease across the orifice.

Note: Do not allow silicone grease to enter nozzle orifice.

Note: If there is any evidence of cooking grease or other residue in the nozzles or distribution piping or agent or agent residue in the distribution piping, the entire piping network must be inspected and thoroughly cleaned. Portions of piping that cannot be thoroughly cleaned must be replaced.

Utilizing the Nozzle Aiming Device (Part No. 431992 or Part No. 439877) ensure that all nozzles are correctly aimed at the appropriate location on the appliance. Reinstall blow-off caps.

- ▶ 17. Remove the lock bar or lock pin and manually test the regulated release assembly by operating the remote manual pull station. Check pull station cover for damage or wear. Replace cover if cable has worn a groove in the cover as deep as the diameter of the cable. If flexible conduit is used in installation, check conduit for damage, cuts and sharp bends.
- 18. Cock the regulated release mechanism using cocking lever
 ▶ (Part No. 14995 or 435603/Part No. 441042 or 441041).
 See Figure 8-5.

Before proceeding with Step 18, test electric (snap-action) switches:

- With the AUTOMAN in the cocked or ready position, press the lever of each switch up. If the switch is working properly, there should be an audible click.
- b. With the AUTOMAN in the fired position, press the lever of each switch up, there should be no audible click.
- c. If an audible click is heard in the fired position several adjustments can be made. The trip lever extension pin can be rotated so the peak of one of the hex points is pointed up against the switch levers. Tighten it in that position. If this doesn't resolve the problem, loosen the screws holding the switches, apply a small counterclockwise torque on the switches and retighten the screws. If necessary, a final adjustment can be made by removing the snap action switch and bending the lever slightly.
- d. After adjustments, repeat Steps a. and b. Then, recock AUTOMAN and insert lock bar or lock pin.




FIGURE 8-5

SECTION 8 – MAINTENANCE EXAMINATION

UL EX3470 ULC EX3470

PAGE 8-4 REV. 11 2014-SEP-01

SEMI-ANNUAL MAINTENANCE EXAMINATION (Continued) Alternate Test Method: (Continued)

19. Raise tension lever to "UP" position. See Figure 8-6.




FIGURE 8-6

- ▶ 20. Install test link (Part No. 24916) in terminal detector.
 - 21. Lower tension lever to "DOWN" position. See Figure 8-7.




FIGURE 8-7

22. Using wire cutter, cut test link at terminal detector to simulate automatic actuation.

NOTICE

If regulated release mechanism does not actuate, refer to Steps 2 and 3 of "Testing Detection System" in "Testing and Placing in Service," Section 6, Page 6-3.

 After successful actuation, raise the tension lever to "UP" position.

- 24. Remove and destroy all existing fusible links from the terminal and series detector brackets and replace with properly-rated ANSUL approved, fusible links in accordance with NFPA 17A.
- 25. Inspect wire rope at all detector locations, pulley elbows, pulley tee and at AUTOMAN release. If wire rope shows signs of wear or fraying, replace entire length.
- 26. Lower the tension lever to "DOWN" position.
- 27. Recock the regulated release mechanism and insert the lock bar or lock pin.
- 28. Inspect the base of the wire rope locking clamp to make certain that there is a minimum of 1/4 in. (6.4 mm) and a maximum of 3/8 in. (9.5 mm) clearance between the base of the trip hammer locking clamp assembly and the cable lever assembly. See Figure 8-8.




FIGURE 8-8

000329

NOTICE

If clearance is not between 1/4 in. (6.4 mm) or 3/8 in. (9.5 mm), raise tension lever to "UP" position, raise trip hammer 3/8-1/2 in. (9.5-12.7 mm), tighten set screws, and repeat Steps 24 and 26.

- For scissor-style linkage, locate linkage and properly position in each bracket all the way toward termination end of detection run.
- 30. If a mechanical gas valve is installed, begin the test procedure by removing both side covers.
- 31. At the regulated release, push the air cylinder rod fully down.

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 8-5

SEMI-ANNUAL MAINTENANCE EXAMINATION (Continued) Alternate Test Method: (Continued)

- 32. The gas valve should operate.
- 33. Pull the air cylinder rod to its fully extended position.
- 34. Re-cock the gas valve by pulling the valve stem up until the pin in the stem engages the cocking lever.
- Reinstall side covers on the gas valve and connect the visual indication seal.
- 36. Test electric switches and electric gas valves by completing steps on Page 6-2 in Section 6, "Testing and Placing In Service."
- 37. Before reinstalling cartridge, reset all additional equipment by referring to appropriate section of "Recharge and Resetting Procedures," Section 7.
- 38. Remove shipping cap and weigh each cartridge. Replace if weight is 1/2 ounce (14.2 g), or more, below weight stamped on cartridge.
- 39. Make certain regulated release mechanism is cocked and lock bar or lock pin is installed, then screw replacement cartridge into regulated release mechanism and each regulated actuator receiver(s) and hand tighten.
- ▶ 40. Remove lock bar or lock pin.

CAUTION

Make certain tension lever is in the "DOWN" position after completing all tests. Failure to put the tension lever in the "DOWN" position will cause the system to not operate automatically.

- Snap cover on regulated release and each regulated actuator, insert visual seal (Part No. 197) through holes in cover and box, and secure.
- 42. If system contains an Agent Distribution Hose and Restraining Cable Assembly, also perform the following steps:
 - a. Carefully pull or push out the appliance and verify that the Restraining Cable limits the travel of the appliance and prevents the application of any pull force or bending stress on the Agent Distribution Hose or hose-to-pipe connections.
 - b. Check the Restraining Cable to verify it is not frayed and is securely fastened to the appliance and the wall or restraining location.
 - c. Check the hose and hose fittings and verify that the hose remains in a vertical natural loop with no noticeable fatigue at hose end couplings, no hose twists, no hose kinking or sharp bends.
 - d. Check the outer hose covering for signs of damage, checking, tears, or wear. If any of these signs are observed, replace the hose.

- e. Return the appliance to its normal operating position. Again, check the hose and hose fittings to verify that the hose does not have sharp bends, and is not kinked, twisted, or caught on anything behind the appliance. If any of these conditions exist, the hose and/or hose connections will require installation modifications.
- f. With the appliance in its normal operating position, check the hose bend to make certain the bend is not less than a 3 in. (77 mm) bend radius (6 in. (153 mm) diameter). If less, replace hose.
- g. Verify that the appliance is returned to its original desired location. Failure to do so may result in undue stress and fatigue of the hose and hose connections.
- 43. Record semi-annual maintenance date on tag attached to unit and/or in a permanent file.

ANNUAL MAINTENANCE EXAMINATION

In addition to performing all the steps necessary for Semi-Annual Maintenance, disconnect the agent discharge piping from the storage tank outlet(s) and verify that the agent distribution piping is not obstructed.

 At least annually, use dry air or nitrogen and blow through the agent distribution piping with the nozzle blow-off caps removed, verifying that dry air or nitrogen is discharging at each nozzle location.

CAUTION

If nozzles show signs of cooking grease migration into the orifice of the nozzle, or if there is evidence of agent residue in the nozzle(s) or the inlet to the agent distribution piping, some or all of the piping may require dismantling to verify that the piping is not obstructed.

At least annually, all rubber nozzle blow-off caps must be replaced.

Note: Annual replacement is not necessary for metal blow-off caps.

SECTION 8 – MAINTENANCE EXAMINATION

UL EX3470 ULC EX3470

PAGE 8-6 REV. 11 2014-SEP-01

12-YEAR MAINTENANCE EXAMINATION

In addition to performing all of the steps necessary for semi-annual and annual maintenance, the following twelve-year maintenance procedures for single, double, and multiple-tank systems must be performed.

NOTICE

Under certain circumstances hood and duct cleaning operations may render your fire suppression system ineffective due to a coating of cleaning chemical left on the detection equipment or mishandling of the system by cleaning service personnel.

Therefore, it is strongly recommended that the R-102 system be completely inspected and serviced by an authorized ANSUL distributor immediately following any such cleaning operations.

At twelve-year intervals, the liquid agent tank(s) must be hydrostatically tested and refilled with a fresh charge of ANSULEX Low pH Liquid Fire Suppressant. The date of manufacture is stamped on the bottom of the agent tank or on the tank label.

- Remove the enclosure cover from the AUTOMAN regulated release assembly and each regulated actuator assembly.
- Insert the lock bar (Part No. 14985) or lock pin (Part No. 438031) on the cocked regulated release mechanism. See Figure 8-9 or Figure 8-10.




FIGURE 8-9




FIGURE 8-10

Remove cartridge from regulated release assembly and each regulated actuator assembly, install safety shipping cap, and set aside in a safe location.

CAUTION

Do not reinstall cartridge at this time or system may be actuated.

- 4. Remove gasket from cartridge receiver in regulated release mechanism and each regulated actuator. Check gasket for elasticity or cuts and replace Gasket (Part No. 181) if necessary. Clean and coat gasket lightly with a good grade of extreme temperature grease. Reinstall gasket into cartridge receiver(s).
- 5. From tank in enclosure: Disconnect the expellant gas piping or hose from each tank adaptor assembly.
 - From tank in bracket assembly: Disconnect expellant gas piping union at each tank adaptor inlet line.
- Disconnect distribution piping union at each tank adaptor outlet line.
- 7. From tank in enclosure: Remove tank.

From tank in bracket assembly: Loosen wingnut, disengage bracket band, and remove each tank. Keep tank in upright position to avoid spilling the agent.

8. Loosen tank adaptor/tube assembly and remove.

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 8-7

12-YEAR MAINTENANCE EXAMINATION (Continued)

9. A CAUTION

Safety glasses should be worn during transfer operations of ANSULEX Low pH Liquid Fire Suppressant. Avoid contact with skin or eyes. In case of contact, flush immediately with water for 15 minutes. If irritation persists, contact a physician. Do not take internally. If taken internally do not induce vomiting. Dilute with water or milk and contact a physician.

Pour the liquid agent from the tank into a clean, plastic container, and flush tank with clear water.

10. At this point, each liquid agent tank, including the 1/4 in. gas hose assembly, must be HYDROSTATICALLY TESTED to 330 psi (26.6 bar). Refer to "Hydrostatic Test Instructions," F-7602, for test adaptors and instructions.

NOTICE

DO NOT hydrostatically test a red painted mild steel agent storage tank. Instead, replace the tank with a new stainless steel tank shipping assembly (3 Gallon (Part No. 429862) or 1.5 Gallon (Part No. 429864)).

- 11. Verify date stamped on cartridge. The cartridge must also be hydrotested at intervals not greater than 12 years. (European cartridges are not refillable, therefore cannot be hydrotested and refilled. They must be discarded).
- 12. If cartridge date indicates the need for hydrotesting, the cartridge must be bled down through normal AUTOMAN release operation, returned to Tyco Fire Protection Products for credit (or hydrotested by properly trained personnel at authorized cartridge refilling stations), and replaced with a charged, replacement cartridge.

NOTICE

Cartridge bleed down can be used to verify pneumatic accessories operation.

- 13. If system contains an Agent Distribution Hose and Restraining Cable Assembly, a hydrostatic test is required at 220 psi (15.2 bar) for hose assembly.
- 14. The regulator must be flow tested at 12 year intervals. Check the date code stamped on the regulator body to determine if the regulator(s) requires the 12 year testing (see data code table). If regulator does not require testing, proceed to step 12. Flow test the regulator(s) per the following table:

Date Code Table

UL 541L

		1		
Month*			Yea	ır*
Jan	Α		1981 K	
Feb	В		1982	L
Mar	С		1983	М
Apr	D		1984	N
May	Е		1985	Р
Jun	F		1986	R
Jul	G		1987	S
Aug	Н		1988	Т
Sep	J		1989	U
Oct	K		1990	V
Nov	L		1991	W
Dec	М		1992	Υ
			1993	Z
			1994	Α
			1995	В
			1996	С
			1997	D
			1998	Е
			1999	F
			2000	G
			2001	Н
			2002	J
			2003	K
			2004	L
			2005	М

*STAMPED MONTH 1ST, YEAR 2ND

UL 74FF

Year*		Month	า**
2005	Е	Jan	А
2006	F	Feb	В
2007	G	Mar	С
2008	Н	Apr	D
2009	I	May	E
2010	J	Jun	F
2011	K	Jul	G
		Aug	Н
		Sep	ı
		Oct	J
		Nov	Ιĸ

*STAMPED YEAR 1ST, MONTH 2ND

Dec

**STAMPED "I" FOR SEPTEMBER

UL 74FF

Month*		Yea	ır*
Jan	Α	2011	Т
Feb	В	2012	U1
Mar	С	2013	U2
Apr	D	2014	U3
May	Е	2015	U4
Jun	F	2016	U5
Jul	G	2017	U6
Aug	Н	2018	U7
Sep	J	2019	U8
Oct	K	2020	U9
Nov	L	2021	V1
Dec	М	2022	V2
		2023	V3
		2024	V4
		2025	V5

*STAMPED MONTH 1ST, YEAR

SECTION 8 - MAINTENANCE EXAMINATION

UL EX3470 ULC EX3470

PAGE 8-8 REV. 11 2014-SEP-01

12-YEAR MAINTENANCE EXAMINATION (Continued) Step 14 (Continued)

a. Regulated Release Mechanism

For First Tank: Disconnect expellant gas pipe or hose from tank. Connect regulator test kit (Part No. 56972) to hose. See Figure 8-11.




FIGURE 8-11

For Second Tank: Disconnect expellant gas piping at union. Remove union from expellant gas piping and install pipe cap to prevent cartridge pressure from escaping during test. See Figure 8-12.




FIGURE 8-12

Pressure Switch: If an ANSUL supplied pressure switch is still in good operating condition, it should remain connected as part of system maintenance test.

NOTICE

For multiple-tank systems, one test kit (Part No. 56972) is required for each regulator in the system.

b. Regulated Actuator

For First Tank: Disconnect expellant gas hose from tank. Connect regulator test kit (Part No. 56972) to hose. See Figure 8-13.




FIGURE 8-13

For Second Tank: Disconnect expellant gas piping at union. Remove union from expellant gas piping and install pipe cap to prevent cartridge pressure from escaping during test. See Figure 8-14.




FIGURE 8-14

00037

NOTICE

Make certain valve is **closed** on regulator test kit or pressure will escape before test can be performed.

UL EX3470 **ULC EX3470** 2014-SEP-01 **REV. 11 PAGE 8-9**

12-YEAR MAINTENANCE EXAMINATION (Continued) Step 14 (Continued)


c. Install either a nitrogen or CO2 cartridge into release mechanism and each regulated actuator provided with the system. (Cartridge should be conditioned to approximately 70 °F (21 °C) before test.)

NOTICE


Before continuing with Step d, make certain valve on test kit is closed.

d. Remove lock bar or lock pin and operate remote manual pull station to actuate the regulated release and supply pressure to each test kit.

Two styles of regulators are used with the R-102 release mechanisms. The diaphragm style (see Figure 8-15) was used in R-102 systems up to approximately 1988. The piston style (see Figure 8-15) has been used since 1988. Each style requires a slightly different flow test procedure. Use the appropriate flow test procedure as stated in Step e.



DIAPHRAGM STYLE (USED UNTIL 1988)



PISTON STYLE (USED AFTER 1988)

FIGURE 8-15

e. Flow test each regulator by completing the following

Diaphragm Style – The correct pressure should read 90 to 110 psi (6.2 to 7.6 bar) with the valve on the test kit closed and 80 psi (5.5 bar) with the valve on the test kit opened. Keep the valve opened to completely empty the pressure cartridge after pressure test has been verified.

Piston Style - Open the valve on the regulator test kit. The correct pressure should read between 95 to 125 psi (6.6 to 8.6 bar). Keep the valve open to completely empty the pressure cartridge.

If necessary, continue to flow test at each additional regulated actuator. Test each regulated actuator by repeating Step e.

- f. Cock release mechanism using cocking lever (Part No. 14995 or 435603/Part No. 441042 or 441041) and insert lock bar (Part No. 14985) or lock pin (Part No. 438031).
- g. Remove empty nitrogen cartridge(s) from release mechanism and each regulated actuator.
- h. Remove test kit(s) from release mechanism and each regulated actuator.

- i. If regulator test was not successful, replace regulator.
- j. Reconnect all expellant gas lines.
- k. Reset all additional equipment that was operated by release mechanism.
- 15. Examine threads on each adaptor and tank collar for nicks. burrs, or cross-threading. Clean and coat o-ring with a good grade of extreme temperature grease. Make certain bursting disc is in place and silver side is away from tank. See Figure 8-16.




FIGURE 8-16

- 16. Examine pick-up tube for signs of damage or corrosion. Replace assembly if needed.
- 17. Refill each tank with 1.5 (5.8 L) or 3.0 (11.6 L) gallons of only new ANSULEX Low pH Liquid Fire Suppressant. Note: Use a funnel with a screen to stop any foreign material from entering the tank.

CAUTION

During filling, the agent temperature should be 60 °F to 80 °F (16 °C to 27 °C). DO NOT FILL WITH COLD AGENT. Refer to the "Installation" section, Page 5-3 for maximum fill heights for ANSULEX Low pH agent storage tanks. DO NOT OVERFILL. Overfilling may result in agent entering gas hose and regulator, potentially causing system malfunction.

18. Clean seating surface and return each adaptor/tube assembly to tank. Firmly tighten.

NOTICE

Do not reinstall any tank at this time.

19. Remove blow-off caps from nozzles. Inspect each blow-off cap and replace if deteriorated. On older style metal blowoff caps with spring clips, make certain spring clip rotates freely on cap. On newer metal blow-off caps, make certain integral o-ring is intact and undamaged. If there are signs of deterioration, replace cap(s).

NOTICE

Rubber blow-off caps that have been installed in the system for one year or more must be replaced.

SECTION 8 – MAINTENANCE EXAMINATION

UL EX3470 ULC EX3470

PAGE 8-10 REV. 11 2014-SEP-01

12-YEAR MAINTENANCE EXAMINATION (Continued)

- 20. Check all nozzles to ensure that they are free of cooking grease build-up and have a covering of clean silicone grease on the orifice. Reinstall blow-off caps.
- 21. Remove lock bar or lock pin and manually test the regulated release assembly by operating the remote manual pull station.
 - Cock the regulated release mechanism using cocking lever (Part No. 14995 or 435603/Part No. 441042 or 441041).
 See Figure 8-17.




FIGURE 8-17

23. Raise the tension lever to "UP" position. See Figure 8-18.




FIGURE 8-18

▶ 24. Install test link (Part No. 24916) in terminal detector.

25. Lower tension lever to "DOWN" position. See Figure 8-19.




FIGURE 8-19

26. Using wire cutter, cut test link at terminal detector to simulate automatic actuation.

NOTICE

If regulated release mechanism does not actuate, refer to Steps 2 and 3 of "Testing Detection System" in "Testing and Placing in Service," Section 6.

- After successful actuation, raise the tension lever to "UP" position.
- Remove and destroy all existing fusible links from the terminal and series detector brackets and replace with properly-rated ANSUL approved, fusible links in accordance with NFPA 17A.
- 29. Lower tension lever to "DOWN" position.
- 30. Recock the regulated release mechanism and insert lockbar or lock pin.

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 8-11

12-YEAR MAINTENANCE EXAMINATION (Continued)

31. Inspect the base of the wire rope locking clamp to make certain that there is a minimum of 1/4 in. (6.4 mm) and a maximum of 3/8 in. (9.5 mm) clearance between the base of the trip hammer locking clamp assembly and the cable lever assembly. See Figure 8-20.




FIGURE 8-20

NOTICE

If clearance is not between 1/4 in. (6.4 mm) or 3/8 in. (9.5 mm), raise tension lever to "UP" position, raise trip hammer 3/8-1/2 in. (9.5-12.7 mm), tighten set screws, and repeat Steps 29 and 31.

- Locate detector linkage and properly position in each bracket.
- 33. Make certain additional devices have operated as intended.
- 34. Before reinstalling cartridge, reset all additional equipment by referring to appropriate section of "Recharge and Resetting Procedures," Section 7.
- 35. Place each fully charged tank in enclosure and/or bracket and secure.
- 36. Reconnect all distribution piping and expellant gas piping unions as required. Wrench tighten.
- 37. Check each gas cartridge by removing shipping cap and weighing cartridge. Replace if weight is 1/2 ounce (14.2 g), or more, below weight stamped on cartridge.
- 38. Make certain regulated release mechanism is cocked and lock bar or lock pin is installed, then screw replacement cartridge into regulated release mechanism and each regulated actuator receiver(s) and hand tighten.

- ▶ 39. Remove lock bar or lock pin.
 - 40. Install cover on regulated release assembly and each regulated actuator assembly and secure with appropriate fasteners or visual inspection seal. Insert seal (Part No. 197) in each upper and lower cover hole, if applicable. If system is installed in an OEM enclosure, attach enclosure cover and secure with appropriate hardware or procedure.

CAUTION

Before installing cover, make certain tension lever is in the "DOWN" position after completing all tests. Failure to put the tension lever in the "DOWN" position will cause the system to not operate automatically.

41. Record date of 12 year maintenance examination on tag attached to enclosure and/or in a permanent file.

UL EX3470 ULC EX3470

PAGE 8-12 REV. 11 2014-SEP-01

NOTES:

SYSTEM SELECTION GUIDE

Note: System options do not cover all conceivable/acceptable variations. They are listed here as a general guideline to show the most common type arrangement for multiple systems. Based on certain system designs utilizing manifolding, non-manifolding, 3-tank systems, etc., other tank/cartridge combinations can be designed. The combinations below are based on 11 flow, 3 gallon tanks and 5 flow, 1.5 gallon tanks. More competitive designs may be available by utilizing 12 flow and 6 flow systems when appropriate.

•	0		,	0	, , , , ,
Total Flow No.* 1-5	Tank Quantity 1	Type of System Single	Type of Hardware 1.5 Gal. Reg. Release	Carbon Dioxide Cartridge Required 101-10 (423439)	Nitrogen Cartridge Required LT-20-R (423429)
6-11	1	Single	3 Gal. Reg. Release	101-20 (423441)	LT-30-R (423435)
12-16	2	Double	1.5 Gal. Reg. Release 3 Gal. Additional Tank	101-30 (423443)	Double (423493)
17-22	2	Double	3 Gal. Reg. Release 3 Gal. Additional Tank	101-30 (423443)**	Double (423493)
▶ 17-22	2	Manifold	3 Gal. Reg. Release 3 Gal. Additional Tank	_	Double (423493)
23-27	3	Multiple	1.5 Gal. Reg. Release3 Gal. Reg. Actuator3 Gal. Additional Tank	101-10 (423439) 101-30 (423443)***	LT-20-R (423429) LT-A-101-30 (423491)
23-33	3	Multiple	3 Gal. Reg. Release3 Gal. Reg. Actuator3 Gal. Additional Tank	101-20 (423441) 101-30 (423443)***	LT-30-R (423435) LT-A-101-30 (423491)
► 23-33 (Optional)	3	Multiple	3 Gal. Reg. Release (2) 3 Gal. Additional Tanks	N/A	Double (423493)
34-38	4	Multiple	1.5 Gal. Reg. Release3 Gal. Reg. ActuatorDouble 3 Gal. Tank Box	101-10 (423439) N/A	LT-20-R (423435) LT-A-101-30 (423491)
34-38	4	Multiple	1.5 Gal. Reg. Release	101-30 (423443)	Double (423493)
(Optional)			3 Gal. Additional Tank3 Gal. Reg. Actuator3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
39-44	4	Multiple	3 Gal. Reg. Release 3 Gal. Reg. Actuator Double 3 Gal. Tank Box	101-20 (423441) N/A	LT-30-R (423435) LT-A-101-30 (423491)
39-44 (Optional)	4	Multiple	3 Gal. Reg. Release 3 Gal. Additional Tank	101-30 (423443)**	Double (423493)
(Optional)			3 Gal. Additional Tank 3 Gal. Reg. Actuator 3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
45-49	5	Multiple	1.5 Gal. Reg. Release	101-30 (423443)	Double (423493)
			3 Gal. Additional Tank 3 Gal. Reg. Actuator Double 3 Gal. Tank Box	N/A	LT-A-101-30 (423491)

^{*} Based on 5 flow numbers for a 1.5 gal system and 11 flow numbers for a 3 gal. system.

 $^{^{\}star\star}$ If tanks are manifolded, only a "double tank" nitrogen cartridge (Part No. 423493) can be used.

^{***} If tanks are manifolded, either an LT-A-101-30 nitrogen cartridge (Part No. 423491) or a double tank cartridge (Part No. 423493) can be used.

SECTION 9 – APPENDIX

UL EX3470 ULC EX3470

PAGE 9-2 REV. 11 2014-SEP-01

SYSTEM SELECTION GUIDE (Continued)

SYSTEM SELE					
Total Flow No.*	Tank Quantity	Type of System	Type of Hardware	Carbon Dioxide Cartridge Required	Nitrogen Cartridge Required
45-49 (Optional)	5	Multiple	1.5 Gal. Reg. Release3 Gal. Reg. Actuator3 Gal. Additional Tank	101-10 (423439) 101-30 (423443)***	LT-20-R (423429) LT-A-101-30 (423491)
			3 Gal. Reg. Actuator 3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
50-55	5	Multiple	3 Gal. Reg. Release 3 Gal. Additional Tank	101-30 (423443)	Double (423493)
			3 Reg. Actuator Double 3 Gal. Tank Box	N/A	LT-A-101-30 (423491)
50-55 (Optional)	5	Multiple	3 Gal. Reg. Release 3 Gal. Reg. Actuator	101-20 (423441) 101-30 (423443)***	LT-30-R (423435) LT-A-101-30 (423491)
			3 Gal. Additional Tank3 Gal. Reg. Actuator3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
56-60	6	Multiple	1.5 Gal. Reg. Release 3 Gal. Additional Tank	101-30 (423443)	Double (423493)
			3 Gal. Reg. Actuator 3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
		3 Gal. Reg. Actuator 3 Gal. Additional Tank	3 Gal. Reg. Actuator	101-30 (423443)***	LT-A-101-30 (423491)
61-66	6	Multiple	3 Gal. Reg. Release 3 Gal. Additional Tank	101-30 (423443)**	Double (423493)
			3 Gal. Reg. Actuator3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
			3 Gal. Reg. Actuator 3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
67-71	7	Multiple	1.5 Gal. Reg. Release(2) 3 Gal. Reg. Actuator(2) Double 3 Gal. Tank Box	101-10 (423439) N/A	LT-20-R (423429) (2) LT-A-101-30 (423491)
67-71 (Optional)	7	Multiple	Remote Mechanical Release 3 Gal. Reg. Actuator 1.5 Gal. Additional Tank	101-10 (423439) 101-30 (423443)	 LT-A-101-30 (423491)
			3 Gal. Reg. Actuator 3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
			3 Gal. Reg. Actuator 3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
			3 Gal. Reg. Actuator	101-20 (423441)***	LT-30-R (423435)
72-77	7	Multiple	3 Gal. Reg. Release(2) 3 Gal. Reg. Actuator(2) Double 3 Gal. Tank Box	101-20 (423441) N/A	LT-30-R (423435) (2) LT-A-101-30 (423491)
72-77 (Optional)	7	Multiple	Remote Mechanical Release 3 Gal. Reg. Actuator 3 Gal. Additional Tank	101-10 (423439) 101-30 (423443)***	 LT-A-101-30 (423491)
			3 Gal. Reg. Actuator 3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
			3 Gal. Reg. Actuator3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
* Dec-1 5 "		al austana and 44 °	3 Gal. Reg. Actuator	101-20 (423441)	LT-30-R (423435)

^{*} Based on 5 flow numbers for a 1.5 gal. system and 11 flow numbers for a 3 gal. system.

^{**} If tanks are manifolded, only a "double tank" nitrogen cartridge (Part No. 423493) can be used.

^{***} If tanks are manifolded, either an LT-A-101-30 nitrogen cartridge (Part No. 423491) or a double tank cartridge (Part No. 423493) can be used.

SYSTEM SELECTION GUIDE (Continued)

STSTEW SELEC	TION GUID	E (Continued)			
Total Flow No.* 78-82	Tank Quantity 8	Type of System Multiple	Type of Hardware 1.5 Gal. Reg. Release 3 Gal. Additional Tank (2) 3 Gal. Reg. Actuator (2) Double 3 Gal. Tank Box	Carbon Dioxide Cartridge Required 101-30 (423443) N/A	Nitrogen Cartridge Required LT-30-R (423435) (2) LT-A-101-30 (423491)
78-82 (Optional)	8	Multiple	Remote Mechanical Release 3 Gal. Reg. Actuator 1.5 Gal. Additional Tank	101-10 (423439) 101-30 (423443)	 LT-A-101-30 (423491)
			3 Gal. Reg. Actuator 3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
			3 Gal. Reg. Actuator	101-30 (423443)***	LT-A-101-30 (423491)
			3 Gal. Additional Tank3 Gal. Reg. Actuator3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
83-88	8	Multiple	3 Gal. Reg. Release 3 Gal. Additional Tank	101-30 (423443)	LT-30-R (423435)
			(2) 3 Gal. Reg. Actuator (2) Double 3 Gal. Tank Box	N/A	(2) LT-A-101-30 (423491)
83-88	8	Multiple	Remote Mechanical Release	101-10 (423439)	
(Optional)	O	Wattiple	3 Gal. Reg. Actuator 3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
			3 Gal. Reg. Actuator 3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
			3 Gal. Reg. Actuator 3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
			3 Gal. Reg. Actuator 3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
89-99	9	Multiple	Remote Mech. Release (3) 3 Gal. Reg. Actuator (3) Double 3 Gal. Tank Box	101-10 (423439) N/A	N/A (3) LT-A-101-30 (423491)
89-93 (Optional)	9	Multiple	Remote Mechanical Release 3 Gal. Reg. Actuator	101-10 (423439) 101-30 (423443)***	 LT-A-101-30 (423491)
			3 Gal. Additional Tank 3 Gal. Reg. Actuator	101-30 (423443)***	LT-A-101-30 (423491)
			3 Gal. Additional Tank3 Gal. Reg. Actuator3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
			3 Gal. Reg. Actuator 1.5 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
			3 Gal. Reg. Actuator	101-20 (423441)	LT-30-R (423435)
94-99	9	Multiple	Remote Mechanical Release	101-10 (423439)	
(Optional)		•	3 Gal. Reg. Actuator 3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
			3 Gal. Reg. Actuator3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
			3 Gal. Reg. Actuator 3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
			3 Gal. Reg. Actuator 3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
			3 Gal. Reg. Actuator	101-20 (423441)	LT-30-R (423435)

 $^{^{\}star}$ Based on 5 flow numbers for a 1.5 gal. system and 11 flow numbers for a 3 gal. system.

^{**} If tanks are manifolded, only a "double tank" nitrogen cartridge (Part No. 423493) can be used.

^{***} If tanks are manifolded, either an LT-A-101-30 nitrogen cartridge (Part No. 423491) or a double tank cartridge (Part No. 423493) can be used.

SECTION 9 – APPENDIX

UL EX3470 ULC EX3470

PAGE 9-4 REV. 11 2014-SEP-01

SYSTEM SELECTION GUIDE (Continued)

Total Flow No.* 100-110	Tank Quantity 10	Type of System Multiple	Type of Hardware Remote Mech. Release (3) 3 Gal. Reg. Actuator (3) Double 3 Gal. Tank Box 3 Gal. Reg. Actuator	Carbon Dioxide Cartridge Required 101-10 (423439) N/A 101-20 (423441)	Nitrogen Cartridge Required N/A (3) LT-A-101-30 (423491) LT-30-R (423435)
100-104 (Optional)	10	Multiple	Remote Mechanical Release 3 Gal. Reg. Actuator 1.5 Gal. Additional Tank	101-10 (423439) 101-30 (423443)	 LT-A-101-30 (423491)
			3 Gal. Reg. Actuator 3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
			3 Gal. Reg. Actuator 3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
			3 Gal. Reg. Actuator 3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
			3 Gal. Reg. Actuator 3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
100-104 (Optional)	10	Multiple	Remote Mech. Release (2) 3 Gal. Reg. Actuator (2) Double 3 Gal. Tank Box	101-10 (423439) N/A	N/A (2) LT-A-101-30 (423491)
			(2) 3 Gal. Reg. Actuator 3 Gal. Additional Tank 1.5 Gal. Additional Tank	(2) 101-30 (423443)	(2) LT-A-101-30 (423491)
105-110 (Optional)	10	Multiple	Remote Mechanical Release 3 Gal. Reg. Actuator 3 Gal. Additional Tank	101-10 (423439) 101-30 (423443)***	 LT-A-101-30 (423491)
			3 Gal. Reg. Actuator 3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
			3 Gal. Reg. Actuator 3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
			3 Gal. Reg. Actuator 3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)
			3 Gal. Reg. Actuator 3 Gal. Additional Tank	101-30 (423443)***	LT-A-101-30 (423491)

^{*} Based on 5 flow numbers for a 1.5 gal. system and 11 flow numbers for a 3 gal. system.

Options are available up to a maximum of 15 tanks. Contact Technical Services Department for detailed information.

^{**} If tanks are manifolded, only a "double tank" nitrogen cartridge (Part No. 423493) can be used.

^{***} If tanks are manifolded, either an LT-A-101-30 nitrogen cartridge (Part No. 423491) or a double tank cartridge (Part No. 423493) can be used.

SYSTEM COMPONENT INDEX

	COMPONENT IN	IDEA		
	Description		Part No.	Description
429853	Mechanical AUT Shipping Asseml	OMAN Regulated Release	418054	OEM Regulated Electric Release Shipping
>	Includes: Re	gulated Release Mechanism in ainless Steel Mounting Enclosure		Assembly (120VAC) Includes: Regulated Release Mechanism with Solenoid and Switch
429856	Electric AUTOM. Shipping Asseml	AN Regulated Release	70402	1/4 in. Hose and Mounting Bracket
	Includes: Re So	gulated Release Mechanism with lenoid and Switch in ainless Steel Mounting Enclosure	79493	OEM Regulated Mechanical Release Shipping Assembly Includes: Regulated Release Mechanism 1/4 in. Hose and Mounting Bracket
429850 •	Includes: Ac	ntor Shipping Assembly tuator and Regulator in ainless Steel Mounting Enclosure	418691	OEM Regulated Actuator Shipping Assembly Includes: Actuator and Regulator Hose
429870 •		Mounting Box Shipping Assembly ainless Steel Mounting Box	429878	Bracket 3 Gallon Bracket Assembly (Bracket Only)
429872		sure Shipping Assembly	433485	Remote Release Assembly
>		: Two Expellant Gas Hoses Two Grommets	▶439946	OEM Remote Release Assembly
429859	24VDC Regulate	ainless Steel Mounting Box ed Release Shipping Assembly	418522	OEM Regulated Actuator Shipping Assembly Includes: Actuator and Regulator
		24VDC AUTOMAN II-C Release Mechanism in Stainless Steel	429862	Hose
		Mounting Box	429864	3 Gallon Tank Shipping Assembly
430299		echanical Release Shipping Assembly flechanical Regulated Release Assembly Gallon Tank Assembly Mechanical Release Shipping Assembly	56972	1.5 Gallon Tank Shipping Assembly Regulator Test Kit
				Includes: Gauge, Hose and Valve Assembly
430300			79694	1.5 Gallon (5.8 L) Container of ANSULEX Low pH Liquid Fire Suppressant
		nical Regulated Release Assembly llon Tank Assembly	79372	3.0 Gallon (11.6 L) Container of ANSULEX Low pHLiquid Fire Suppressant
430309		ted Actuator Shipping Assembly	423429	Cartridge Shipping Assembly (LT-20-R) (TC/DOT)
+30303	including:		423435	Cartridge Shipping Assembly (LT-30-R) (TC/DOT)
		julated Actuator Assembly allon Tank Assembly	423493	Cartridge Shipping Assembly (R-102 Double-Tank) (TC/DOT)
430316	Assembly includ	less Steel Enclosure Shipping ing: gle Tank Mounting Box Assembly	423491	Cartridge Shipping Assembly (LT-A-101-30) (TC/DOT)
		Gallon Tank Assembly	423439	Cartridge Shipping Assembly (101-10) (TC/DOT)
430317		ss Steel Enclosure Shipping	15850	Cartridge Shipping Assembly (101-10) (DOT)
	Assembly includ 429870 Sind	cluding: Single Tank Mounting Box Assembly	423441	Cartridge Shipping Assembly (101-20) (TC/DOT)
		allon Tank Assembly	423443	Cartridge Shipping Assembly (101-30) (TC/DOT)
430324		ss Steel Enclosure Shipping	428440	Cartridge Shipping Assembly (LT-20-R) (European)
	Assembly includ 429872 Two	ing: Tank Mounting Box Assembly	428441	Cartridge Shipping Assembly (LT-30-R) (European)
420222		allon Tank Assembly (2)	428446	Cartridge Shipping Assembly (R-102 Double Tank) (European)
430332	including: 429878 3 G	ng Bracket Shipping Assembly allon Mounting Bracket Assembly allon Tank Assembly	428442	Cartridge Shipping Assembly (LT-A-101-30) (European)

SECTION 9 – APPENDIX

UL EX3470 ULC EX3470

PAGE 9-6 REV. 11 2014-SEP-01

SYSTEM COMPONENT INDEX (Continued)

Part No.	Description	Part No.	Description
428443	Cartridge Shipping Assembly (101-10) (European)	419385	Swivel Adaptor Shipping Assembly
428445	Cartridge Shipping Assembly (101-20) (European)		Includes: 9 Swivel Adaptors
428444	Cartridge Shipping Assembly (101-30) (European)	423572	Swivel Adaptor Shipping Assembly Includes: 25 Swivel Adaptors
428948	Cartridge Shipping Assembly (LT-20-R) (Australian)	77695	Blow-Off Cap Shipping Assembly (Spare)
426553	Cartridge Shipping Assembly (LT-30-R) (Australian)		Includes: 50 Blow-Off Caps
426563	Cartridge Shipping Assembly (R-102 Double Tank) (Australian)	77411	Blow-Off Cap Shipping Assembly Includes: 12 Blow-Off Caps
426555	Cartridge Shipping Assembly (LT-A-101-30) (Australian)	433208	CB Metal Blow-Off Cap Shipping Assembly Includes: 10 Blow-Off Caps
▶ 439839	Nozzle Shipping Assembly (1W) Includes: 25 1W Nozzles	► 439861 ►	Metal Blow-Off Cap Shipping Assembly Includes: 10 Blow-Off Caps
► 439837	25 Blow-Off Caps Nozzle Shipping Assembly (1/2N)	434707	CB Stainless Steel Blow-Off Cap Shipping Assembly Includes: 10 Blow-Off Caps
	Includes: 9 1/2N Nozzles 9 Blow-Off Caps	► 439866 ►	Stainless Steel Blow-Off Cap Shipping Assembly Includes: 10 Blow-Off Caps
▶ 439838	Nozzle Shipping Assembly (1N) Includes: 25 1N Nozzles 25 Blow-Off Caps	► 439848 ►	Metal Blow-Off Cap O-Ring Shipping Assembly Includes: 25 O-Rings
► 439841 Nozzle S	Nozzle Shipping Assembly (3N)	► 416970	In-Line Burst Disc Union Assembly
7 400041	Includes: 9 3N Nozzles 9 Blow-Off Caps	417911	In-Line Burst Disc Shipping Assembly Includes: 10 Burst Discs
▶ 439840	Nozzle Shipping Assembly (2W)	25627	1/4 in. Check Valve
	Includes: 25 2W Nozzles 25 Blow-Off Caps	▶ 551265	Nozzle Aiming Device (without Adaptor)
► 439842	Nozzle Shipping Assembly (230)	439877	Nozzle Aiming Device with Adaptor
	Includes: 25 230 Nozzles	439876	Aiming Device Adaptor
. 400040	25 Blow-Off Caps	435547	Series Detector Shipping Assembly ("Scissor")
▶ 439843	Nozzle Shipping Assembly (245) Includes: 25 245 Nozzles	435548	Series Detector, Pack of 25 ("Scissor")
► 439844	25 Blow-Off Caps Nozzle Shipping Assembly (260)	435546	Terminal Detector Shipping Assembly ("Scissor") Includes: Test Link
	Includes: 9 260 Nozzles 9 Blow-Off Caps	435545	Detector Hook Assembly ("Scissor")
► 439845	Nozzle Shipping Assembly (290) Includes: 9 290 Nozzles	▶ 439515	Detector Hook Assembly ("Scissor") Includes: 10 Detectors
► 439846	9 Blow-Off Caps Nozzle Shipping Assembly (2120)	415671	Pulley Elbows Shipping Assembly (Socket End) – to 700 °F (371 °C)
7 400040	Includes: 9 2120 Nozzles 9 Blow-Off Caps	423251	Includes: 50 Elbows Pulley Elbows Shipping Assembly (Compression
▶ 439836	Nozzle Shipping Assembly (1F) Includes: 9 1F Nozzles	407000	End) – to 700 °F (371 °C) Includes: 50 Elbows
	9 Blow-Off Caps	427929	Pulley Tee
▶ 439865	Stainless Steel Nozzle Shipping Assembly (1N)	15821 79653	Wire Rope (50 ft (15.2 m)) Wire Rope (500 ft (152.4 m))
. 400004	Includes: 1 Blow-Off Cap	79653 24919	Stop Sleeve Package
▶ 439864	Stainless Steel Nozzle Shipping Assembly (1W) Includes: 1 Blow-Off Cap	2 4 313	Includes: 10 Stop Sleeves

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 9-7

SYSTEM COMPONENT INDEX (Continued)

Part No.	Description	Part No.	Description
550122	Oval Sleeve Package Includes: 100 Oval Sleeves	426151	Gas Shut-off Equipment (Electrical 110 VAC, 60 Hz) Includes: Relay – Manual Reset
436063	Conduit Offset Shipping Assembly Includes: 6 Conduit Offsets	423878	One Electric Switch (Field Mounted) Kit Includes: Electric Switch (SPDT) Mounting Hardware
78196	1/4 in. "Quik-Seal" Adaptor Package Includes: 24 "Quik-Seals"	423879	Two Electric Switch (Field Mounted) Kit
77285	3/8 in. "Quik-Seal" Adaptor Package Includes: 24 "Quik-Seals"		Includes: 2 Electric Switches (SPDT) Mounting Hardware
77287	1/2 in. "Quik-Seal" Adaptor Package Includes: 24 "Quik-Seals"	423880	Three Electric Switch (Field Mounted) Kit Includes: 3 Electric Switches (SPDT) Mounting Hardware
77289	3/4 in. "Quik-Seal" Adaptor Package Includes: 24 "Quik-Seals"	423881	Four Electric Switch (Field Mounted) Kit Includes: 4 Electric Switches (SPDT)
79149	1/4 in. "Compression-Seal" Pipe Adaptor Package Includes: 24 "Compression-Seals"	100011	Mounting Hardware
79151	3/8 in. "Compression-Seal" Pipe Adaptor Package	428311	Alarm Initiating Switch Kit
70447	Includes: 24 "Compression-Seals"	55598	Gas Shut-off Equipment Mechanical (ANSUL) Includes: Mechanical Gas Valve – 3/4 in.
79147	1/2 in. "Compression-Seal" Pipe Adaptor Package Includes: 24 "Compression-Seals"	55601	Gas Shut-off Equipment Mechanical (ANSUL) Includes: Mechanical Gas Valve – 1 in.
79153	1/2 in. "Compression-Seal" EMT Conduit Adaptor Package Includes: 24 "Compression-Seals"	55604	Gas Shut-off Equipment Mechanical (ANSUL) Includes: Mechanical Gas Valve – 1 1/4 in.
423253	Hood Seal Adaptor Shipping Assembly Includes: 6 Hood Seals	55607	Gas Shut-off Equipment Mechanical (ANSUL) Includes: Mechanical Gas Valve – 1 1/2 in.
436228	Reducing Coupling	55610	Gas Shut-off Equipment Mechanical (ANSUL) Includes: Mechanical Gas Valve – 2 in.
4 41042	Short Handle Cocking Lever with Lock Pin (Mechanical/Electrical AUTOMAN)	25937	Gas Shut-off Equipment Mechanical (ASCO) Includes: Mechanical Gas Valve – 2 1/2 in.
▶ 441041	Long Handle Cocking Lever with Lock Pin (Mechanical/Electrical AUTOMAN)	25938	Gas Shut-off Equipment Mechanical (ASCO) Includes: Mechanical Gas Valve – 3 in.
26310	Cocking Lever (AUTOMAN II-C)	15733	Gas Shut-off Equipment
416018	Cocking Lever (Mechanical Gas Valve)		Includes: Air Cylinder and Tube Assembly
▶ 438031	Lock Pin	434618	Remote Manual Pull Station Assembly
13707	Gas Shut-off Equipment (Electrical 110 VAC, 60 Hz) Includes: Solenoid Valve – 3/4 in.	435960	Remote Manual Pull Station Assembly Includes: 50 ft (15.2 m) of Wire Rope
13708	Gas Shut-off Equipment (Electrical 110 VAC, 60 Hz) Includes: Solenoid Valve – 1 in.	24915	Break Rod Package Includes: 10 Glass Break Rods (Part No. 4834) (Replacement)
550360	Gas Shut-off Equipment (Electrical 110 VAC, 60 Hz) Includes: Solenoid Valve – 1 1/4 in.	427074	Trim Rings (Pack of 10)
13709	Gas Shut-off Equipment (Electrical 110 VAC, 60 Hz)	434525	Flexible Conduit – 500 ft (152.4 m)
	Includes: Solenoid Valve – 1 1/2 in.	435959	Flexible Conduit – 500 ft (152.4 m)
13710	Gas Shut-off Equipment (Electrical 110 VAC, 60 Hz) Includes: Fluid Power Gas Valve – 2 in.		Includes: 500 ft (152.4 m) of Wire Rope
550363	Gas Shut-off Equipment (Electrical 110 VAC, 60 Hz) Includes: Fluid Power Gas Valve – 2 1/2 in.	435979	Flexible Conduit Strain Relief Includes: 50 Strain Reliefs
17643	Gas Shut-off Equipment (Electrical 110 VAC, 60 Hz) Includes: Fluid Power Gas Valve – 3 in.	434347	Flexible Conduit Inserts Includes: 50 Inserts

SECTION 9 – APPENDIX

UL EX3470 ULC EX3470


PAGE 9-8 REV. 11 2014-SEP-01

SYSTEM COMPONENT INDEX (Continued)

	0.0.	COMIT CITERT INDEX (Continued)
	Part No.	Description
•	439104	Pre-Fed Flexible Conduit – 50 ft (15.2 m)
•	436150	P-Clip Shipping Assembly Includes: 50 P-Clips
	31809	16 in. (406 mm) Stainless Steel Actuation Hose
	32335	20 in. (508 mm) Stainless Steel Actuation Hose
	32336	24 in. (610 mm) Stainless Steel Actuation Hose
	430815	42 in. (1067 mm) Stainless Steel Actuation Hose
	435982	Agent Distribution Hose and Restraining Cable Kit
	434455	Henny Penny Fryer Nozzle Kit
	24916	Test Link Shipping Assembly Includes: 10 Test Links
•	439085	SL Style Fusible Link – 165 °F (74 °C) Includes: 25 Links
	439086	SL Style Fusible Link – 212 °F (100 °C) Includes: 25 Links
	439087	SL Style Fusible Link – 280 °F (138 °C) Includes: 25 Links
	439088	SL Style Fusible Link – 360 °F (182 °C) Includes: 25 Links
	439089	SL Style Fusible Link – 450 °F (232 °C) Includes: 25 Links
	439227	Tyco A-PC Style Fusible Link – 165 °F (74 °C) Includes: 10 Links
	439228	Tyco A-PC Style Fusible Link – 212 °F (100 °C) Includes: 10 Links
	439229	Tyco A-PC Style Fusible Link – 280 °F (138 °C) Includes: 10 Links
	439230	Tyco A-PC Style Fusible Link – 360 °F (182 °C) Includes: 10 Links
	439231	Tyco A-PC Style Fusible Link – 450 °F (232 °C) Includes: 10 Links
	439232	Tyco A-PC Style Fusible Link – 500 °F (260 °C Includes: 25 Links
	439517	Trip Hammer Set Screw Includes: 25 Screws
	15240	Maximum Registering Thermometer
	197	Lead and Wire Seal
	181	Cartridge Receiver Gasket
	74274	Vent Plug Assembly
 	418087	R-102 System Manual

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 9-9

AUTOMAN REGULATED RELEASE ASSEMBLY



		Electrical
Description	Part No.	Part No.
Regulated Release Shipping Assembly	429853	429856
Mounting Box	419293	419293
Basic Release w/Regulator	79140	_
Basic Release w/Solenoid, Switch, and Regulator	_	79288
Self-Tapping Screw	71342	71342
Spacer	76555	76555
Tension Spring	79094	79094
Lever and Bracket Assembly	79300	79300
Machine Screw	14973	14973
Lockwasher	7310	7310
Hex Nut	14732	14732
Caution Label	57652	57652
Gasket	181	181
Expellant Gas Cartridge Assembly		
	423435 / 423441	423435 / 423441
Double Tank/101-30 (Ordered Separately)	423493 / 423443	423443 / 423443
Safety Shipping Cap	77251	77251
Tank Assembly 1.5/3 Gal. (Ordered Separately)	429864 / 429862	429864 / 429862
Hose Assembly	79007	79007
Enclosure Cover (Includes Label)	423744	423744
Solenoid Assembly	_	423575
Electric Snap-Action Switch	_	423878
Cover Screw	15362	15362
Speed Nut	423479	423479
Set Screw (25 Pack)	439517	439517
	Regulated Release Shipping Assembly Mounting Box Basic Release w/Regulator Basic Release w/Solenoid, Switch, and Regulator Self-Tapping Screw Spacer Tension Spring Lever and Bracket Assembly Machine Screw Lockwasher Hex Nut Caution Label Gasket Expellant Gas Cartridge Assembly LT-30-R/101-20 (Ordered Separately) Double Tank/101-30 (Ordered Separately) Safety Shipping Cap Tank Assembly 1.5/3 Gal. (Ordered Separately) Hose Assembly Enclosure Cover (Includes Label) Solenoid Assembly Electric Snap-Action Switch Cover Screw Speed Nut	Regulated Release Shipping Assembly

SECTION 9 – APPENDIX

UL EX3470 ULC EX3470

PAGE 9-10 REV. 11 2014-SEP-01

REGULATED ACTUATOR ASSEMBLY




Figure No.	Description	Part No.
	Regulated Actuator Assembly	429850
1	Mounting Box	419293
2	Pneumatic Actuator Assembly Including Regulator	79340
3	Hex Jam Nut	67990
4	Hole Adaptor (2)	423277
5	Lockwasher	69521
6	Gasket	181
7	Expellant Gas Cartridge Assembly LT-20-R/101-10 (Ordered Separately) LT-30-R/101-20 (Ordered Separately) Double Tank/101-30 (Ordered Separately) LT-A-101-30/101-30 (Ordered Separately)	423429 / 423439 423435 / 423441 423493 / 423443 423491 / 423443
8	Safety Shipping Cap	77251
9	Label	426953
10	Tank Assembly 1.5 / 3 Gal. (Ordered Separately)	429864 / 429862
11	Hose Assembly	79007
12	Enclosure Cover (Without Labels)	419294
13	Cover Screw	15362
14	Speed Nut	423479

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 9-11

ENCLOSURE ASSEMBLY




Figure No.	Description	Part No.
_	Enclosure Shipping Assembly	429870
1	Enclosure	419295
2	Cover	419296
3	Nameplate	429871
4	Screw	15362
5	Speed Nut	423479

SECTION 9 – APPENDIX

UL EX3470 ULC EX3470

PAGE 9-12 REV. 11 2014-SEP-01

BRACKET ASSEMBLY




Figure No.	Description	3 Gallon Part No.
_	Bracket Shipping Assembly	429878
1	Bracket Assembly	-
2	Grommet	14089
3	Grommet	8688
4	Wing Nut	12065

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 9-13

TANK ASSEMBLY




Figure No.	Description	1.5 Gallon Part No.	3 Gallon Part No.
_	Tank Assembly	429864	429862
1	Tank Adaptor Shipping Assembly	430103	79522
2	Pickup Tube Assembly	429883	417700
3	Vent Plug Assembly	74247	74247
4	O-Ring	56909	56909
5	Union Nut	417705	417705
6	Union Tail Piece	417706	417706
7	Burst Disc	416974	416974
8	Shell	429861	429860
9	Nameplate	N/A	N/A

SECTION 9 – APPENDIX

UL EX3470 ULC EX3470

PAGE 9-14 REV. 11 2014-SEP-01

REMOTE RELEASE




Figure		
No.	Description	Part No.
_	Remote Release	433485
1	Mounting Box	419295
2	Cover	419296
3	Maintenance Label	17351
4	Spring	79094
5	Speed Nut	423479
6	Machine Screw	14973
7	Hex Nut	14732
8	Lockwasher	7310
9	101 Release	433702
10	Spacer	76555
11	Screw	71342
12	Cover Screw	15362
13	Tension Lever and Bracket Assembly	79300
14	Gasket	181
15	101 Cartridge (Order Separately) (Not Shown)	(TC/DOT) 423439
		(DOT) 15850

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 9-15

MULTIPLE NOZZLE FRYER PROTECTION CALCULATION EXAMPLES


Example No. 1 – Donut Fryer Without Dripboard. This fryer has a frypot that measures 26 in. depth x 28 in. length (660 mm x 711 mm). Because the frypot exceeds the maximum dimensions for one nozzle, multiple nozzles will be required.

Procedure:

Find the area of the fryer by multiplying the 26 in. depth x the 28 in. length (660 mm x 711 mm) which equals 728 in.² (46,967 mm²). Using the 3N nozzle (approved for fryers with the longest side of 25 3/8 in. (644 mm) and a maximum of 370.5 in.² (23,903 mm²) in area), divide the total area of 728 in.² (46,967 mm²) by 370.5 in.² (23,903 mm²) to find the number of nozzles needed. 728 in.² (46,967 mm²) divided by 370.5 in.² (23,903 mm²) per nozzle = $\frac{2 \text{ nozzles}}{2 \text{ nozzles}}$ required. Then, verify the maximum longest side dimension of 25 3/8 in. (644 mm). Doing this will require doubling the 3N nozzles to = a total of 4 nozzles, if we are to protect the 26 in. (660 mm) depth and the 28 in. (711 mm) length of the fryer with this 3N nozzle option. See Figure 9-1.

Using the same process, but utilizing the 3N nozzle approved for fryer protection with the longest side of 27 5/8 in. (702 mm) and the maximum of 324 in.² (20,903 mm²) in area, the calculation will change to 728 in.² (46,967 mm²) divided by 324 in.² (20,903 mm²) per nozzle = 3 nozzles. Because this 3N nozzle option will protect 27 5/8 in. (701 mm) on the longest side, it will protect the 26 in. (660 mm) side in this example, thus eliminating the need for extra nozzles. Utilizing this option, in this example, will require a total of 9 flows, but allows less nozzles and less nozzle drops*. See Figure 9-1.

* **Note:** 2-flow appliance nozzles can also be used. This option requires a total of 4 nozzles (728 in.² (46,967 mm²) divided by 210 in.² (13,548 mm²) per nozzle = 4 nozzles, or 8 total flows). Using this option requires that the nozzles be placed over each quadrant of frypot area protected and aimed to the center of the modules. This option may be desirable if minimizing total system flows is important.






FIGURE 9-1

Example No. 2 – Fryer With Dripboard. This fryer has an overall fry vat, including a dripboard, that measures 24 in. (609 mm) in depth x 20 in. (508 mm) in length. The actual frypot measures 20 in. x 20 in. (508 mm x 508 mm). Because both the frypot and the overall fry vat including the dripboard exceed the maximum dimensions for one nozzle, multiple nozzles will be required.

Procedure:

Divide the fryer cooking area from left to right or from front to back into modules that do not exceed single nozzle area limitations and longest side limitations as described in the table for "Fryer Multiple Nozzle Protection" located in the Design Section.

The example fryer can either be divided from left to right into two modules, each measuring 10 in. x 24 in. (254 mm x 609 mm), or it can be divided from front to back. See Figure 9-2.

If the fryer is divided from front to back, two 2-flow nozzles may be adequate. To determine this, first protect as much of the rear portion of the vat (the frypot area) that is allowed with 2-flow appliance nozzles using the maximum area of 210 in.² (13,548 mm²) per nozzle with the maximum longest side of 21 in. (533 mm) for multiple nozzles. See Figure 9-2.

In the example, the frypot is 20 in. (508 mm) from side to side. Use the maximum area of 210 in. 2 (13,548 mm 2) allowed for one nozzle and divide it by 20 in. (508 mm), a total of 10 1/2 in. (266 mm) of the frypot can be protected with one 2-flow nozzle (210 in. 2 divided by 20 in. = 10.5 in.). See Figure 9-2.

This leaves the remainder of 9 1/2 in. (241 mm) of frypot and the entire dripboard yet to protect. One 2-flow appliance nozzle will protect up to 10 1/2 in. (266 mm) of frypot, therefore, there is no need to verify the remaining 9 1/2 in. (241 mm). There is only the overall of 9 1/2 in. (241 mm) remaining plus the dripboard to verify.

The dripboard measures 4 in. x 20 in. (101 mm x 508 mm), with an overall remainder of frypot + dripboard area size of 13 1/2 in. x 20 in. (342 mm x 508 mm) = 270 in.² (17,419 mm²). Reviewing the "Multiple Nozzle Fryer Table," a 2-flow appliance nozzle can protect an area, including dripboard, of 294 in.² (18,967 mm²) with a longest side of 21 in. (533 mm). Because the area is less than the maximum of 294 in.² (18,967 mm²) and the longest side is less than the maximum of 21 in. (533 mm), a 2-flow nozzle will be sufficient. See Figure 9-2.

SECTION 9 – APPENDIX

UL EX3470 ULC EX3470

PAGE 9-16 REV. 11 2014-SEP-01

MULTIPLE NOZZLE FRYER PROTECTION CALCULATION EXAMPLES (Continued)

Example No. 2 - Fryer With Dripboard (Continued)

Adding the protection required for the back of the frypot to the front protection requires two **2-flow appliance nozzles** as a minimum. See Figure 9-2.




FIGURE 9-2

WIRING DIAGRAM

NFPA standards require simultaneous operation for fire suppression systems when two or more hazards can be simultaneously involved in fire by reason of their proximity. To accomplish simultaneous operation, the 120 VAC Electric AUTOMAN Regulated Release Assembly can be used. This release can be activated independently by fusible line operation exactly like the mechanical version and can also be triggered electrically using a snap action switch from another 120 VAC Electric AUTOMAN Regulated Release Assembly or a Mechanical AUTOMAN Regulated Release Assembly. The electrical wiring used to connect from one AUTOMAN Regulated Release Assembly to another will not be supervised. However, NFPA 96 allows an exception for electrically operated systems which "include automatic mechanical detection (fusible link) and actuation as a backup detection system."

In the case of multiple hoods sharing a common exhaust duct, NFPA 17A requires one of two forms of simultaneous operation. The following wiring diagrams (See Figures 3 and 4) identify two principle uses for the 120 VAC Electric AUTOMAN Regulated Release Assembly. Refer to Components Section, Page 3-1, Figure 3-3.

- 1. Simultaneous operation of all independent hood, duct, and appliance protection systems. See Figure 9-3.
- 2. Simultaneous operation of any hood, duct, and appliance protection system and the system(s) protecting the entire common exhaust duct. See Figure 9-4.

Simultaneous Actuation of Multiple 120 VAC Electric AUTOMAN Regulated Release Assemblies





FIGURE 9-3

UL EX3470 ULC EX3470 2014-SEP-01 REV. 11 PAGE 9-17

WIRING DIAGRAM (Continued)

Simultaneous Actuation of One or More 120 VAC Electric AUTOMAN Assemblies from Multiple Mechanical AUTOMAN Assemblies



- Note 1: For fusible link detection only.
- Note 2: Use AUTOMAN assemblies with solenoid and electric switch. Replace Single Electric Switch (Part No. 423878) with Dual Switch Kit (Part No. 423879).
- Note 3: See Installation section of this manual for power capacity of solenoid and switches.
- Note 4: This method does not provide supervision for battery or system wiring. The authority having jurisdiction (AHJ) may waive this requirement.
- Note 5: When any one of the Mechanical AUTOMAN assembles is activated, the microswitch will transfer to the N.O. position, completing the circuit to the N.C. switch in the Electrical AUTOMAN assembly. This will activate the AUTOMAN assembly. When the AUTOMAN assembly fires, the N.C. switch transfers to the N.O. position, opening the circuit to the solenoid.

R-102 Restaurant Fire Suppression Manual

SECTION 9 – APPENDIX

UL EX3470 ULC EX3470

PAGE 9-18 REV. 11 2014-SEP-01

NOTES: